

ENVIRONMENTAL QUALIFICATION OF SAFETY-RELATED  
ELECTRICAL EQUIPMENT  
IEB 79-01B

TECHNICAL EVALUATION REPORT

DOCKET NO. 50-306

DATED: November 17, 1980

Licensee: Northern States Power Co.  
Type Reactor: W PWR  
Plant: Prairie Island Unit 2

Prepared by S. J. Jablonski  
Engineering Support Section  
Reactor Construction and Engineering  
Support Branch, RIII

8106010590

## CONTENTS

|   | <u>Page</u> |
|---|-------------|
| Introduction                            | 1           |
| Background and Discussion               | 1           |
| Summary of Licensee Actions/Statements  | 1           |
| System Comparison                       | 2           |
| Equipment Evaluation                    | 2 - 4 - 8   |
| Caveat                                  | 2           |
| Conclusion                              | 2           |
| Attachments:                            |             |
| 1. Referenced Test Reports              |             |
| 2. Onsite Inspection Report             |             |
| 3a. Generic Issues                      |             |
| 3b. Site Specific Issues                |             |
| 4. Licensee System List                 |             |
| 5. NRR's System List                    |             |
| 6. Category Criteria                    |             |
| 7. LER's                                |             |
| 8. Unresolved Generic - Specific Issues |             |
| 9. Concurrence Code                     |             |

## Introduction

This report is submitted in accordance with TI 2515/41<sup>1/</sup> for use as input to the Safety Evaluation Report on qualification of Class 1E electrical equipment installed in potentially "harsh" environmental areas at this facility.

## Background and Discussion

IE Bulletin No. 79-01<sup>2/</sup> required the licensee to perform a detailed review of the environmental qualification of Class 1E equipment to ensure that the equipment would function under (i.e. during and following) postulated accident conditions.

The Technical Evaluation Report (TER) is based on IE's review of the licensee's submittal for conformance with the DOR guidelines or NUREG-0588, a site inspection of selected system components, to verify accuracy of the submittal, and EQB's review of component test reports.<sup>3/</sup>

Licensee submittals were received on March 13, 1980, May 12, 1980, May 23, 1980, July 10, 1980 and October 31, 1980.

The site inspection was completed on September 26, 1980. <sup>4/</sup> Generic and site specific guidance was requested from IE/NRR headquarters.<sup>5/</sup>

## Summary of Licensee Actions/Statements

Based upon evaluation of Class 1E equipment, licensee believes he has complied with the requirements of Bulletin 79-01B. Licensee believes that with the completion of the action items noted, there will exist no outstanding items which would preclude the continued safe operation of Prairie Island Unit 2. Replacement of solenoid valves, limit switches and other instruments is being accomplished as material is received and scheduled for installation during the next outage. Present schedules call for Unit 2 to be shutdown in February 1981. All modifications will be completed by June 1982.

- 1/ Technical Evaluation Report (TER) On Results Of Staff Actions Taken To Verify Reactor Licensee Response To IEB 79-01B And Supplemental Information.
- 2/ Environmental Qualification of Class 1E Equipment.
- 3/ Attachment 1.
- 4/ Attachment 2.
- 5/ Attachments 3a and 3b.

### System Comparison

A comparison was made between the systems list provided by the licensee<sup>6/</sup> and a similar list provided to IE by NRR<sup>7/</sup> during a meeting in Bethesda, MD on September 30, 1980. The following systems were not included in the licensee's submittal.

- . Pressurizer Spray
- . Emergency Power
- . Control Room Habitability
- . Safety Equipment Area Ventilation

### Equipment Evaluation

Class 1E equipment was evaluated, that is, placed into five separate categories.<sup>8/</sup> Result of the evaluation follows: (See pages following)

### Caveat

Test reports and other documentation which licensees referenced as establishing environmental qualification were reviewed for acceptability by NRR, Environmental Qualification Branch. (Reference Attachment 3a, memorandum dated June 20, 1980 Hayes to Jordan.)

This TER does not include information about seismic or fire withstand capability. It should therefore not be inferred that Category I equipment meets all necessary qualification requirements.

### Conclusion

Based on IE's review of the licensee's submittal, the site inspection, and licensee's proposed actions, it cannot be concluded that there is reasonable assurance all components installed at the Prairie Island Unit 2 are environmentally qualified and installation methods of environmentally qualified components would not contribute to the failure of such components during a potential accident.

A positive conclusion cannot be made until:

1. All matters referred to IEHQ/S/NRR have been satisfied.<sup>9/</sup>
2. The 4 systems missing from the licensee's submittal have been evaluated by NRR. (Page 2)
3. The negative equipment evaluations have been reviewed by NRR. (Pages 4, 5, 6, and 8.)

<sup>6/</sup> Attachment 4.

<sup>7/</sup> Attachment 5.

<sup>8/</sup> Attachment 6.

<sup>9/</sup> Attachment 8.

Blank

POOR ORIGINAL

| CAT    | DESCRIPTION | MANUFACTURER | MOD/TYPE          | NOTES                 | LOC     | OP TIME    | TEMP | PRESS | RH  | SPRV                                   | RAD                  | AGING                           | ATTI REFD  | CONCUR?    |
|--------|-------------|--------------|-------------------|-----------------------|---------|------------|------|-------|-----|--|----------------------|---------------------------------|------------|------------|
| Ia 2   | MOV         | Limitorque   | SMB-00            | Fw to<br>Stm Gen      | AUX     | 69 Hrs     | 325  | 74.7  | 100 | -                                      | -                    | 40 Yr                           | 1, 2, 3    | Yes-A      |
| Ia 4   | MOV         | Limitorque   | SMB-00            | KCP seal<br>Wat Ret   | AUX     | 69 Hrs     | 325  | 74.7  | 100 | -                                      | -                    | 40 Yr                           | 1, 2, 3    | Yes-A      |
| Ia 5   | MOV         | Limitorque   | SMB-00            | Excess<br>Letdown     | CNT     | 6 days     | 325  | 104.7 | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 204X10 <sup>8</sup>  | 40 Yr                           | 4, 1, 2    | No-B, C    |
| Ia 9   | MOV         | Limitorque   | SMB-000           | Fan Coil<br>Unit Chg  | CNT     | 69 Hrs     | 325  | 74.7  | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 204X10 <sup>8</sup>  | 40 Yr                           | 1, 2, 3    | Yes-A      |
| Ia 12  | Motor       | W            | L1054-1769<br>875 | Fan Coil<br>Units     | CNT     | 20 MDS.    | 324  | 94.7  | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2X10 <sup>8</sup>    | 40 Yr                           | 7          | No-L, P, Q |
| Ia 13  | Fan/Motor   | Joy          | 600277-69         | Dome<br>Reirc         | CNT     | 1 Yr       | 300  | 89.7  | 100 | Caustic                                | 5X10 <sup>7</sup>    | 2.5 Yr                          | 8          | No-M, P, Q |
| Ia 14  | Sol. Vv.    | ASCO         | NP-8321A1E        | Gap & Vent<br>Dampers | CNT     | 30 days    | 300  | 84.7  | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 1.5X10 <sup>8</sup>  | 4.4 Yr                          | 9          | No-G       |
| Ia 20  | 110V        | Limitorque   | SMB-000           | Supply &<br>Venting   | CNT     | 6 days     | 325  | 104.7 | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 204X10 <sup>8</sup>  | 40                              | 4, 1       | No-B, C    |
| Ia 20A | MOV         | Limitorque   | SMB-000           | Supply &<br>Venting   | CNT     | 6 days     | 325  | 104.7 | -   | -                                      | 2.04X10 <sup>8</sup> | 40                              | 1          | Yes-A      |
| Ia 20B | Sol. Vv.    | ASCO         | NP-8321A1E        | Air Supply<br>Event   | Annulus | 30 dup     | 300  | 84.7  | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 1.5X10 <sup>8</sup>  | 4.4 Yr                          | 9          | No-G       |
| Ia 27  | Limit Sw    | NAMCO        | EA-170            | Contmt<br>Purge (End) | Annulus | 200 hrs    | 200  | -     | 100 | -                                      | 207X10 <sup>8</sup>  | 200 <sup>9</sup> (?)<br>200 hrs | 92         | No-N       |
| Ia 28A | Limit Sw.   | Honeywell    | BZ-2RWS9942       | Contmt<br>Purge (End) | Annulus | Continuous | 180  | 5.92  | -   | -                                      | -                    | 5 Yrs                           | 43, 19, 11 | No-N, G    |
| Ia 28B | Sol. Vv.    | ASCO         | NP-8321A1E        | Vac.<br>Brkr.         | Annulus | 30 days    | 300  | 84.7  | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 1.5X10 <sup>8</sup>  | 4.4 Yr                          | 9          | No-G       |
| Ia 31  | MOV         | Limitorque   | SMB-0             | Contmt<br>SP Pp       | AUX     | 69 hrs     | 325  | 74.7  | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2X10 <sup>8</sup>    | 40 Yr                           | 1, 2, 3    | Yes-A      |
| Ia 32  | MOV         | Limitorque   | SMB-0             | Contmt<br>SP Pp       | AUX     | 69 hrs     | 325  | 74.7  | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2X10 <sup>8</sup>    | 40 Yr                           | 1, 2, 3    | Yes-A      |

Attachment 9

Prairie Island # 2

Page 1 of 7

POOR ORIGINAL

| CAT    | DESCRIPTION | MANUFACTURER    | MOD/TYPE    | NOTES                          | LOC | OP TIME | TEMP    | PRESS     | RH  | SPRAY                                  | RAD                 | AGING | ATTJ REFL | CONCUR? |
|--------|-------------|-----------------|-------------|--------------------------------|-----|---------|---------|-----------|-----|--|---------------------|-------|-----------|---------|
| Ia 3d  | Press Xmtr  | Foxboro         | E116M-SADI  | Accum                          | CNT | 24hrs   | 318     | 104.7     | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 76X10 <sup>7</sup>  | —     | 14        | No-FH,E |
| Ia 39  | MOV         | Limitorgue      | SMB-3       | Sim. Gen.<br>FW contnt<br>150L | AUX | 69hrs   | 325     | 74.7      | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2X10 <sup>8</sup>   | 40Yr  | 1, 2, 3   | Yes-A   |
| Ia 42A | RTD         | SSTM            | 11901B      | RCS Temp<br>Wide               | CNT | 2 WKS   | 320     | 80.7      | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 5X10 <sup>7</sup>   | 12Yr  | 17        | No-G    |
| Ia 48B | RTD         | Rosemount       | 176 KS      | RCS Temp<br>Wide               | CNT | 2 WKS   | 320     | 80.7      | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 5X10 <sup>7</sup>   | 12Yr  | 17        | No-G    |
| Ia 45  | Transducer  | Fisher Controls | S46         | stan Gen<br>Rif                | AUX | —       | —       | —         | —   | —                                      | —                   | —     | 18        | Yes-A   |
| Ia 47  | Sol. Vv.    | ASCO            | NR83/6E35E  | MSIV                           | AUX | 30 days | 300     | 84.7      | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 1.5X10 <sup>8</sup> | 4.4Yr | 9         | No-G    |
| —      | —           | —               | —           | —                              | —   | —       | —       | —         | —   | —                                      | —                   | —     | —         | —       |
| Ia 55A | MOV         | Limitorgue      | SMB-00      | AFW Pp                         | AUX | 69hrs   | 325     | 74.7      | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2X10 <sup>8</sup>   | 40    | 1, 2, 3   | Yes-A   |
| Ia 56  | Limit Sw    | NAMCO           | D2400X      | MSIV (END)<br>PORV             | AUX | —       | 194/210 | 14.7/15.2 | 100 | —                                      | —                   | —     | 20        | No-O*   |
| Ia 58  | Limit Sw    | NAMCO           | D2400X      | S/G & (END)<br>PORV            | AUX | —       | 194/210 | 14.7/15.2 | 100 | —                                      | —                   | —     | 20        | No-O*   |
| Ia 74  | MOV         | Limitorgue      | SMB-00      | Press Rif<br>Vv Isol           | CNT | 69hrs   | 325     | 74.7      | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 20X10 <sup>8</sup>  | 40    | 1, 2, 3   | Yes-A   |
| —      | —           | —               | —           | —                              | —   | —       | —       | —         | —   | —                                      | —                   | —     | —         | —       |
| Ia 76A | Sol. Vv.    | ASCO            | NR83/654E   | Press rif<br>Vv                | CNT | 30 days | 300     | 84.7      | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 1.5X10 <sup>8</sup> | 4.4Yr | 9         | No-G    |
| Ia 81  | Sol. Vv.    | ASCO            | NR83/0A186E | Rx Cont<br>Samp                | CNT | 30 days | 300     | 84.7      | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 1.5X10 <sup>8</sup> | 4.4Yr | 9         | No-G    |
| Ia 83  | Sol. Vv.    | ASCO            | NR83/0A182E | SG Samp<br>Line                | CNT | 30 days | 300     | 84.7      | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 1.5X10 <sup>8</sup> | 4.4Yr | 9         | No-G    |

| CAT    | DESCRIPTION | MANUFACTURER | MOD/TYPE | NOTES                  | LOC | OP TIME                   | TEMP | PRESS | RH   | SPRAY                                  | RAD                 | AGING  | ATTN REF    | CONCUR?       |
|--------|-------------|--------------|----------|------------------------|-----|---------------------------|------|-------|------|--|---------------------|--------|-------------|---------------|
| Ia 90  | Motor       | W            | HSD-P    | Class B RHR PPS        | AUX | Not (M) ?<br>Required (R) | NR ? | NR ?  | NR ? | —                                      | 2x10 <sup>8</sup>   | 40 yr  | 21          | No-J, N       |
| Ia 96  | MOV         | Limitorque   | SMB-00   | SI PP Suct             | AUX | 69hrs                     | 325  | 74.7  | 100  | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2x10 <sup>8</sup>   | 40 yr  | 1, 2, 3     | Yes -         |
| Ia 97  | MOV         | Limitorque   | SMB-00   | SI PP-RHR HX           | AUX | 69hrs                     | 325  | 74.7  | 100  | —                                      | 2x10 <sup>8</sup>   | 40 yr  | 1, 2, 3     | Yes - A       |
| Ia 100 | MOV         | Limitorque   | SMB-1    | Calmt Sump B           | AUX | 69hrs                     | 325  | 74.7  | 100  | —                                      | 2x10 <sup>8</sup>   | 40 yr  | 1, 2, 3     | Yes - A       |
| Ia 101 | MOV         | Limitorque   | SMB-00   | RCS cid Leg Inj        | AUX | 69hrs                     | 325  | 74.7  | 100  | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2x10 <sup>8</sup>   | 40 yr  | 1, 2, 3     | Yes - A       |
| Ia 102 | MOV         | Limitorque   | SMB-00   | SI to RV Vessel        | AUX | 69hrs                     | 325  | 74.7  | 100  | —                                      | 2x10 <sup>8</sup>   | 40 yr  | 1, 2, 3     | Yes - A       |
| Ia 103 | MOV         | Limitorque   | SMB-0    | RWST Suct              | AUX | 69hrs                     | 325  | 74.7  | 100  | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2x10 <sup>8</sup>   | 40 yr  | 1, 2, 3     | Yes - A       |
| Ia 104 | MOV         | Limitorque   | SMB-1    | (-1) Flood Accum       | CNT | 6 days                    | 325  | 104.7 | 100  | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2x10 <sup>8</sup>   | 40 yr  | 1, 2, 4     | No-B, C, F, H |
| Ia 105 | MOV         | Limitorque   | SMB-00   | (-1) Flood Cod leg Inj | CNT | 6 days                    | 325  | 104.7 | 100  | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2x10 <sup>8</sup>   | 40 yr  | 1, 2, 4     | No-B, C, F, H |
| Ia 106 | MOV         | Limitorque   | SMB-1    | Lo Head Inj            | CNT | 6 days                    | 325  | 104.7 | 100  | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2x10 <sup>8</sup>   | 40 yr  | 1, 2, 4     | No-B, C       |
| Ia 107 | MOV         | Limitorque   | SMB-00   | Rx Vsl Inj Line        | CNT | 6 days                    | 325  | 104.7 | 100  | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2x10 <sup>8</sup>   | 40 yr  | 1, 2, 4     | No-B, C       |
| Ia 108 | MOV         | Limitorque   | SMB-00   | Rx Vsl Inj (-1) Flood  | CNT | 6 days                    | 325  | 104.7 | 100  | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2x10 <sup>8</sup>   | 40 yr  | 1, 2, 4, 44 | No-B, C       |
| Ia 109 | MOV         | Limitorque   | SMB-00   | SI Suct BAT            | AUX | 69hrs                     | 325  | 74.7  | 100  | —                                      | 2x10 <sup>8</sup>   | 40 yr  | 1, 2, 3     | Yes - A       |
| Ia 109 | Motor       | W            | HSD-P    | SI PUMP                | AUX | Not (M) ?<br>Required (R) | NR ? | NR ?  | NR ? | —                                      | 2x10 <sup>8</sup>   | 40 yr  | 21          | No-J, N       |
| Ia 116 | SolTV       | ASCO         | WPSSTATE | SI Inj Ext Air         | CNT | 30 days                   | 300  | 89.7  | 100  | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 1.5x10 <sup>8</sup> | 4.4 yr | 9           | No-G          |

POOR ORIGINAL



| CAT     | DESCRIPTION     | MANUFACTURER  | MOD/TYPE         | NOTES                          | LOC         | OP TIME                  | TEMP | PRESS | RH  | SPRAY                                  | RAD                 | AGING | ATTI REF#  | CONCUR?     |
|---------|-----------------|---------------|------------------|--------------------------------|-------------|--------------------------|------|-------|-----|--|---------------------|-------|------------|-------------|
| Ia 118  | MOV             | Limitorgue    | SMB-00           | Stm Gen<br>Iso                 | CNT         | 6 days                   | 325  | 104.7 | 100 | H <sub>3</sub> BO <sub>3</sub><br>NaOH | 204x10 <sup>8</sup> | 40yr  | 1, 2, 4    | No-B, C     |
| Ia 120  | Fuse Holder     | Bussman       | HEB-A            | MSIV's                         | AUX         | 5 Hrs                    | 149  | 14.7  | Imm | —                                      | 5.5x10 <sup>8</sup> | 40yr  | 23, 13     | Yes-A       |
| Ia 121  | Lube Oil        | Mobil         | DTE-AVY MED      | —                              | AUX         | Not (N)?<br>Required (R) | NR?  | NR?   | NR? | —                                      | 2x10 <sup>8</sup>   | NR?   | 24         | No-J, N     |
| Ia 122  | Grease          | Chevron       | SRI-2            | —                              | AUX/<br>CNT | Not (N)?<br>Required (R) | 350  | NR?   | NR? | NR?                                    | 2x10 <sup>8</sup>   | NR?   | 25, 7, 26  | No-J, N     |
| Ia 125A | Splice Kit      | OKonite       | 604-92-1511      | (-) Flood                      | AUX/<br>CNT | 3 mos                    | 346  | 127.7 | 100 | H <sub>3</sub> BO <sub>3</sub><br>NaOH | 2x10 <sup>8</sup>   | 40yr  | 30, 31     | No-F, H, Q  |
| Ia 126  | Cable, Power    | OKonite       | —                | (-) Flood                      | AUX/<br>CNT | 3 mos                    | 346  | 127.7 | 100 | H <sub>3</sub> BO <sub>3</sub><br>NaOH | 2x10 <sup>8</sup>   | 40yr  | 30         | No-F, H, Q  |
| Ia 127  | Cable, Pwr/Cont | Kerite        | HTK & FR         | (-) Flood                      | AUX/<br>CNT | 3 wks                    | 320  | 96.7  | 100 | H <sub>3</sub> BO <sub>3</sub><br>NaOH | 2x10 <sup>8</sup>   | 40yr  | 1, 33, 34  | No-F, H, Q  |
| Ia 129  | Cable, Inst     | BIW           | —                | (-) Flood*                     | AUX/<br>CNT | 24 Hrs / *<br>30 days    | 316  | 104.7 | 100 | H <sub>3</sub> BO <sub>3</sub><br>NaOH | 2x10 <sup>8</sup>   | 40yr  | 35, 36     | No-O*, F, H |
| Ib 30   | Motor           | Elec Mach MFG | —                | CNT SP<br>Pump                 | AUX         | Not (N)?<br>Required (R) | NR?  | NR?   | NR? | —                                      | 1x10 <sup>8</sup>   | 40yr  | 12, 13, 45 | No-J, N     |
| Ib 38   | Flow xmtr       | Foxboro       | E13DH<br>(MCA)   | Stm Gen<br>FW In               | AUX         | 24 hrs                   | 300  | 74.7  | 100 | —                                      | —                   | —     | 14         | No-E        |
| Ib 130  | Penetration     | D.G. O'brien  | S/N Pr-110 (MVP) | —                              | AUX/<br>CNT | 48 hrs                   | 270  | 66.7  | 100 | H <sub>3</sub> BO <sub>3</sub><br>NaOH | 3x10 <sup>8</sup>   | —     | 37, 39, 38 | No-H, R, S  |
| Ib 131  | Penetration     | D.G. O'brien  | S/N Pr-12 (LVP)  | —                              | AUX/<br>CNT | 10 days                  | 270  | 66.7  | 100 | H <sub>3</sub> BO <sub>3</sub><br>NaOH | 3x10 <sup>8</sup>   | —     | 37, 38, 39 | No-H, R, S  |
| Ib 131A | Penetration     | D.G. O'brien  | S/N Pr-2 (TI)    | —                              | AUX/<br>CNT | 48 hrs                   | 270  | 66.7  | 100 | H <sub>3</sub> BO <sub>3</sub><br>NaOH | 3x10 <sup>8</sup>   | —     | 37, 38, 39 | No-H, R, S  |
| IIa     | None            | —             | —                | —                              | —           | —                        | —    | —     | —   | —                                      | —                   | —     | —          | —           |
| IIb 6   | Limit Sw.       | NAMCO         | EA 180           | (-) Flood<br>Lt Dwn Iso<br>End | CNT         | 30 days                  | 340  | 84.7  | 100 | H <sub>3</sub> BO <sub>3</sub><br>NaOH | 204x10 <sup>8</sup> | 40yr  | 5, 6       | No-F, H, I  |

POOR ORIGINAL

# Analysis

Prairie Island # 2

Page 4 of 7

| CAT     | DESCRIPTION                    | MANUFACTURER  | MOD/T/PE            | NOTES                        | LOC        | OP TIME                  | TEMP | PRESS | RH          | SPRAY                                  | RAD                 | AGING | ATTN REFD | CONCUR?               |
|---------|--------------------------------|---------------|---------------------|------------------------------|------------|--------------------------|------|-------|-------------|--|---------------------|-------|-----------|-----------------------|
| IIb 7   | Limit Sw                       | NAMCO         | D2400X              | (-Flood<br>4+ on ISO<br>IND  | CNT        | —                        | —    | —     | —           | —                                      | —                   | —     | —         | NO-F, H, I            |
| IIb 15  | Limit Sw                       | NAMCO         | EA-180              | Air Hnd<br>Damp Ind          | CNT        | 30 days                  | 340  | 84.7  | 100         | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 204X10 <sup>8</sup> | 40    | 5         | Yes-A, T              |
| IIb 20  | Limit Sw                       | NAMCO         | EA-180              | Purg 5 rh<br>Ind             | CNT        | 30 days                  | 340  | 84.7  | 100         | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 204X10 <sup>8</sup> | 40    | 5         | Yes-A, T              |
| IIb 42D | Incore Thermo<br>Ref. Junc Box | ETI           | K81                 | Sub Cly<br>Meter             | CNT        | —                        | —    | —     | —           | —                                      | —                   | —     | —         | Yes-D                 |
| IIb 76  | Limit Sw                       | NAMCO         | EA-180              | Psr Rif<br>Vv Ind            | CNT        | 30 days                  | 340  | 84.7  | 100         | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 204X10 <sup>8</sup> | 40    | 5         | Yes-A, T              |
| IIb 78  | Limit Sw                       | NAMCO         | EA-180              | Rad<br>Monit                 | CNT        | 30 days                  | 340  | 84.7  | 100         | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 204X10 <sup>8</sup> | 40    | 5         | Yes-A, T              |
| IIb 114 | Limit Sw                       | NAMCO         | EA-180              | Strp Inst<br>Air Ind         | CNT        | 30 days                  | 340  | 84.7  | 100         | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 204X10 <sup>8</sup> | 40    | 5         | Yes-A, T              |
| IIb 133 | DC. Dist Pnl                   | Creiger Elec  | —                   | PWR to<br>DC. Aux            | CNT        | —                        | —    | —     | —           | —                                      | —                   | —     | —         | Yes-D, E              |
| III     | None                           | —             | —                   | —                            | —          | —                        | —    | —     | —           | —                                      | —                   | —     | —         | —                     |
| IVa 41  | Accelerometer                  | Endevco       | 2273 AM20           | Rif. Vv.<br>Monitor          | CNT        | —                        | —    | —     | —           | —                                      | —                   | —     | 16        | Yes-U                 |
| IVa 42  | Charge Amp                     | Unholz-Dickey | 22CA-2TR            | Rif. Vv.<br>Monitor          | CNT        | —                        | —    | —     | —           | —                                      | —                   | —     | —         | Yes-U                 |
| IVa 42a | Press Xmtr                     | Foxboro       | E11GM-5AE1<br>(MCA) | Psr<br>Press                 | CNT        | 24 hrs                   | 300  | 74.7  | 100         | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2X10 <sup>8</sup>   | —     | 14        | Yes-A, V<br>NO-W      |
| IVa 63  | Press Xmtr                     | Foxboro       | E11GM (med)         | Strp<br>press                | AUX        | 24 hrs                   | 300  | 74.7  | 100         | —                                      | —                   | —     | 14        | Yes-A, V              |
| IVa 110 | Flow Xmtr                      | Barton        | 332                 | SI                           | AUX        | Not (N)?<br>Required (2) | NR?  | NR?   | NR?         | —                                      | 2X10 <sup>8</sup>   | —     | 1         | NO-J, M, E            |
| IVa 123 | Terminal Block<br>Coating      | 6E            | 74010/<br>74010A    | (-Flood*<br>Epoxy<br>Vainish | AUX<br>CNT | Not (N)?<br>Required (2) | 500° | NR?   | Wat.<br>Res | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 3.6X10 <sup>7</sup> | —     | —         | NO-F, H, O*Y<br>Yes-X |

Prairie Island # 2

19 Attachment 9

POOR ORIGINAL

| CAT     | DESCRIPTION          | MANUFACTURER  | MOD/TYPE          | NOTES                     | LOC                 | OP TIME | TEMP | PRESS | RH  | SPRNY         | RAD               | AGING | ATTN REF# | CONCUR ?                                  |
|---------|----------------------|---------------|-------------------|---------------------------|---------------------|---------|------|-------|-----|---------------|-------------------|-------|-----------|---|
| IVa 124 | Terminal Block/Strip | Allen Bradley | 1492-CD3          | —                         | AUX CNT             | *       | ‡    | †     | *   | *             | *                 | *     | —         | No-V <sub>1</sub> J <sub>2</sub><br>Yes-X |
| IVb 42F | Press Xmtr           | Foxboro       | E115M-SAE1 (0589) | Prsr Press                | CNT                 | 24 hrs  | 300  | 747   | 100 | M5603<br>N40H | 2X10 <sup>8</sup> | —     | 14        | Yes-A, V<br>No-W                          |
| V 18    | Sol. Vv.             | ASCO          | RHT8321A1         | Air Hndly Unit            | CNT                 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.<br>Yes-D.O.                      |
| V 23    | Sol Vv               | ASCO          | 8321A1            | Vacuum Breaker            | A <sub>1</sub> 4/16 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.<br>Yes-D.O.                      |
| V 25    | Limit Sw             | NAMCO         | D2400 X           | CNT                       | CNT                 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.                                  |
| V 28    | Limit Sw             | NAMCO         | D2400 X           | CNT                       | CNT                 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.                                  |
| V 36    | Level Xmtr           | Magnetrol     | A-53-FEPIVX TO    | CNT (1-512)<br>SUMP Level | CNT                 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.                                  |
| V 42C   | Press Xmtr           | Foxboro       | E11GH             | RCS Press                 | CNT                 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.                                  |
| V 62    | Flow Xmtr            | Barton        | 384               | stm Flow to R Pot         | CNT                 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.                                  |
| V 64    | Level Xmtr           | Foxboro       | E13DH-SAMI        | stm Gen Lev L R Pot       | CNT                 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.                                  |
| V 74    | Limit Sw             | NAMCO         | D2400 X           | Rad Monit                 | CNT                 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.                                  |
| V 85    | Limit Sw             | NAMCO         | D2400 X           | Rx Hot Sampl              | CNT                 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.                                  |
| V 91    | Limit Sw             | NAMCO         | D2400 X           | RNR Ind                   | AUX                 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.                                  |
| V 112   | Sol. Vv.             | ASCO          | RHT832427         | Stn 6 Inst Air            | CNT                 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.                                  |
| V 115   | Limit Sw             | NAMCO         | D2400 X           | Stn 6 Inst Air            | CNT                 | —       | —    | —     | —   | —             | —                 | —     | —         | Yes-D.O.                                  |

Prairie Island # 2

Attachment 9

**POOR ORIGINAL**

| CAT     | DESCRIPTION | MANUFACTURER | MOD/TYPE    | NOTES               | LOC     | OP TIME | TEMP | PRESS | RH  | SPRNY                                  | RAD                 | AGING  | ATTI REFD | CONCUR ?       |
|---------|-------------|--------------|-------------|---------------------|---------|---------|------|-------|-----|--|---------------------|--------|-----------|----------------|
| Ia 24   | Sol. Vv     | ASCO         | NP831654E   | CNT Purge           | Annulus | 30 days | 300  | 84.7  | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 1.5x10 <sup>8</sup> | 4.4 yr | 9         | No-G           |
| Ia 46   | Transducer  | Fisher Cont. | 546         | Stm Dump            | AUX     | —       | —    | —     | —   | —                                      | —                   | —      | 18        | Yes-A          |
| Ia 113A | Sol. Vv     | ASCO         | NP8321A1E   | Stn Inst Air        | AUX     | 30 days | 300  | 84.7  | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 1.5x10 <sup>8</sup> | 4.4 yr | 9         | No-G           |
| Ia 113B | Sol. Vv     | ASCO         | NP8321A1E   | Stn Inst Air        | CNT     | 30 days | 300  | 84.7  | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 1.5x10 <sup>8</sup> | 4.4 yr | 9         | No-G           |
| Ia 98   | MOV         | Limitorgue   | SMB-3       | Cnt Flood Accum     | CNT     | 6 days  | 325  | 104.7 | 100 | H <sub>2</sub> BO <sub>3</sub><br>NaOH | 2.0x10 <sup>8</sup> | 40     | 1,2,4     | No-B,C,<br>F,H |
| V 20c   | Sol. Vv.    | ASCO         | R4B-8320-A1 | H <sub>2</sub> Cont | Annulus | —       | —    | —     | —   | —                                      | —                   | —      | —         | Yes-D,0        |
| V 29c   | Limit Sw.   | NAMCO        | D-2400-X    | Cnt Purge           | Annulus | —       | —    | —     | —   | —                                      | —                   | —      | —         | Yes-D,0        |
| V 50    | Sol. Vv.    | ASCO         | 8211D4      | Main & Aux Stm Dump | AUX     | —       | —    | —     | —   | —                                      | —                   | —      | —         | Yes-D,0        |
| V 53    | Sol. Vv.    | ASCO         | HP8211D4    | Main & Aux Stm Dump | AUX     | —       | —    | —     | —   | —                                      | —                   | —      | —         | Yes-D,0        |
| V 55    | Sol. Vv.    | ASCO         | 8211D4      | Main & Aux Stm Dump | AUX     | —       | —    | —     | —   | —                                      | —                   | —      | —         | Yes-D,0        |
| V 75    | Sol. Vv.    | ASCO         | 831654      | P3r RH Vv.          | CNT     | —       | —    | —     | —   | —                                      | —                   | —      | —         | Yes-D,0        |
| V 82    | Sol. Vv.    | ASCO         | RHT8321A1   | Rx Hot Smplg        | CNT     | —       | —    | —     | —   | —                                      | —                   | —      | —         | Yes-D,0        |
| V 84    | Sol. Vv.    | ASCO         | RHT8320A19  | Rx Hot Smplg        | CNT     | —       | —    | —     | —   | —                                      | —                   | —      | —         | Yes-D,0        |

Attachment 9  
**POOR ORIGINAL**

|     |   |                   |
|-----|---|-------------------|
| 1.  | WCAP 7410-L   | Motorized Valves  |
| 2.  | WCAP 7744   | Motorized Valves  |
| 3.  | FIRL F-C3271  | Motorized Valves  |
| 4.  | Limitorque Project 600456   | Motorized Valves  |
| 5.  | ACME Cleveland Test Plan 8-31-77  | Limit Switches    |
| 6.  | Letter 5-12-80 NSP-NSP  | Limit Switches    |
| 7.  | WCAP 7829   | Fan Motors        |
| 8.  | Joy MFG 1-411   | Fan Motors        |
| 9.  | ASCO Test Report AQS 21678/TR-Rev. A  | Solenoid Valves   |
| 10. | Honeywell Catalog 50, Page E-2  | Limit Switch      |
| 11. | Engineering Test Lab, Bulletin 6  | Limit Switch      |
| 12. | Letter 3-25-80 E/M-NSP  | Motor             |
| 13. | Letter 9-29-80 NSC-NSP  | Motor/Fuse Holder |
| 14. | WCAP 8541   | Transmitter       |
| 15. | Magnetrol TR 9306   | Transmitter       |
| 16. | Letter 11-30-79 BSP-B&W   | Accelerometer     |
| 17. | WCAP 9157   | RTD               |
| 18. | Letter 3/80 NSP-NRC   | Signal Converter  |
| 19. | Letter 3/78 NSP-NRC   | Limit Switch      |
| 20. | Letter 7/80 NSP-NRC   | Limit Switch      |
| 21. | WCAP 8754   | Motor             |
| 22. | WCAP 7410-C   | Transmitter       |
| 23. | MIL-STD-202D  | Fuse Holder       |
| 24. | Letter 2-7-80 Mobil Oil-NSP   | Lube Oil          |
| 25. | Letter 10-30-79 Chevron USA-NSP   | Grease            |
| 26. | Letter 1-19-77 W -Wis/Minn Power  | Grease            |
| 27. | Letter 11-21-78 GE-NSP  | Epoxy Varnish     |
| 28. | Letter 8-7-78 GE-GE   | Epoxy Varnish     |
| 29. | GE Insulating Materials Products Data,<br>74010A Epoxy Resin and 74010 Epoxy<br>Catalyst; Effect of Radiation on<br>Materials | Epoxy Varnish     |
| 30. | Okonite Test Procedure  | Cable             |
| 31. | Letter 8-31-78 Okonite-NSP  | Cable             |
| 32. | WCAP 7410-L Vol. II   | Cable             |
| 33. | FIRL F-C2737  | Cable             |
| 34. | Kerite KPT-LVC-1  | Cable             |
| 35. | BIW B901  | Cable             |
| 36. | BIE B904  | Cable             |
| 37. | D.G. O'Brien C19QA053   | Penetration       |
| 38. | Letter 6-20-78 Fluor-Pioneer-WPS  | Penetration       |
| 39. | D. G. O'Brien ER-192  | Penetration       |
| 40. | LOCA Qualification of Kerite 1000v<br>FR Insulated, FR Jacketed Cables 3-10-80  | Splice Kits       |
| 41. | Qualification Tests of Electrical Cables<br>Under Simulated Post-Accident Rx Cntmt<br>Service Cond. R-C2737 4-15-70           | Splice Kits       |
| 42. | ACME Cleveland Test Plan 7-24-78  | Limit Switch      |
| 43. | Nuclear Radiation and Switch Applications   | Limit Switch      |
| 44. | PINGP's ECCS Actuation Study  | Mov               |
| 45. | Numerous Tests on Various Ins. Mat'l  | Motor             |



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

September 26, 1980

MEMORANDUM FOR: E. L. Jordan, Assistant Director, Division of  
Reactor Operations Inspection, IE:HQ

THRU: *G* G. Fiorelli, Chief, Reactor Construction and  
Engineering Support Branch

FROM: D. W. Hayes, Chief, Engineering Support Section 1

SUBJECT: SCREENING REVIEW OF LICENSEE RESPONSE TO IEB 79-01B  
AND SUMMARY OF INSPECTION OF INSTALLED SYSTEMS AT  
PRAIRIE ISLAND 1 AND 2 - DOCKET NOS. 50-382; 50-306

Frank Jablonski has completed the inspection phase at Prairie Island Units 1 and 2 in response to IEB 79-01B. A walkdown was conducted on September 17, 1980 to inspect installed components associated with the systems listed on the attachment.

Observations:

Motor Operated Valves (MOV's)

MOV Nos. MV-32132 and MV-32135 were limitorque type SMB-000 with Reliance motors, Class "B" insulation; MOV No. MV-32068 was limitorque type SMB-00 with a Reliance motor, Class "HP" insulation. The referenced qualification documentation was Project Number 600456 which qualified motors with "RH" insulation.

MOV No. 32020 was limitorque type SMB-00 with a Reliance motor, Class "B" insulation. Class "B" is suitable outside containment. The referenced qualification documentation was WCAP 7410-L and 7744 which meet or exceed outside containment duty.

In all cases the MOV's were installed in accordance with manufacturer's recommendations. Both power and control cable were installed in flexible metallic conduit.

\*Below flood level.

Dome Recirculation Fan

The fan unit was a Joy Axivane series 1000, Model No. 018-1Y-3450, Serial No. SF27974-1, Motor No. 600277-69. The referenced qualification

Onsite Inspection Report  
ATTACHMENT 2

September 26, 1980

documentation was Joy Manufacturing Report No. X-411; that test report was for Motor No. 600277-69. All requirements appear to have been met.

#### Solenoid Valves

All of the solenoids listed on the attachment were scheduled for replacement, however, discrepancies existed between solenoids listed on the component evaluation sheets and those actually installed. For example, solenoid Nos. 33374 and 33377 were listed as RHT832427; type RHT8321A1 installed. Similar discrepancies existed with solenoid Nos. 33440 and 33441<sup>1</sup>.

In all cases the installation met manufacturer's recommendations, i.e., installation in any position was acceptable. Cable was installed individually or in combination rigid steel/flexible metal conduit. Terminations were made in standard handy boxes, i.e., without gasketed cover; open to atmosphere. (Refer to Terminations, below).

#### Limit Switches

Limit Switch Nos. CD-3407<sup>1</sup> and CD-34078 were NAMCO Model EA-180. Qualification reference document was ACME-Cleveland Test Plan, August 31, 1977. The licensee is considering the installation of hermetic sealing units at the interface of the limit switch and flex/rigid conduit.

Component evaluation sheet for switch No. CV-31107, a NAMCO model D2400X, was not shown to be qualified for aging, operating time, or pressure<sup>1</sup>.

#### Instruments

Instrument Nos. 16796\* and 23015, containment sump level and main steam flow respectively, will be replaced. The installed instrument models were Magnetrol A-153FEP/VPXY-TDM and Barton 384.

The incore thermocouple reference junction boxes, ET1 Model K81, used in conjunction with the subcooling meter will be replaced.

E/P signal converter, No. SC35029, used to control a steam generator power operated relief valve (PORV) was identified by the licensee as not being environmentally qualified. The converter was a Fisher Controls type 546, contained in a NEC Class 1, Group D enclosure. The converter for the other power operated relief valve was located on the opposite side of the same room. Based on the information contained on page 2 of licensee

letter to NRC dated March 13, 1980, it could not be concluded that the signal converter for at least one PORV was adequate to effect an orderly cooldown, i.e., survive the specified environment of 210°F, 15.2 psia and 100% RH.<sup>1</sup>

\*Below flood level.

#### Terminations

Various component termination devices were opened for inspection. Penetrations were terminated on Alan Bradley No. 1492 terminal blocks installed in large junction boxes with covered panels; with Okonite splices; or covered with what appeared to be Scotch 27 tape. The latter two types were not protected by junction boxes. The Okonite splices were qualified by test.


Other components such as solenoid valves and limit switches were terminated in junction boxes or handy boxes; however, no environmental credit was given to any protection which might be offered by the enclosures. The terminations were stated to have been covered with three layers of Scotch No. 70 tape, three layers of Permasel fiberglass tape and then a repeat of Scotch No. 70 tape.

NOTE: A component evaluation worksheet was not included with the submittal<sup>1</sup>.

#### Conclusion

Except as reported above, motor insulation, solenoid valves, signal converters and terminations, the equipment descriptions provided by the licensee on the system component evaluation worksheets for the systems identified were complete and accurate.

<sup>1</sup>The licensee was made aware of these discrepancies. A detailed review will be made by the licensee and the response amended.

  
D. W. Hayes, Chief  
Engineering Support Section 1

Attachment: As Stated

cc:  
J.G. Keppler  
G. Fiorelli  
C. Fierabend, Res. Insp.  
V. D. Thomas, IE:HQ

ATTACHMENT 2



ATTACHMENT

LIST OF COMPONENTS

| <u>NUMBER</u> | <u>UNIT</u> | <u>GENERIC NAME</u>    | <u>SYSTEM</u> | <u>INSIDE</u> | <u>OUTSIDE</u> |
|---------------|-------------|------------------------|---------------|---------------|----------------|
| MV-32132      | 1           | Motor Operated Valve   | CL            | X             |                |
| MV-32135      | 1           | Motor Operated Valve   | CL            | X             |                |
| MV-32068      | 1           | Motor Operated Valve   | SI            | X             |                |
| MV-32020      | 2           | Motor Operated Valve   | MS            |               | X              |
| 11 (DRF)      | 1           | Dome Recirculation Fan | ZC            | X             |                |
| SV-33374      | 1           | Solenoid Valve         | ZC            | X             |                |
| SV-33377      | 1           | Solenoid Valve         | ZC            | X             |                |
| SV-33440      | 1           | Solenoid Valve         | ZP            | X             |                |
| SV-33441      | 1           | Solenoid Valve         | ZP            | X             |                |
| SV-33261      | 2           | Solenoid Valve         | MS            |               | X              |
| SV-33265      | 2           | Solenoid Valve         | MS            |               | X              |
| CD-34074      | 1           | Limit Switch           | ZC            | X             |                |
| CD-34078      | 1           | Limit Switch           | ZC            | X             |                |
| CV-31107      | 2           | Limit Switch           | MS            |               | X              |
| 16796         | 1           | Level Transmitter      | CS            | X             |                |
| 23015         | 1           | Flow Transmitter       | MS            | X             |                |
| 15456         | 1           | Junction Box           | RC            | X             |                |
| SC35029       | 2           | Signal Converter       | MS            |               | X              |
| _____         | 1           | Terminations           | ALL           | X             |                |



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
795 ROOSEVELT ROAD  
GLEN ELLYN ILLINOIS 60137

July 23, 1980

MEMORANDUM FOR: E. L. Jordan, Assistant Director, Division of  
Reactor Operations Inspection, IE:HQ

THRU: *G* G. Fiorelli, Chief, Reactor Construction and  
Engineering Support Branch

FROM: D. W. Hayes, Chief, Engineering Support Section 2

SUBJECT: IEB 79-01B (A/I F03067180)

Attached is a copy of a memorandum dated July 17, 1980 received from Frank Jablonski relative to IEB 79-01B. It is being forwarded for your information and solicited guidance.

The question of identification of safety related systems and components (paragraph No. 1 of the memo) is an old one. I disagree with Frank in that I feel that this identification is a responsibility of the licensee, not the NRC. He must know his plant. I do agree, however, that more guidance is needed for our inspectors in this area. This is especially important for those inspectors that have not had reactor operating experience.

The significant differences in master lists that Frank discusses in paragraph two does raise questions. We can only compare these lists against the SAR. Review and evaluation beyond this is assumed to be an NRR function.

In regard to Frank's question - should we assume the licensee's response to IEB 79-01B to be complete and correct - I have told him yes. Further, that if he identifies significant incompleteness in the response, or incorrect information during his reviews, to bring these to my attention so appropriate action can be recommended.

Comments and further guidance is requested concerning matters discussed in paragraphs 3 and 4 of Frank's memo.

D. W. Hayes, Chief  
Engineering Support Section 2

*Dupe of*  
80123100 83

Generic Issues  
ATTACHMENT 3a

E. L. Jordan

- 2 -

July 23, 1980

Attachment:

F. J. Jablonski Memo to  
D.W. Hayes dtd 7/17/80

cc w/attachment:

J. G. Keppler, RIII  
V. D. Thomas, IE:HQ  
A. Finkel, RI  
R. Hardwick, RII  
D. McDonald, RIV  
J. Elin, RV  
R. F. Heishman, RIII  
→ F. J. Jablonski, RIII



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

July 17, 1980

→ MEMORANDUM FOR: D. W. Hayes, Chief, Engineering Support Section I  
FROM: F. J. Jablonski, Reactor Inspector  
SUBJECT: FORMULATING TECHNICAL EVALUATION REPORTS (TER) -  
REVIEW OF IEB 79-01B  
RE: MEMO TO YOU DATED JUNE 16, 1980 - SAME SUBJECT

Since the review of IEB 79-01B is continual, new discrepancies continue to show up; discrepancies are not necessarily the licensee's. As you know, there is no specific nuclear power plant design required by NRC. Further, the designation of safety related systems is somewhat arbitrary and inconsistent. In fact, the NRC places responsibility for classifying safety related systems on the licensee.

Action Item No. 1 of 79-01B requested each licensee to provide a "master list" of all ESF systems in their respective plant required to function during a postulated accident. Appendix A to 79-01B lists "typical" equipment/functions needed for mitigation of an accident. A comparison of master lists was made of four licensees with similar Westinghouse PWRs (see Attachment 1). Arbitrary selection and non-standard nomenclature of systems makes evaluation of the master lists extremely difficult. NRC requested each licensee to submit the information under oath. Should the information therefore be assumed complete and correct?

It is extremely frustrating to review responses which vary so much in attention to detail, depth of review, etc. As stated previously in the draft TER for D.C. Cook, because I as a principal reviewer lack detailed systems/operations experience, further guidance is requested.

Another TER related matter is motorized valves equipped with Limitorque operators (see Attachment 2). As can be seen, each test report is for a specific unit type including motor type and insulation class. Almost all licensees refer to the various test reports as qualification documentation for all series of operator types; never is name plate data provided. For example, test report No. 600456 (SMB-0-40, Reliance Motor with Class RH insulation) may be listed for all operators from series SMB-000 to SMB-5; motor name plate data not provided. Without the name plate data and the basis for extrapolation, a meaningful evaluation cannot be made.

ATTACHMENT 3a

Ampl of 8012310089

July 17, 1980

It is requested that this memorandum be forwarded to IE:HQS as an addition to A/I F03067180 with the same copy distribution.

*F. J. Jablonski*

F. J. Jablonski  
Reactor Inspector

Attachments:

1. Comparison of Master Lists
2. Motor Operated Valve Tests

cc:

J. G. Keppler  
G. Fiorelli

ATTACHMENT 1

| <u>SYSTEMS</u>              | <u>P.I.</u> | <u>COOK</u> | <u>KEW.</u> | <u>PT. BCH.</u> |
|-----------------------------|-------------|-------------|-------------|-----------------|
| Aux. F.W.                   | X           | X           |             | X               |
| Chem. & Vol. Cont.          | X           | 2           | X           | X               |
| Cntmt. Air Hndlg.           | X           | X           |             | X               |
| Cntmt. H <sub>2</sub> Cont. | X           | X           |             |                 |
| Cntmt. Sp.                  | X           | X           |             | 1               |
| Main Stm.                   | X           | X           |             | X               |
| Aux. Stm.                   | X           |             |             |                 |
| Stm. Dump                   | X           |             |             |                 |
| Rx Clnt.                    | X           | X           | X           | X               |
| Res. Ht. Rm. 1              | X           | 2           | X           | 3               |
| Saf. Inj.                   | X           | 2           | X           | X               |
| Clg. Water                  | X           |             |             |                 |
| Esnt'l. Serv. Wat.          |             | X           |             |                 |
| Comp. Clg. Wat. 2           |             | X           |             | 3               |
| Emerg. Core Clg. 3          | 1           | X           | 1           |                 |
| Aux. Clnt.                  |             |             |             | X               |
| Cntmt. Purge                | X           |             |             |                 |
| Rx. Bldg. Vent              |             |             | X           |                 |
| Inst. & Prot.               | X           |             |             |                 |
| Rx. Trip. Act.              |             | X           |             |                 |
| Rx. Cont. & Prot.           |             |             |             | X               |
| Rad. Monit.                 | X           |             |             |                 |
| Rx. Hot Samp.               | X           |             |             |                 |
| Stn. & Inst. Air            | X           |             |             |                 |
| Stm. Gen. BD                | X           |             |             |                 |
| Post Acc. Monit.            |             | X           |             |                 |
| Rem. Sht. cn. Monit.        |             | X           |             |                 |
| Cntmt. Isol.                |             | X           |             | X               |
| Mn. Stm. Isol.              |             | X           |             |                 |
| Mn. FW Isol.                |             | X           |             |                 |

ATTACHMENT 2

MOTOR OPERATED VALVES  
MOV's

1. There are basically two type series of Limitorque operators: SMB and SB. The operators are sized from 000 (smallest) to 5 (largest) as follows:

SMB-000  
SMB-00  
SMB/SB-0<sup>1</sup>  
SMB/SB-1  
SMB/SB-2  
SMB/SB-3  
SMB/SB-4  
SMB-5

This series may also include SB

This series may also include WB  
This series may be suffixed "T"

2. Test Reports include:

| Report No.                     | Date          | Unit Type | Environment  | Motor Type     | Insulation      |
|--------------------------------|---------------|-----------|--|----------------|-----------------|
| a. 600198                      | 1-2-69        | SMB-0-15* | PWR<br>No Radiation                                | Reliance       | Special Hi Temp |
| b. 600426<br>(B-0009)          | 4-30-76       | SMB-0-25* | BWR <sub>7</sub><br>1x10 <sup>7</sup> R<br>340°    | Peerless<br>DC | H               |
| c. 600376A<br>FIRL F-C<br>3441 | 5-15-76       | SMB-0-25* | BWR<br>2x10 <sup>8</sup>                           | Reliance       | RH              |
| d. 600456                      | 12-9-75       | SMB-0-40* | PWR <sub>8</sub><br>2x10 <sup>8</sup>              | Reliance       | RH              |
| e. 600461                      | 6-7-76        | SMB-0-25* | Outside<br>Cntmt <sub>7</sub><br>2x10 <sup>7</sup> | Reliance       | B               |
| f. WCAP7410L<br>7744           | 12-70<br>8-71 | SMB-00    |  |                | B               |

\* denotes foot pounds of torque

<sup>1</sup> only SMB-0 has been tested seismically Re: a, b, c



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SSINS #6820

JUL 3 1980

MEMORANDUM FOR: Z. R. Rosztoczy, Branch Chief, Equipment Qualification  
Branch, Division of Engineering, NRR

THRU: *Haw for* E. L. Jordan, Assistant Director for Technical Programs,  
Division of Reactor Operations Inspection, IE

FROM: V. D. Thomas, Task Manager, Review Group, IEB 79-01B,  
Division of Reactor Operations Inspection, IE

SUBJECT: REQUEST FOR NRC POSITIONS ON REVIEW QUESTIONS OF IEP-79-01B  
LICENSEE RESPONSES

In accordance to our verbal agreement, we would be happy if you would provide positions on the questions noted in the enclosed memoranda.

Since it is essential to establish a uniform approach to the review effort to obviate the questions being generated in the on-going review of licensee responses, we will be happy to meet with your staff to discuss these concerns to expedite resolution of the issues.

Vincent D. Thomas, Task Manager  
Review Group, IEB 79-01B

Enclosures:

1. Memo D. W. Hayes to G. Fiorelli, RIII  
dated June 20, 1980.
2. Memo F. Jablonski to D. Hayes, RIII  
dated Jun 16, 1980.
3. Memo F. Jablonski to D. Hayes, RIII  
DATED June 10, 1980.

cc: w/enclosures

E. L. Jordan, IE  
V. S. Noonan, NRR  
G. Fiorelli, RIII  
D. W. Hayes, RIII  
A. Finkel, RI  
R. Hardwick, RII  
F. Jablonski, RIII  
D. McDonald, RIV  
J. Elin, RV

JUL 7 1980

ATTACHMENT 3a

*Dupe* { 800807 0229





UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

June 20, 1980

MEMORANDUM FOR: E. L. Jordan, Assistant Director, Division of  
Reactor Operations Inspection, IE:HQ

THRU: *G* G. Fiorelli, Chief, Reactor Construction and  
Engineering Support Branch

FROM: D. W. Hayes, Chief, Engineering Support Section 1

SUBJECT: IEB 79-01B (A/I F03067:80)

Attached are two memorandums from one of my inspectors, Frank Jablonski. The first is dated June 10, 1980 and the second June 16, 1980. Both memos raise basic questions for which we require guidance to complete our review of responses to IEB 79-01B.

By this memo I also would like to confirm our understanding that NRR (Environmental Qualification Branch) will review for acceptability all test reports and other documentation which licensees reference as establishing environmental qualification of instrument/electrical equipment. In connection with this, we are sending under separate cover test reports, etc. in our possession to be forwarded to the Environmental Qualification Branch. (We further understand that the IEB 79-01B task group, on a volunteer basis, may agree to review some of these documents).

The status or schedule for site inspections and review/evaluation of the final reports is also attached. Please note that every licensee has asked for some sort of time extension to submit their first report. We understand that the other regions have had similar reporting problems. Assuming that all our licensees meet their extended submittal dates, we should complete our site inspections, reviews, and technical evaluation

*Dupe*


*f*

800807232

ATTACHMENT 3a

June 20, 1980

reports by the end of December 1980. Further delays in the submittals or any unforeseen events will hamper our ability to meet the new February 1, 1981 deadline.



D. W. Hayes, Chief  
Engineering Support Section 1

Attachments:

1. Memo F. Jablonski to D. Hayes 6/10/80
2. Memo F. Jablonski to D. Hayes 6/16/80
3. Inspection Status/Schedule
4. "Separate Cover" List (Test Reports Sent to IE:HQ)

- Separate Cover: See Attachment 4

cc w/attachments 1, 3, & 4 only:

J. G. Keppler  
G. Fiorelli  
V. D. Thomas, IE:HQ  
A. Finkel, RI  
R. Hardwick, RII  
D. McDonald, RIV  
J. Elin, RV  
R. F. Heishman



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

June 10, 1980

MEMORANDUM FOR: D. W. Hayes, Chief, Engineering Support Section 1  
FROM: F. J. Jablonski, Reactor Inspector  
SUBJECT: EFFECT OF PREVIOUS NRR REVIEW ON MATTERS RELATING  
TO IEB 79-01B

In almost every licensee response to IEB 79-01B there is a subtle or direct reference to matters apparently reviewed by NRR. Because of the referenced dates it is assumed by me that NRR has given either tacit or direct approval to the references; examples follow:

1. All licensees refer to their FSARs for establishing the list of engineered safety feature systems and environmental data such as temperature, pressure, radiation, etc.
2. One licensee, Wisconsin Public Service Corporation, states that "The AEC, in their "Safety Evaluation of the Kewaunee Plant", Section 7.5, issued July 24, 1972, concluded that our criteria and testing program for environmental qualification were adequate". It is further stated that "Our FSAR, which was approved by the AEC, discusses at length the post accident conditions and required qualifications for applicable equipment. (See Section 7.5 of the Kewaunee FSAR.)"
3. Two licensees, American Electric Power and Wisconsin Public Service Corporation, have discussed the effect of components below flood level simply by referencing letters previously submitted to the NRC, or FSAR questions/answers as follows:
  - \* AEP - Letter dated 9-29-75 from Tillinghast (AEP) to Kniel (NRC); FSAR question 40.10 Appendix Q.
  - \* WPSC - Letter dated 2-2-76 from James (WPSC) to Purple (NRC).

Dupe of 8008070238

ATTACHMENT 3a

D. W. Hayes

- 2 -

June 10, 1980

My specific concerns are:

Is it to be assumed that the referenced FSAR parameters, No. 1 above, are correct, i.e. reviewed by NRR?

If the answer is yes, then should it also be assumed that No. 2 above is likewise adequate? (If the answer is no, then none of the licensee responses which reference the FSAR can be assumed to be correct.)

Reference No. 3, even though a component may not be required to operate subsequent to flooding, what effect will short circuits have on containment electrical penetrations? Was this considered by NRR?

I am requesting that these questions/concerns be forwarded to the Assistant Director, Division of Reactor Operations Inspection for resolution.



F. J. Jablonski  
Reactor Inspector

cc:  
J. G. Keppler  
G. Fiorelli



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

June 16, 1980

→ MEMORANDUM FOR: D. W. Hayes, Chief, Engineering Support Section I  
FROM: F. J. Jablonski, Reactor Inspector  
SUBJECT: FORMULATING TECHNICAL EVALUATION REPORTS (TER) -  
REVIEW OF IEB 79-01B

In accordance with IEB 79-01B, an overall conclusion relative to the qualification of instrument electrical equipment is to be made for each operating plant based on a screening review of all plant systems, and by a detailed review and observation of specific system components. Unresolved concerns previously identified by RIII inspectors during reviews of IEC 78-08 and IEB 79-01 along with subsequently identified concerns make it difficult for us to formulate meaningful TERs for certain plants. The previous unresolved concerns are documented in the memorandums listed below (1,2,3) and are reiterated in Attachment A to this memo. Subsequently identified concerns are listed in Attachments B, C, and D.

To assure uniform evaluation, guidance is needed for these items. Please forward these concerns to IE:HQ.

1. TI 2515/13 - Qualification of Safety Related Electrical Equipment Fiorelli to Sniezek, 10/13/78
2. Same title as 1., Fiorelli to Klinger, 12/78
3. Review Status of Responses to IEB 79-01, Hayes to Jordan, 9/5/79

*F. J. Jablonski*

F. J. Jablonski  
Reactor Inspector

Enclosures: As Stated

cc:  
J. G. Keppler  
G. Fiorelli  
V. D. Thomas, IE:HQ  
A. Finkel, RI  
R. Hardwick, RII  
D. McDonald, RIV  
J. Elin, RV

ATTACHMENT 3a

*Dupe of*

*8008 070241*

DUPLICATE

*8008070241*