

LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | I L Z I S 2 | 0 0 - 0 | 0 0 0 0 - 0 0 | 4 1 | 1 1 | 1 | 4 | 5  
7 8 9 14 15 25 26 30 37 38 39  
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

COM'T  
0 1 | L | 0 5 | 0 0 0 3 0 4 | 0 5 0 8 8 1 | 0 5 | 2 6 | 8 | 1 | 9  
7 8 9 80 81 88 89 94 95 96 97 98 99  
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During reactor startup, operating personnel found that Pzr level chan-  
0 3 | nel 2L-461 was reading 6% lower than redundant channels. This condi-  
0 4 | tion was non-conservative for Pzr High Level Rx trip as presented in  
0 5 | T.S. Table 3.1.1. The associated bistable was tripped. Since redun-  
0 6 | dant channels were operable, the health and safety of the public was  
0 7 | not affected. Previous LER's: 50-295/79-29, 79-69, 80-36; 50-304/79-  
0 8 | 10, 79-15, 79-27, 79-44, 80-27.  
7 8 9

0 9 | I A | B | A | I N S T R U | T | Z |  
7 8 9 10 11 12 13 14 15 16  
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE  
17 | LER/RO REPORT NUMBER | 8 1 | | 0 0 7 | | 0 1 | | L | | 0 |  
21 22 23 24 25 26 27 28 29 30 31  
EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPR-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER  
E 18 | F 19 | Z 20 | Z 21 | 0 0 0 0 | N 23 | Y 24 | N 25 | B 0 8 0 0 | 26  
33 34 35 36 37 40 41 42 43 44 47  
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Channel was out of tolerance due to range shift on Xmtr 2LT-461 (Barton  
1 1 | Model 386). Xmtr was range and zero adjusted and the channel returned  
1 2 | to service. This calibration shift seems to be caused by trapped gas  
1 3 | bubbles within the Xmtr sensing lines. These sensing lines will be re-  
1 4 | sloped and trended for any future zero shift effects.  
7 8 9

1 5 | C | 0 0 0 | NA | A | Operator Observation  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32  
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 | Z | Z | NA | NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32  
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 | 0 0 0 | Z | NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32  
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 | 0 0 0 | | NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32  
PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 | Z | NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32  
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 0 | N | NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32  
PUBLICITY ISSUED DESCRIPTION

NAME OF PREPARER R. V. Jenkins

PHONE: 312-746-2084 Ext 507