## LICENSEE EVENT REPORT

	LICENSEE EVENT REPORT
	CONTROL BLOCK: [ ] [ ] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
01	C O F S V 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 2 0 4 57 CAT 58 5
CON'T	REPORT 1 L 6 0 5 0 0 0 2 6 7 7 0 3 1 1 0 8 1 3 0 4 0 9 8 1 9  EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (1)
0 2	It was determined on March 10, 1981, that on February 24, 1981, the total dissolved
013	solids (TDS) in the plant non-radioactive liquid waste effluent exceeded 2300 parts
04	per million limit of LCO NR 1.1. This is reportable per Fort St. Vrain Technical
0 5	Specification AC 7.5.2(b)2. There was no effect on public health or safety. No ac-
06	companying occurrences. Similar reports RO 79-61, 80-38, and 31-004.
07	
0 3	9 SYSTEM CAUSE CAUSE COMP. VALVE
0 9	SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBC
	17   REPORT   8   1
10	High TOS resulted from the circulating water system being shut off over the weekend
	and the subsequent restoration of blowdown at a high rate. The blowdown rate was re-
1	duced, and the TDS level of the plant effluent was within limits by the next shift.
13	Occurrence will be reviewed by Plant Review Panel to determine the need for further
TI A	corrective action in terms of procedures and individuals involved.
15	STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32    E 38   0   6   3   N/A     A 31   Regular Chemical Analysis     A 32   Regular Chemical Analysis     A 33   Regular Chemical Analysis     A 32   Regular Chemical Analysis     A 33   Regular Chemical Ana
, 8	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
7 8	9 PERSONNEL INTERIES 13 90
1 3	NUMBER DESCRIPTION(41) 0 0 0 40 N/A 9 11 12 30
1 9	LOSS OF OR DAMAGE TO FACILITY 43  TYPE DESCRIPTION  Z 42 N/A
7 3	PUBLICITY ISSUED DESCRIPTION 45  NRC USE ONLY
, 8	NAME OF PREPARER (303) 785-2224 9