LICENSEE EVENT REPORT

| CONTROL BLOCK: |
|--|
| 01 C F S V 1 2 0 0 - 0 0 0 0 - 0 0 |
| EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 While the plant was in a shutdown condition and the semi-annual loss of outside |
| alectrical power test was being performed diesel generator 14 output circuit breaker I |
| - did not close. This is a degraded made of ICO (6 1(3) and is reportable per Fort St.) |
| Vrain Technical Specification AC 7.5.2(b)2. There was no affect on public health or |
| safety. No accompanying occurrence. Redundant system available and operable. |
| Similar report RO 77-31. |
| 0181 |
| 7 8 9 SYSTEM CAUSE CAUSE CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE |
| DED EE LA GO CRIBRK 4 LA GO ZO GO |
| SEQUENTIAL REPORT NO. 17 REPORT TYPE 17 9 |
| One ITE Model K-1600 circuit breaker failed to close. Breaker replaced with an equi- |
| valent spare. The breaker was disassembled and inspected. The grease used in the |
| breaker was found to have to dried out due to the high ambient temperature. The |
| breaker was relubricated and returned to service. A maintenance program was estab- |
| lished to disassemble and relubricate these breakers every six months. |
| FACILITY STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 1 5 D 38 0 0 0 0 9 N/A B 31 Surveillance Test |
| 3 3 10 11 12 13 44 45 46 BO ACCITIVITY CONTENT AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36 BO AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36 BO AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36 BO ACCITIVITY 35 L |
| PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 1 7 0 0 0 37 Z 38 N/A |
| 7 8 9 PERSONNEL INJURIES 13 NUMBER DESCRIPTION (41) 1 3 0 0 0 0 0 N/A |
| LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION 1 9 Z (2) N/A |
| PUBLICITY ISSUED DESCRIPTION 45 PUBLICITY OFFICIAL PRINCIPLE OFFICIAL |
| 8 1 06 03 0 30 30 30 30 30 30 30 30 30 30 30 3 |