

DISTRIBUTION:

MAY 27 1981

ACC:
TERA
PNR
LPR
NSIC
TIC
ACRS (16)

LB#1 Rdg
DEisenhut
JYoungblood
GEdison
MRushbrook
SHanauer
RVollmer
TMurley
RMattson
RHartfield, MPA
OELD
OIE (3)

Docket No.: STN 50-482

Mr. Glenn L. Koester
Vice President - Nuclear
Kansas Gas and Electric Company
201 North Market Street
Wichita, Kansas 67201



Dear Mr. Koester:

Subject: Request for Additional Information for the Review of the
Wolf Creek Plant, Unit 1 Regarding Fire Protection

As a result of our continuing review of the Wolf Creek Plant, Unit 1 FSAR, we find that we need additional information to complete our evaluation. The specific information required is in the area of fire protection and is presented in the Enclosure.

To maintain our licensing review schedule for the Wolf Creek Plant FSAR, we will need responses to the enclosed request by June 15, 1981. If you cannot meet this date, please inform us within seven days after receipt of this letter of the date you plan to submit your responses so that we may review our schedule for any necessary changes.

Please contact Dr. G. E. Edison, Wolf Creek Licensing Project Manager, if you desire any discussion or clarification of the enclosed request.

Sincerely,

Original signed by
Robert L. Tedesco

Robert L. Tedesco, Assistant Director
for Licensing
Division of Licensing

Enclosure:
As stated

cc: See next page

REGULATORY DOCKET FILE COPY

8106030 378

F

OFFICE	DL:LB#1	DL:LB#1	DL:AC/L			
SURNAME	GEdison/lq	BYoungblood	RLTedesco			
DATE	5/15/81	5/27/81	5/27/81			

Mr. Glenn L. Koester
Vice President - Nuclear
Kansas Gas and Electric Company
201 North Market Street
P. O. Box 208
Wichita, Kansas 67201

cc: Mr. Nicholas A. Petrick
Executive Director, SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20750

Mr. Jay Silberg, Esquire
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. Donald T. McPhee
Vice President - Production
Kansas City Power and Light Company
1330 Baltimore Avenue
P. O. Box 679
Kansas City, Missouri 64101

Ms. Mary Ellen Salva
Route 1, Box 56
Burlington, Kansas 66839

Mr. L. F. Drbl
Missouri-Kansas Section:
American Nuclear Society
15114 Navaho
Olathe, Kansas 66062

Ms. Treva Hearne, Assistant General Counsel
Public Service Commission
P. O. Box 360
Jefferson City, Missouri 65102

Mr. Tom Vandell
Resident Inspector/Wolf Creek NPS
c/o USNRC
P. O. Box 1407
Emporia, Kansas 66801

Mr. Michael C. Kenner
Wolf Creek Project Director
State Corporation Commission
State of Kansas
Fourth Floor, State Office Bldg.
Topeka, Kansas 66612

Ms. Wanda Christy
515 N. 1st Street
Burlington, Kansas 66839

Floyd Mathews, Esq.
Birch, Horton, Bittner & Monroe
1140 Connecticut Avenue, N. W.
Washington, D. C. 20036

Kansas for Sensible Energy
P. O. Box 3192
Wichita, Kansas 67201

Francis Blaufuse
Westphalia, Kansas 66093

ENCLOSURE

280.0 FIRE PROTECTION

Notification of Appendix R to 10 CFR Part 50 as a Licensing Requirement.

280.6wc Appendix R to 10 CFR Part 50 will also be used as guidance for our review of your fire protection program. Your compliance with the requirements set forth in Appendix R as modified by accepted exceptions will be made a license condition. Identify any exceptions your program makes to the requirements of Appendix R as well as BTP ASB 9.5-1, and describe your alternative for providing an equivalent level of fire protection.