

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 P A B V S L 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 _____ 5
7 8 9 14 15 25 26 30 37 CAT 58

CONT
01 REPORT SOURCE L 6 0 5 0 0 0 3 3 4 7 0 4 2 9 8 1 8 0 5 2 9 8 1 9
7 8 90 91 58 59 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
02 On 4/29/81 at 1330 hours with the plant at 100 percent power, while performing a
03 routine maintenance surveillance procedure on containment pressure instrument
04 [PT-LM-100A], the comparator module which actuates on hi-hi containment pressure was
05 reported inoperable as a result of a loosened fuse. Based on a review of the
06 sequence of events recorder, the channel was likely inoperable for a 13-hour period
07 prior to this discovery. The public health and safety was not jeopardized since
08 sufficient redundant channels were available to initiate safety features. 80

09 SYSTEM CODE I B 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE Z Z Z Z Z Z 14 COMP SUBCODE Z 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 8 1 1 22 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED Y 23 NPD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z 9 9 9 26
13 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
10 The fuse was re-engaged and the channel restored to service at the time of the
11 discovery. The cause for the dislodged fuse is unknown. The fuses for the
12 remaining three channels were checked and found firmly in place.
13
14

15 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS N/A 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Maintenance surveillance procedures 32
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY N/A 35 LOCATION OF RELEASE N/A 36
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION N/A 39
7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION N/A 41
7 8 9 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION N/A 43
7 8 9 11 12 80

20 PUBLICITY ISSUED N 44 DESCRIPTION N/A 45
7 8 9 10 80

8106040501

Attachment To LER 81-43/03L
Beaver Valley Power Station
Duquesne Light Company
Docket No. 50-334

No further information is available or needed to satisfy the reporting requirement.