



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
631 PARK AVENUE  
KING OF PRUSSIA, PENNSYLVANIA 19406

13 MAY 1981

Docket No. 50-277  
50-278

Philadelphia Electric Company  
ATTN: Mr. S. L. Daltroff  
Vice President  
Electric Production  
2301 Market Street  
Philadelphia, Pennsylvania 19101



Gentlemen:

Subject: Combined Insection No. 50-277/80-18 and  
50-278/80-10

This refers to your letter dated April 22, 1981, in response to our letter dated April 2, 1981.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a future inspection of your licensed program.

On Page 2 of your letter dated April 22, 1981 the following statement was made.

"Periodic alpha sampling of air particulate filters and loose contamination smears is now being performed"

It is our understanding that alpha sampling of air particulates and smears shall be done quarterly, as stated by Mr. Gazda in a telephone conversation on May 4, 1981.

On Page 3 of your letter dated April 22, 1981, the following statement was made:

"Arrangements will be made to periodically calibrate our neutron survey meters..."

It is our understanding that the neutron survey meters will be calibrated annually, as stated by Mr. Gazda.


8106040 526  
Q

13 MAY 1981

If our understanding is not correct, please inform us.

Your cooperation with us is appreciated.

Sincerely,



James H. Joyner, Chief  
Technical Inspection Branch

cc:

W.T. Ullrich, Station Superintendent

Troy B. Conner, Jr., Esquire

Eugene J. Bradley, Esquire

Raymond L. Hovis, Esquire

Michael J. Scibinico, II, Assistant Attorney General