



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

NEBRASKA PUBLIC POWER DISTRICT
DOCKET NO. 50-298
COOPER NUCLEAR STATION
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 70
License No. DPR-46

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Nebraska Public Power District dated March 5, 1981 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-46 is hereby amended to read as follows:


(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 70, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

8106050174

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Thomas A. Ippolito, Chief
Operating Reactors Branch #2
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Dated: May 22, 1981

ATTACHMENT TO LICENSE AMENDMENT NO. 70

FACILITY OPERATING LICENSE NO. DPR-46

DOCKET NO. 50-298

Remove the following pages of the Appendix "A" Technical Specifications and replace with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

Remove

Replace

212

212

-

212b

-

212c

-

212d

-

212e

213

213

214c

214c

214d

214d

L_T = Total core length - 12 feet

L = Axial position above bottom of core

G = 13.5 kW/ft for 7x7 fuel bundles

= 13.4 kW/ft for 8x8 fuel bundles

W = 0.038 for 7x7 fuel bundles

= 0.0 for 8x8 fuel bundles

If at any time during steady state operation it is determined by normal surveillance that the limiting value for LAGR is being exceeded action shall then be initiated to restore operation to within the prescribed limits. Surveillance and corresponding action shall continue until the prescribed limits are again being met.


C. Minimum Critical Power Ratio (MCPR)

During steady state power operation the MCPR for each type of fuel at rated power and flow shall not be lower than the limiting value shown in Figure 3.11-2. If, at any time during steady state operation it is determined by normal surveillance that the limiting value for MCPR is being exceeded, action shall then be initiated within 15 minutes to restore operation to within the prescribed limits. If the steady state MCPR is not returned to within the prescribed limits within two (2) hours, the reactor shall be brought to the Cold Shutdown condition within 36 hours. Surveillance and corresponding action shall continue until the prescribed limits are again being met.

For core flows other than rated the MCPR shall be the operating limit at rated flow times K_E , where K_E is as shown in Figure 3.11-3.


C. Minimum Critical Power Ratio (MCPR)

MCPR shall be determined daily during reactor power operation at > 25% rated thermal power and following any change in power level or distribution that would cause operation with a limiting control rod pattern as described in the bases for Specification 3.3.B.5.




(based on tested measured scram time
as defined in Reference 9)

Figure 3.11-2a 7x7 Fuel




(Based on tested measured scram time as defined in Reference 9)

Figure 3.11-2b Sx8 Fuel




(Based on tested measured scram time as defined in Reference 9)

Figure 3.11-2c 8x8R Fuel



(based on tested measured scram time as defined in Reference 9)

Figure 3.11-2d P8x8R Fuel



Note: Applicable to MG set plants only.

POOR ORIGINAL

3.11 Bases: (Cont'd)

The limiting transient which determines the required steady state MCPR limit and thus yields the largest MCPR is discussed in Reference 5. When added to the safety limit MCPR of 1.07 the deterministic MCPR's are obtained. The required minimum operating limit MCPR's are determined by methods given in References 6 and 9.

Prior to the analysis of abnormal operational transients an initial fuel bundle MCPR was determined. This parameter is based on the bundle flow calculated by a GE multi-channel steady state flow distribution model as described in Section 4 of NEDO-24011⁽²⁾ and on core parameters shown in Table 3-2 of Reference 1.

The evaluation of a given transient begins with the system initial parameters shown in Table 3-2 of Reference 1 that are input to the GE core dynamic behavior transient computer program described in NEDO-10802⁽⁵⁾ and NEDO-24154⁽⁷⁾. The outputs of the program along with the initial MCPR form the input for further analyses of the thermally limiting bundle with the single channel transient thermal hydraulic SCAT code described in NEDO-20566⁽⁴⁾. The principal result of this evaluation is the reduction in MCPR caused by the transient.

D. MCPR Limits for Core Flows Other than Rated

The purpose of the K_f factor is to define operating limits at other than rated flow conditions. At less than 100% flow, the required MCPR is the product of the operating limit MCPR and the K_f factor. Specifically, the K_f factor provides the required thermal margin to protect against a flow increase transient. The most limiting transient initiated from less than rated flow conditions is the recirculation pump speed up caused by a motor-generator speed control failure.

For operation in the automatic flow control mode, the K_f factors assure that the operating limit MCPR will not be violated should the most limiting transient occur at less than rated flow. In the manual flow control mode, the K_f factors assure that the Safety Limit MCPR will not be violated for the same postulated transient event.

3.11 Bases: (Cont'd)

The K_f factor curves shown in Figure 3.11-3 were developed generically which are applicable to all BWR/2, BWR/3, and BWR/4 reactors. The K_f factors were derived using the flow control line corresponding to rated thermal power at rated core flow.

For the manual flow control mode, the K_f factors were calculated such that at the maximum flow state (as limited by the pump scoop tube set point) and the corresponding core power (along the rated flow control line), the limiting bundle's relative power was adjusted until the MCPR was slightly above the Safety Limit. Using this relative bundle power, the MCPR's were calculated at different points along the rated flow control line corresponding to different core flows. The ratio of the MCPR calculated at a given point of core flow, divided by the operating limit MCPR determined the K_f .

For operation in the automatic flow control mode, the same procedure was employed except the initial power distribution was established such that the MCPR was equal to the operating limit MCPR at rated power and flow.

The K_f factors shown in Figure 3.11-3, are conservative for Cooper operation because the operating limit MCPR's are greater than the original 1.20 operating limit MCPR used for the generic derivation of K_f .

References for Bases 3.11.B, 3.11.C, 3.11.D

1. "Cooper Nuclear Station Channel Inspection and Safety Analyses with Bypass Holes Plugged," NEDO-21072, October 1975.
2. Licensing Topical Report, General Electric Boiling Water Reactor, Generic Reload Fuel Application, (NEDE-24011-P), (most current approved submittal).
3. R. B. Linford, Analytical Methods of Plant Transient Evaluations for the GE BWR, February 1973 (NEDO-10802).
4. General Electric Company Analytical Model for Loss-of-Coolant Analysis in Accordance with 10 CFR 50, Appendix K, NEDO-20566, dated January 1976.
5. "Supplemental Reload Licensing Submittal for Cooper Nuclear Station Unit 1," (most current approved submittal).
6. April 18, 1978 letter from J. M. Pilant (NPPD) to G. E. Lear (NRC).
7. "Qualification of the One-Dimensional Core Transient Model for Boiling Water Reactors," NEDO-24154, Volumes 1, 2 and 3, October 1978.
8. Letter, R. H. Buckholz (GE) to P. S. Check (NRC), "ODYN Adjustment Methods for Determination of Operating Limits," January 19, 1981.
9. Letter (with attachment) R. H. Buckholz (GE) to P. S. Check (NRC), "Response to NRC Request for Information on ODYN Computer Model," September 5, 1980.