

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-346THE TOLEDO EDISON COMPANYANDTHE CLEVELAND ELECTRIC ILLUMINATING COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY  
OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 40 to Facility Operating License No. NPF-3, issued to The Toledo Edison Company and The Cleveland Electric Illuminating Company (the licensees), which revised Technical Specifications (TSs) for operation of the Davis-Besse Nuclear Power Station, Unit No. 1 (the facility) located in Ottawa County, Ohio. The amendment is effective as of its date of issuance.

This amendment changes the TSs to provide consistency in terminology between the TSs and plant design and to ensure adequate surveillance requirements. These changes were identified during the Commission's review of Amendment No. 36 to License No. NPF-3. Amendment No. 36 allows the plant to use a manual switchover of the Emergency Core Cooling System pumps from the Borated Water Storage Tank (BWST) to the emergency sump during a loss of coolant accident after the BWST reaches a low level.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate

8106080 124

-2-


findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with the issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated February 24, 1981, (2) Amendment No. 40 to License No. NPF-3, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, NW, Washington, DC, and at the William Carlson Library, University of Toledo, 2801 W. Bancroft Avenue, Toledo, Ohio. A copy of items (2) and (3) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, DC 20555. Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland, this 1st day of June 1981.

FOR THE NUCLEAR REGULATORY COMMISSION

  
John F. Stolz, Chief  
Operating Reactors Branch #4  
Division of Licensing

**POOR ORIGINAL**