LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | TNSNP1 (2) | 00-000000-00 (3) | 4111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT 58

CON'T 01 | REPORT SOURCE L (6) | 05000327 (7) | 050381 (8) | 052981 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | With Unit 1 at 30% RTP, liquid radwaste effluent monitor 0-RM-90-122 would not source
03 | check. The plant entered action statement 30 of LCO 3.3.3.9 until the monitor was
04 | returned to service on 5/14/81. There was no effect on public health or safety. For
05 | previous occurrences refer to SQRO-50-327/81013 and SQRO-50-327/81034.
06 |
07 |
08 |

09 | SYSTEM CODE MC (11) | CAUSE CODE E (12) | CAUSE SUBCODE E (13) | COMPONENT CODE INSTRU (14) | COMP SUBCODE C (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 81 — SEQUENTIAL REPORT NO. 053 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN C (18) | FUTURE ACTION F (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER L (25) | COMPONENT MANUFACTURER G063

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The monitor failed due to the high background accumulation in the sample chamber. The
11 | sample chamber was replaced and the monitor was returned to service. DCR-1109 has been
12 | submitted to install another monitoring system. DCR-908 has been submitted to provide
13 | a flushing capability for the present monitoring system.
14 |

15 | FACILITY STATUS E (28) | % POWER 030 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Failed to source check

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

8106080279

Name of Preparer: M. R. Harding/A. M. Milkey Phone: (615) 842-8317