LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	I L Z I S 1 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)	(5)		
	LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT		

CON'T 0 1	REPORT SOURCE L (6)	0 5 0 0 0 2 9 5 (7)	0 1 1 6 8 1 (8)	0 2 1 3 8 1 (9)	
		DOCKET NUMBER	EVENT DATE	REPORT DATE	

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While in HSD as part of safe shutdown and ESF testing, the 1A charging

0 3 pump was tripped but would not restart. This event is reportable since

0 4 it could have occurred during power operation and T.S. 3.8.1 requires

0 5 operability of this pump. The redundant pump was started and operated

0 6 successfully. Since the redundant pump was operable the .ealth and

0 7 safety of the public were not affected.

0 8

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	S F (11)	E (12)	A (13)	C K T B R K (14)	A (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 1	—	0 0 3	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
C (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	Y (24)	A (25)	I 0 0 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The failure was apparently due to a dirty mechanical trip linkage on the

1 1 breaker. The ITE 4kv breaker was replaced with a spare and the pump

1 2 started normally. The faulty breaker was cleaned and inspected with no

1 3 problems found. Both breakers subsequently tested OK. Since this is not

1 4 a recurring problem, no further corrective action is necessary.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	G (28)	0 0 0 (29)	NA	B (31)	Operator Observation

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	NA

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	NA	

8106090655

NAME OF PREPARER James J. Madden PHONE: 312-746-2084 X369