

APPENDIX A

NOTICE OF DEVIATION

Tennessee Valley Authority
Sequoyah 1

Docket No. 50-327
License No. DPR-77

As a result of the inspection conducted on March 24-27, 1981, certain of your activities appear to deviate from your commitments to the Commission as indicated below:

Table 1.1 in TVA's Response to NRC's Question 1 and TVA's Response to NRC's Question 14.B on TVA's Fire Protection Program Reevaluation for Sequoyah state that rate compensated thermal fire detectors with heat collectors will be provided above each ERCW pump in the ERCW pump house and the intake pumping station prior to fuel loading.

Contrary to the above, fire detectors have not been provided above each ERCW pump in the ERCW pump house and the intake pumping station.

8106100 239