


TERA



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JUN 3 1981



Docket Nos: 50-329  
and 50-330

APPLICANT: Consumers Power Company

FACILITY: Midland Plant, Units 1 & 2

SUBJECT: SUMMARY OF APRIL 30, 1981 MEETING TO REVIEW AUXILIARY  
FEEDWATER SYSTEM DESIGN

On April 30, 1981, the NRC staff and its Sandia consultant met in Ann Arbor, Michigan with Consumers Power Company (the Applicant); Bechtel; Babcock and Wilcox (B&W); and Pickard, Lowe and Garrick, Inc. Attendees are listed in Enclosure 1. The propose of the meeting was to review the design of the Midland Auxiliary Feedwater System (AFWS). A site tour to observe the system was conducted on April 28, 1981.

The meeting consisted of a review of the written presentation, "Auxiliary Feedwater Design Review," which was submitted by the Applicants letter of April 24, 1981. The table of contents of that submittal provided the agenda for the meeting and is attached (Enclosure 2). The submittal also includes as Appendix A a synopsis (Report PLG-0166 dated March, 1981) of the reliability analysis of the Midland AFWS, for which the full report (PLG-0147 dated October, 1980) was forwarded by the Applicant's letter of February 23, 1981. For details of the meeting, see these documents. Selected illustrations from these documents are reprinted (Enclosure 3).


Several action items were identified during the meeting:

1. At least one AFWS flow train should be capable of being operated independently of AC power for at least two hours. In the event of a complete loss of AC the AFW turbine driven pump room coolers will not be available. Consumers Power committed to provide the results of a study to demonstrate that the AFW turbine driven pump and any associated equipment in the turbine driven pump room will operate and remain operable for two hours without room cooling.
2. A transfer of the normal suction of the AFWS to the Service Water System is automatic upon coincident AFW Actuation signal and low suction pressure. If the AFWS is manually initiated and the normal (non-seismic, non-tornado) water source is lost, operator action would be required to effect a transfer. Consumers Power should investigate the advisability of installing an automatic low suction pressure pump trip to provide pump protection. This concern must be addressed to evaluate Recommendation GL-4, paragraph 10A.3.3 of FSAR Appendix 10A.

18106110017  
A

3. Consumers Power should revise FSAR section 9.3.3, Equipment and Floor Drainage System, to include a description and location of the controls for the drain isolation valves for the Engineered Safety Features and AFWS equipment rooms.
4. Consumers Power should investigate the effects of the seismic anchor being located downstream of the check valve on the suction line to the condenser hotwell. Consumers Power should discuss the reason for the present location of the seismic anchor and the merits of relocating it upstream of the check valve.
5. The Midland design includes AC solenoid control valves in the pump recirculation lines. Since these valves fail closed on loss of control power, Consumers Power should determine whether there are conditions in a complete loss of AC event that could result in the AFWS turbine driven pump flow falling below the manufacturer's required pump flow.
6. On April 24, 1980, a generic letter with short term and long term AFWS recommendations was issued to applicants with Babcock and Wilcox NSSS. Subsequently, Additional Short Term Recommendation 2 on pump endurance testing was revised from 72 hours to 48 hours. Test data requirements were added to the 48 hours endurance test guidelines. Consumers Power should commit to conducting pump endurance tests per the revised recommendation and providing the data requested in the revised recommendation.
7. Recommendation GS-4 states that emergency procedures for transferring to alternate sources of AFW supply should be available to the plant operators. Consumers Power should indicate that procedures will be available for the case in which the primary water supply is being depleted. The procedures should be consistent with the criteria in GS-4.
8. Recommendation GS-6 specifies that flow path availability for an AFWS flow train that has been out of service to perform periodic testing or maintenance should be confirmed. Consumers Power should state that there will be procedures or a technical specification requirement for independent backup verification of proper valve alignment. Consumers Power should also indicate that technical specifications will be proposed to assure that prior to plant startup following an extended cold shutdown, a flow test will be performed to verify a flow path from the Condensate Storage Tank to the steam generators.

9. Additional Short Term Recommendation 1 discussed the level indication and alarm provisions needed for the primary water sources. Consumers Power should describe how its design meets these provisions.
10. Additional Short Term Recommendation 4 discusses procedures to be followed in plants which require local manual realignment of valves to conduct periodic tests on one AFWS train and which have only one remaining AFW train available for operation. The Consumers Power response only discussed provisions for operator communication in the control room. Consumers Power should commit to following the operator procedures discussed in this recommendation.
11. Consumers Power should review the AFWS normally open manual valves from a reliability view point to determine the need for administrative controls.



Darl Hood  
Licensing Branch No. 4  
Division of Licensing

Enclosures:  
As stated

Mr. J. W. Cook  
Vice President  
Consumers Power Company  
1945 West Parnall Road  
Jackson, Michigan 49201

cc: Michael I. Miller, Esq.  
Ronald G. Zamarin, Esq.  
Alan S. Farnell, Esq.  
Isham, Lincoln & Beale  
Suite 4200  
1 First National Plaza  
Chicago, Illinois 60603

James E. Brunner, Esq.  
Consumers Power Company  
212 West Michigan Avenue  
Jackson, Michigan 49201

Myron M. C. Esq.  
1 IBM Plaza  
Chicago, Illinois 60611

Ms. Mary Sinclair  
5711 Summerset Drive  
Midland, Michigan 48640

Frank J. Kelley, Esq.  
Attorney General  
State of Michigan Environmental  
Protection Division  
720 Law Building  
Lansing, Michigan 48913

Mr. Wendell Marshall  
Route 10  
Midland, Michigan 48640

Mr. Steve Gadler  
2120 Carter Avenue  
St. Paul, Minnesota 55108

Mr. Don van Farowe, Chief  
Division of Radiological Health  
Department of Public Health  
P.O. Box 33035  
Lansing, Michigan 48909

William J. Scanlon, Esq.  
2034 Pauline Boulevard  
Ann Arbor, Michigan 48103

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Route 7  
Midland, Michigan 48640

Ms. Barbara Stamiris  
5795 N. River  
Greeland, Michigan 48623

ENCLOSURE 1

ATTENDEES

AFW Presentation 4/30/81

O. D. Parr	NRC/DSI/ASB
E. J. Sullivan, Jr.	NRC/DSI/ASB
B. J. Roscoe	SNL/DIV 4412
Darl S. Hood	NRC/DOL
Raj Anand	NRC/NRR
Dennis C. Bley	Pickard, Lowe & Garrick
Dennis Budzik	CPCO Licensing
Blair Fairbrother	E&W/Systems Engineering
Cesar P. Ansoldo	Bechtel/Mechanical Group - Midland Project
Gusharan Singh	Bechtel/Control Systems
Ashok K. Katyal	Bechtel/Control Systems
T. G. Ballweg	Bechtel/Mechanical Group
R. A. Polick	CPCO/Mech/Nuclear - Design Productions
P. E. Papaisannou	CPCO - Safety Analysis
R. M. Hamm	CPCO - Safety & Licensing
T. J. Sullivan	CPCO - Safety & Licensing
L. S. Gibson	CPCO - Safety & Licensing
J. G. Kovach	Bechtel/Electrical
K. C. Prasad	Bechtel/Nuclear Staff
B. P. Burdick	Bechtel/Licensing & Safety
D. F. Lewis	Bechtel/Licensing & Safety
D. W. Stillwell	Pickard, Lowe & Garrick Inc.
J. P. Kindinger	CPCO - Safety & Licensing
F. J. Levandesk	B&W/Project Mgt.
R. G. Griese	B&W - Systems Engineering
S. W. Emerson	Bechtel/Mechanical Group
J. D. Agar	B&W - Project Engineering
R. W. Huston	CPCO - Licensing
B. L. Harshe	CPCO - Safety & Licensing
T. A. Klompstra	CPCO - Safety & Licensing
John Wahl	Bechtel - Safety & Licensing



**POOR ORIGINAL**

TABLE OF CONTENTS

	<u>Page</u>
1.0 <u>INTRODUCTION</u>	1-1
1.1 PURPOSE OF PRESENTATION	1-1
1.2 PRESENTATION FORMAT	1-1
1.3 INTRODUCTION OF SPEAKERS	1-1
2.0 <u>DESIGN BASES</u>	2-1
2.1 SAFETY DESIGN BASES	2-1
2.2 POWER GENERATION DESIGN BASES	2-2
2.3 CODES AND STANDARDS	2-2
3.0 <u>SYSTEM DESIGN AND OPERATION</u>	3-1
3.1 AFW SUPPLY PIPING AND SUCTION SOURCES	3-1
3.2 AFW PUMPS	3-2
3.3 AFW DISCHARGE PIPING	3-3
3.4 OPERATING MODES	3-4
3.5 AFW ACTUATION	3-5
3.6 POWER SUPPLY	3-6
3.7 INSTRUMENTATION AND CONTROLS	3-8
4.0 <u>STEAM GENERATOR CONTROL/SYSTEM RESPONSE</u>	4-1
4.1 STEAM GENERATOR LEVEL CONTROL	4-1
4.2 FEED-ONLY-GOOD GENERATOR INTERLOCK	4-5
4.3 STEAM GENERATOR OVERFILL PROTECTION	4-6

	<u>Page</u>
5.0 <u>AFW SYSTEM RELIABILITY</u>	5-1
6.0 <u>DESIGN EVALUATION/REGULATIONS</u>	6-1
6.1 SAFETY EVALUATION	6-1
6.2 GENERAL DESIGN CRITERIA	6-3
6.3 REGULATORY GUIDES	6-5
6.4 BRANCH TECHNICAL POSITIONS	6-7
6.5 OTHER REGULATORY GUIDANCE	6-8

LIST OF ABBREVIATIONS

TABLES

FIGURES

APPENDIX A:	MIDLAND PLANT AFW SYSTEM RELIABILITY ANALYSIS SYNOPSIS
APPENDIX B:	FSAR APP 10A
APPENDIX C:	TECHNICAL SPECIFICATION 16.3/4.7.1.2
APPENDIX D:	NUREG-0667 RESPONSES, RECOMMENDATIONS 9, 10, 21
APPENDIX E:	FSAR QUESTION 211.184
APPENDIX F:	FSAR CHAPTER 7 (SELECTED SECTIONS)

**POOR ORIGINAL**