

- 4.2.4 The licensee shall submit a report or application for license amendment to the NRC within 90 days after any time that Crystal River Unit 3 fails to maintain a cumulative reactor utilization factor of at least 65%.

The report shall provide justification for continued operation of TMI-1 with the reactor vessel surveillance program conducted at Crystal River Unit No. 3, or the application for license amendment shall propose an alternate program for conduct of the TMI-1 reactor vessel surveillance program.

For the purpose of this technical specification, the definition of commercial operation is that given in Regulatory Guide 1.16, Revision 4. The definition of cumulative reactor utilization factor is:

Cumulative reactor utilization factor - (Cumulative megawatt hours (thermal) since the beginning of Cycle 3 (9/10/80) x (100) divided by (licensed power (MWt) x (Cumulative hours since the beginning of Cycle 3 (9/10/80))).

- 4.2.5 In addition to the reports required by Specification 4.2.4, a report shall be submitted to the NRC prior to September 1, 1982, which summarizes the first five years of operating experience with the TMI-1 integrated surveillance program performed at a host reactor. If, at the time of submission of this report, it is desired to continue the surveillance program at a host reactor, such continuation shall be justified on the basis of the attained operating experience.

Bases

- a. Specifications 4.2.1 & 2 ensure that inservice inspection of ASME Code Class 1, 2 and 3 components will be performed in accordance with a periodically updated version of Section XI of the ASME Boiler and Pressure Vessel Code and Addenda as required by 10 CFR 50.55a(g). Relief from any of the above requirements has been provided in writing by the NRC and is not a part of these technical specifications.