



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

THE TOLEDO EDISON COMPANY

AND

THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

DOCKET NO. 50-346

DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 39
License No. NPF-3

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by The Toledo Edison Company and The Cleveland Electric Illuminating Company (the licensees) dated March 22, 1978, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8106150 053

2. Accordingly, Facility Operating License No. NPF-3 is hereby amended as indicated below and by changes to the Technical Specifications as indicated in the attachment to this license amendment:


Revise paragraph 2.C.(2) to read as follows:

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 39, are hereby incorporated in the license. The Toledo Edison Company shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: June 1, 1981

ATTACHMENT TO LICENSE AMENDMENT NO. 39

FACILITY OPERATING LICENSE NO. NPF-3

DOCKET NO. 50-346

Replace page 3/4 3-7 of the Appendix "A" Technical Specifications with the enclosed page as indicated. The revised page is identified by Amendment number and contains a vertical line indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

TABLE 4.3-1

REACTOR PROTECTION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
1. Manual Reactor Trip	N.A.	N.A.	S/U(1)	N.A.
2. High Flux	S	D(2), and Q(7)	M	1, 2
3. RC High Temperature	S	R	M	1, 2
4. Flux - Δ Flux - Flow	S(4)	M(3) and Q(7,8)	M	1, 2
5. RC Low Pressure	S	R	M	1, 2
6. RC High Pressure	S	R	M	1, 2
7. RC Pressure-Temperature	S	R	M	1, 2
8. High Flux/Number of Reactor Coolant Pumps On	S	R	M	1, 2
9. Containment High Pressure	S	R	M	1, 2
10. Intermediate Range, Neutron Flux and Rate	S	R(7)	S/U(5)(1)	1, 2 and*
11. Source Range, Neutron Flux and Rate	S	R(7)	M and S/U(1)(5)	2, 3, 4 and 5
12. Control Rod Drive Trip Breakers	N.A.	N.A.	M and S/U(1)	1, 2 and*
13. Reactor Trip Module Logic	N.A.	N.A.	M	1, 2 and*
14. Shutdown Bypass High Pressure	S	R	M	2**,3**,4**,5**