NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE: C A R S S 1 (2)	LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3)	LICENSE TYPE: 4 1 1 1 1 (4) CAT: (5)
CON'T 0 1	REPORT SOURCE: L (6)	DOCKET NUMBER: 0 5 0 0 0 3 1 2 (7)	EVENT DATE: 0 5 0 6 8 1 (8) REPORT DATE: 0 6 0 2 8 1 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 On May 6, 1981 while performing SP 201.10A, Safety System Hydraulic Snubbers

0 3 Surveillance Inservice Test, an inaccessible snubber, List No. SS-22, was

0 4 found low on fluid. Per Technical Specification Table 4.14-1 it is exempt

0 5 from functional testing, and it was therefore declared inoperable.

0 6

0 7

0 8

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	C B (11)	X (12)	Z (13)	S U P O R T (14)	D (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 1	—	0 2 8	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
B (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	Y (23)	N (24)	A (25)	B 2 0 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Similar to LER 81-22, the low fluid level was either due to the accumulator

1 1 internals or the valve body. Both were removed, reworked, and reinstalled.

1 2 The unit was then determined operable. To assure consistent snubber

1 3 inspection results, the District's Quality Assurance department will audit

1 4 the next scheduled snubber surveillance.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	H (28)	0 0 0 (29)	N/A	B (31)	Routine Surveillance

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	N/A	N/A

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	N/A

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	N/A

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	N/A

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	Y (44)	Local newspapers and wire services	

8106160202

NAME OF PREPARER R. W. Colombo PHONE (916) 452-3211