LICENSEE EVENT REPORT

CICCIOCE OF THE CONTROL INFORMATION)
CONTROL SLOCK: PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION
0 1 P A B V S 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 4 57 CAT 58 5
CONT ARPORT L 6 0 5 0 0 0 3 3 4 0 0 5 0 3 8 1 8 0 6 0 2 8 1 9
VENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) [0 2 In the process of putting the Residual Heat Removal (RHR) System in operation on
May 3, 1981, one of the RHR pump suction valves would not open. The failure of this valve would have precluded use of the RHR System until repairs could be made. The
old valve would have precluded use of the KRK System differ repair walley is not designed as a
consequences to this problem are minimal because Beaver Valley is not designed as a
0 [6] cold shutdown plant.
0 7 1
7 8 9 SYSTEM CAUSE CAUSE COMP. VALVE
CODE CODE SUBCODE COMPONENT CODE SUBCODE
17 REPORT NUMBER S 1
ACTION FUTURE SPECT SHUTDOWN HOURS 22 ATTACHMENT SUBMITTED FORM SUB. SUPPLIER SUPPLIER L 2 0 0 26
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
No specific cause was found for the failure. Adjustments were made to the valve
[:] Limit switch to assist opening. Wiring and terminal connections were also checked.
There is presently a task force looking at motor operators that could possibly
[:[3] provide input to this problem.
80
2 3 3 FACILITY STATUS SPOWER OTHER STATUS
10 12 13 45 46
ACTIVITY CONTENT RELEASED OF RELEASE N/A N/A N/A 80
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
1 - 0 0 0 37 Z 33 N/A 80
NUMBER DESCRIPTION (41) 1 3 0 0 0 40 N/A 80
LOSS OF OR DAMAGE TO FACILITY 43
NAC USE ONLY
SSUED DESCRIPTION (45) N/A 68 69 30.5
7 3 9 10 NAME OF PREPARER W. S. Lacey PHONE 412-643-8525

Attachment To LER 81-48/03L Beaver Valley Power Station Duquesne Light Company Docket No. 50-334

No further information is available or needed to satisfy the reporting requirement.