

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | O R T N P 1 | 2 0 0 - 0 0 0 0 0 0 - 0 0 | 3 4 1 1 1 1 | 4 | 5
7 8 9 | LICENSEE CODE 14 15 | LICENSE NUMBER 25 28 | LICENSE TYPE 30 | 57 CAT 58

CON'T
0 1 | REPORT SOURCE | L 6 0 5 0 - 0 3 4 4 | 7 0 5 0 2 8 1 | 8 0 6 0 1 8 1 | 9
7 8 9 | DOCKET NUMBER 58 59 | EVENT DATE 74 75 | REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | THE OUTER DOOR OF THE AIRLOCK AT THE 93' ELEVATION OF CONTAINMENT WAS
0 3 | LEFT OPEN FOR APPROXIMATELY 10 HOURS. THE PLANT WAS IN MODE 3 AT THIS
0 4 | TIME AND TECHNICAL SPECIFICATIONS REQUIRE THAT BOTH AIRLOCK DOORS BE
0 5 | CLOSED EXCEPT WHEN THE AIRLOCK IS BEING USED FOR NORMAL TRANSIT. WITH
0 6 | THE OUTER DOOR LEFT OPEN, THE REQUIREMENTS OF THIS SPECIFICATION WERE
0 7 | NOT MET.

0 9 | SYSTEM CODE | S | A | 11 | CAUSE CODE | D | 12 | CAUSE SUBCODE | Z | 13 | COMPONENT CODE | P E N E T R | 14 | COMP. SUBCODE | A | 15 | VALVE SUBCODE | Z | 16
7 8 9 | 9 10 | 11 | 12 | 13 | 18 | 19 | 20

17 | LER/RO REPORT NUMBER | 8 1 | EVENT YEAR | 8 1 | SEQUENTIAL REPORT NO. | 0 1 0 | OCCURRENCE CODE | 0 3 | REPORT TYPE | L | REVISION NO. | 0
21 22 | 23 | 24 26 | 27 | 28 29 | 30 | 31 | 32
ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
H 18 | G 19 | Z 20 | Z 21 | 0 0 0 0 | Y 23 | N 24 | A 25 | W 3 0 2 | 26
33 34 | 35 | 36 | 37 | 40 | 41 | 42 | 43 | 44 | 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | PERSONNEL ERROR. ADDITIONAL TRAINING AND INSTRUCTIONS HAVE BEEN
1 1 | PROVIDED.
1 2 |
1 3 |
1 4 |

1 5 | FACILITY STATUS | D | 28 | % POWER | 0 0 0 0 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | OPERATOR OBSERVATION | 32
7 8 9 | 9 10 | 12 13 | 13 | 44 45 | 46 | 46

1 6 | ACTIVITY RELEASED | Z | 33 | CONTENT | Z | 34 | AMOUNT OF ACTIVITY | N/A | 35 | LOCATION OF RELEASE | N/A | 36
7 8 9 | 9 10 | 11 | 44 | 45 | 46 | 80

1 7 | PERSONNEL EXPOSURES NUMBER | 0 0 0 | 37 | TYPE | Z | 38 | DESCRIPTION | N/A | 39
7 8 9 | 9 10 | 11 | 12 | 13 | 80

1 8 | PERSONNEL INJURIES NUMBER | 0 0 0 | 40 | DESCRIPTION | N/A | 41
7 8 9 | 9 10 | 11 | 12 | 80

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | N/A | 43
7 8 9 | 9 10 | 11 | 12 | 80

2 0 | PUBLICITY ISSUED | Z | 44 | DESCRIPTION | N/A | 45 | NRC USE ONLY
7 8 9 | 9 10 | 11 | 12 | 68 69 | 80

NAME OF PREPARER R. P. Schmitt PHONE: (503) 556-3713

8106160536