June 12, 1981

Docket No. 50-213 LS05-81-06-048

> Mr. W. G. Counsil, Vice President Nuclear Engineering and Operations Connecticut Yankee Atomic Power Co. Post Office Box 270 Hartford, Connecticut 06101



Dear Mr. Counsil:

SUBJECT: SEP TOPICS VII-1.A, ISOLATION OF REACTOR PROTECTION SYSTEM FROM NON-SAFETY SYSTEMS, INCLUDING QUALIFICATION OF ISOLA-TION DEVICES AND VII-2, ENGINEERED SAFETY FEATURES (ESF) SYSTEM CONTROL LOGIC AND DESIGN - REQUEST FOR ADDITIONAL INFORMATION (HADDAM NECK)

The enclosed request for additional information has been prepared as part of our evaluation of the subject matters at Haddam Neck.

Because these concerns are parts of SEP Topics, response within 30 days is requested so that we maintain the present SEP review schedule.

Sincerely,

Dennis M. Crutchfield, Chief Operating Reactors Branch No. 5 Division of Licensing

Enclosure: As stated

cc w/enclosure: See next page

8106180 271 p

OFFICE	SEPB: DE	SEPB: DL	SEPB:DL	ORB#5;PL:PM	OR	Ag:SA:DL
6. The . E .	RSchall:dk	RHermann	WRussel1	WPaulson	DCrutchfield	dLainas
(77	6F1/81	6/9/81	6/10 /81	6/10 /81	6/11/81	6/ /81
Lac Port	ala is abinate	(240	05510141		0.94	USGRD 1980-12



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555 June 12, 1981

Docket No. 50-213 LS05-81-06-048

> Mr. W. G. Counsil. Vice President Nuclear Engineering and Operations Connecticut Yankee Atomic Power Co. Post Office Box 270 Hartford, Connecticut 06101

Dear Mr. Counsil:

SUBJECT: SEP TOPICS VII-1.A, ISOLATION OF REACTOR PROTECTION SYSTEM FROM NON-SAFETY SYSTEMS, INCLUDING QUALIFICATION OF ISOLA-TION DEVICES AND VII-2, ENGINEERED SAFETY FEATURES (ESF) SYSTEM CONTROL LOGIC AND DESIGN - REQUEST FOR ADDITIONAL INFORMATION (HADDAM NECK)

The enclosed request for additional information has been prepared as part of our evaluation of the subject matters at Haddam Neck.

Because these concerns are parts of SEP Topics, response within 30 days is requested so that we maintain the present SEP review schedule.

Sincerely,

mis M. Cutche

Dennis M. Crutchfield, Chief Operating Reactors Branch No. 5 Division of Licensing

Enclosure: As stated

cc w/enclosure: See next page Mr. W. G. Counsil

1.

cc

Day, Berry & Howard Counselors at Law One Constitution Plaza Hartford, Connecticut 06103

Superintendent Haddam Neck Plant RFD #1 Post Office Box 127E East Hampton, Connecticut 06424

Mr. James R. Himmelwright Northeast Utilities Service Company P. O. Box 270 Hartford, Connecticut 06101

Russell Library 119 Broad Street Middletown, Connecticut 06457

Board of Selectmen Town Hall Haddam, Connecticut 06103

Connecticut Energy Agency ATTN: Assistant Director Research and Policy Development Department of Planning and Energy Policy 20 Grand Street Hartford, Connecticut 06106

Director, Criteria and Standards Division. Office of Radiation Programs (ANR-460) U. S. Environmental Protection Agency Washington, D. C. 20460 U. S. Environmental Protection Agency Region I Office ATTN: EIS COORDINATOR JFK Federal Building Boston, Massachusetts 02203

Resident Inspector Haddam Neck Nuclear Power Station c/o U. S. NRC East Haddam Post Office East Haddam, Connecticut 06423

REQUEST FOR ADDITIONAL INFORMATION

ON HADDAM NECK FOR SEP TOPICS VII-1.A AND VII-2

ISOLATION OF REACTOR PROTECTION AND ENGINEERED SAFETY SYSTEMS

The FDSAR and available drawings do not contain sufficient information for us to adequately review the degree of isolation between the Reactor Trip and ESF systems from control and non-safety systems. Therefore please provide the following additional information and drawings:

- Current schematics or elementary diagrams of the Reactor Trip System and the ESF Systems and their interface with Shared Control Systems.
- 2. P&ID's of the ESF systems.

man .

- Identify by make and model the isolation buffers installed in the Nuclear Power Range channels to obtain isolated indication of the detector ion currents. (Plant Design Change #198.) Describe how they meet the requirements of IEEE Standard 279-1971 Sect. 4.7.2 and GDC 24.
- 4. Identify locations and describe any other isolation buffers currently in use in the reactor trip and ESF systems to isolate these systems from control, computer, recorders and non-safety systems. Describe how they comply with the requirements of IEEE Standard 279 and GDC 24.