



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 5, 1981

Dockets Nos. 50-277 and 50-278



Mr. Edward C. Bauer, Jr.
Vice President and General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

SUBJECT: ENVIRONMENTAL QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

RE: Peach Bottom Atomic Power Station, Licenses Nos. DPR-44 and DPR-56

Reference (a) - Order for Modification of License Concerning the Environmental Qualification of Safety-Related Electrical Equipment dated October 24, 1980

Dear Mr. Bauer:

This letter transmits the Safety Evaluation for the Environmental Qualification of Safety-Related Electrical Equipment at your facility. This evaluation was based on your submittals dated March 3, April 15, August 26 and October 31, 1980. Our letter of February 25, 1981, which forwarded our preliminary results, indicated that an item-by-item reevaluation would be required at a later date. This Safety Evaluation identifies the specific information required by the staff and the actions, on your part, necessary to comply with Reference (a). We request that you provide the information identified in Sections 3 and 4 of this Safety Evaluation to us within 90 days.

This Safety Evaluation addresses only the safety-related electrical equipment exposed to a harsh environment resulting from an accident (i.e., the IEB 79-01B review). Reference (a) requires that all safety-related electrical equipment be qualified by June 30, 1982. The NRC review effort for the equipment in mild environments will be addressed by separate correspondence.

Your response may present alternatives to the staff positions in the evaluation. The staff will consider alternative approaches if these methods are within the DOR Guidelines or NUREG-0588, as appropriate. For example, an acceptable alternative to the NRC staff's temperature criterion used for the service conditions (i.e. Section 3.3) must base that service condition on the FSAR analysis or other NRC approved analysis, provided that the specific analysis, together with reference to the previous NRC acceptance of that analysis, accompanies the 90 day response. In addition, some of the information in the Safety Evaluation may require clarification. Contact your project manager for assistance in these matters.

81061900514


P

Mr. Edward G. Bauer, Jr.

-2-

It remains your responsibility to assure that the qualification deadline is met for all safety-related electrical equipment. The staff's review of your response to this letter should not delay any action which is required in order to meet the deadline.

Sincerely,



John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosures:

1. SER
2. TER

cc w/ encl:
See next page

Philadelphia Electric Company

cc w/enclosure(s):

Eugene J. Bradley
Philadelphia Electric Company
Assistant General Counsel
2301 Market Street
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr.
1747 Pennsylvania Avenue, N.W.
Washington, D. C. 20006

Raymond L. Hovis, Esq.
35 South Duke Street
York, Pennsylvania 17401

Warren K. Rich, Esq.
Assistant Attorney General
Department of Natural Resources
Annapolis, Maryland 21401

Philadelphia Electric Company
ATTN: Mr. W. T. Ullrich
Peach Bottom Atomic
Power Station
Delta, Pennsylvania 17314

Albert R. Steel, Chairman
Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

Curt Cowgill
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Peach Bottom Atomic Power Station
P. O. Box 399
Delta, Pennsylvania 17314

Director, Criteria and Standards
Division
Office of Radiation Programs (ANR-460)
U. S. Environmental Protection Agency
Washington, D. C. 20460

U. S. Environmental Protection Agency
Region III Office
ATTN: EIS COORDINATOR
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

M. J. Cooney, Superintendent
Generation Division - Nuclear
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Government Publications Section
State Library of Pennsylvania
Education Building
Commonwealth and Walnut Streets
Harrisburg, Pennsylvania 17126

Mr. R. A. Heiss, Coordinator
Pennsylvania State Clearinghouse
Governor's Office of State Planning
and Development
P. O. Box 1323
Harrisburg, Pennsylvania 17120