

**Detroit
Edison**

2000 Second Avenue
Detroit, Michigan 48226
(313) 237-8000

June 16, 1981

EF2-53,667



Mr. L.L. Kintner
Division of Project Management
Office of Nuclear Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Reference: Enrico Fermi Atomic Power Plant - Unit 2
NRC Docket No. 50-341

Subject: GDC 51 Information Transmittal

Dear Mr. Kintner:

Detroit Edison submitted information on June 9, 1981, to demonstrate that the containment pressure boundary materials were fabricated in accordance with GDC 51. We then reported the maximum wedge thickness of HPCI valve V8-2194 to be 5¼". However, the vendor has subsequently indicated that, although this is the maximum thickness, 1½" is the most critical section thickness. This information is shown on the dimensional inspection report previously transmitted.

Sincerely,

W.F. Colbert
Technical Director
Fermi 2 Project

KH/gs

A

Bool
S/g

8106220 228