## LICENSEE EVENT REPORT LER 81-14/3L

	CONTROL BLOCK:
0 1	V T V Y S 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 57 CAT 58
GON'T	SQUACE   1   0   5   0   0   0   2   7   1   7   0   5   1   8   8   1   3   0   6   1   6   8   1   9
0 2	During monthly surveillance testing the A Diesel Generator was shutdown due to sub-
013	stantial coolant leakage in the No. 12 cylinder cooling water jacket outlet. The
04	inoperable diesel was contrary to the requirements of T. S. 3.5.H.1 and 3.10.B.1.
0 5	There were no consequences to the public health and safety as a result of this event.
06	No similar occurrences were reported to the commission.
0 7	
018	1
	SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBCODE
0 9	E E (1) E (12) B (13) E N G-I N E (14) Z (15) (16)  SEQUENTIAL OSCURRENCE REPORT REVISION
	17 REPORT   8 1
	ACTION FUTURE EFFECT SHUTDOWN METHOD HOURS 22 ATTACHMENT FORM SUB. SUPPLIER MANUFACTURER LA 18 Z 19 Z 20 Z 21 0 0 0 0 0 N 24 A 25 F 0 1 0 26
1101	The cause of the event was found to be a failed gasket in the cooling water jacket
	outlet of the No. 12 cylinder. The gasket was replaced and a subsequent satisfactory
1121	surveillance test was performed.
TIA	
7 8	FACILITY STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION (32)
7 8	E 28 1 0 0 29 NA B 31 Surveillance Test
	ELEASED OF RELEASE AMOUNT OF ACTIVITY (15)  [Z] (3) [Z] (34) NA NA NA
7 9	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
7 9	0 0 0 0 27 Z 38 NA
1 3	NUMBER DESCRIPTION (41)  [0   0   0   (40)  NA
-	LOSS OF OR DAMAGE TO FACILITY 43
1 9	Z   42   NA   10
2 2	SSUED DESCRIPTION 45 NA NA NA NA
81	0622 TME OF PREPARER Warren P. Murphy PHONE (802) 257-7711
01	339