

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER - DALLAS, TEXAS 75201

Log # TXX-3335
File # 830

June 16, 1981

Mr. Spottswood Burwell
U. S. Nuclear Regulatory Commission
Licensing Project Manager
Office of Nuclear Reactor Regulation
Washington, D.C. 20555



SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
EXPANDED COMMITMENT FOR STARTUP TESTS
OF AUXILIARY FEEDWATER AND FEEDWATER SYSTEMS

Dear Mr. Burwell:

Our startup test commitment shall be expanded to include a 48 hour endurance test of the Auxiliary Feedwater Systems. Additionally, Feedwater and Auxiliary Feedwater Systems shall be tested for waterhammer.

If you have any questions, please call.

Sincerely,

H. C. Schmidt
H. C. Schmidt

G. D.

AND:tlb

cc: R. D. Calder

J. C. Kuykendall

3001
51/0

8106220326