

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER - DALLAS, TEXAS 75201

Log # TXX-3314
File # 830

June 22, 1981

Mr. Spottswood Burwell
Licensing Project Manager
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555



SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
CIRCULATING WATER EXPANSION JOINT FAILURE

REF: LETTER TXX-3310, EVALUATION OF CIRCULATING WATER EXPANSION
JOINT FAILURE

Dear Mr. Burwell:

In regards to the referenced letter we shall provide estimates of the time the operator requires to terminate the forced flow into the Turbine Building and identify the instrumentation that alerts the operator to flooding. If flooding above the PMF level occurs before the operator can terminate the expansion joint leak, modifications will be proposed to prevent flooding above the PMF level in the electrical and control buildings and/or provide additional instrumentation to the operator to assure a faster response time.

If you have any questions, please call.

Sincerely,

H. C. Schmidt

AND:tls

cc: R. D. Calder
R. E. Ballard
J. T. Merritt
J. C. Kuykendall

Boo!
3
1/0

8106260 191