



**Consumers
Power
Company**

COPY

General Offices: 212 West Michigan Avenue, Jackson, MI 49201 • (517) 788-0550

June 26, 1981

Director, Nuclear Reactor Regulation
Att Mr Dennis M Crutchfield, Chief
Operating Projects Branch No 5
US Nuclear Regulatory Commission
Washington, DC 20555

DOCKET 50-155 - LICENSE DPR-6 -
BIG ROCK POINT PLANT - SEP TOPIC XV-14, INADVERTENT
OPERATION OF ECCS AND CHEMICAL AND VOLUME CONTROL
SYSTEM MALFUNCTION THAT INCREASES REACTOR COOLANT
INVENTORY

Attached is the Consumers Power Company evaluation of SEP Topic XV-14 for
the Big Rock Point Plant.

Robert A Vincent (Signed)

Robert A Vincent
Staff Licensing Engineer

CC Director, Region III, USNRC
NRC Resident Inspector - Big Rock Point

P

8106290 229

Aφ35
S
1/0

Topic XV-14: Inadvertent Operation of ECCS and Chemical and Volume Control System Malfunction that Increases Reactor Coolant Inventory

Evaluation: For boiling water reactors, Standard Review Plan section 15.5.1/2 defines the following specific initiating events for consideration under this topic:

1. Inadvertent operation of high pressure core spray system
2. Inadvertent operation of high pressure coolant injection system
3. Inadvertent operation of reactor core isolation system

Big Rock Point has none of the systems listed above. Therefore, this topic is not applicable.