

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C M I G S 1 2 0 0 - 1 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

CON'T
01 REPORT SOURCE L 5 0 5 0 0 0 3 6 9 7 0 4 2 2 8 1 8 0 5 2 2 8 1 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 3, initial fuel loading, the outer door of the lower personnel
03 air lock closed; however, the locking pins would not move and the seals
04 would not inflate. The door was thus declared inoperable. This is in
05 violation of Technical Specification 3.6.1.3 and is reportable per Technical
06 Specification 6.9.1.13(b). Since the outer door remained operable, contain-
07 ment integrity was maintained and the health and safety of the public were
08 not affected.

09 SYSTEM CODE S D 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE P N E T R 14 COMP SUBCODE A 15 VALVE SUBCODE 16
17 LER/NO REPORT NUMBER 8 1 21 EVENT YEAR 8 1 22 SEQUENTIAL REPORT NO. 0 6 3 24 OCCURRENCE CODE 0 3 25 REPORT TYPE L 26 REVISION NO. 0 27
18 ACTION TAKEN A 18 28 FUTURE ACTION 2 19 29 EFFECT ON PLANT Z 20 30 SHUTDOWN METHOD Z 21 31 HOURS 0 0 0 0 32 ATTACHMENT SUBMITTED Y 33 NRC FORM SUB. N 34 PRIME COMP SUPPLIER L 35 COMPONENT MANUFACTURER W 3 0 36

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The shear pin which holds the limit switch actuating shaft in place was
11 missing. This prevented the limit switch from being actuated. The shear
12 pin was replaced and the door was returned to an operable status.

15 FACILITY STATUS X 28 29 POWER 0 0 0 29 Mode 3 30 OTHER STATUS 30 METHOD OF DISCOVERY A 31 32 DISCOVERY DESCRIPTION Personnel Observation 32

16 ACTIVITY CONTENT RELEASED OR RELEASE Z 32 33 AMOUNT OF ACTIVITY NA 34 LOCATION OF RELEASE NA 35

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 38 DESCRIPTION NA 39

18 PERSONNEL INJURIES NUMBER 0 0 0 40 41 DESCRIPTION NA 42

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 43 DESCRIPTION NA 44

20 PUBLICITY ISSUED N 44 45 DESCRIPTION NA 46

NAME OF PREPARER R. W. Ouellette

PHONE: (704) 373-7530

8106290 292