NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(2) LICENSEE CODE: NCMGS1 (3) LICENSE NUMBER: 00-00 00 (4) LICENSE TYPE: 4111 (5) CAT

CON'T

(6) REPORT SOURCE: L (7) DOCKET NUMBER: 050003 69 (8) EVENT DATE: 041881 (9) REPORT DATE: 051881

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

While in Mode 3, initial fuel loading, a lower containment high temperature alarm was received in the Control Room. The feeder breakers for the containment ventilation air handling units C and D had tripped. This is in violation of T.S. 3.6.1.5 since the lower containment temperature exceeded 120°F. This is reportable per T.S. 6.9.1.13(b). Unit D was still capable of operation, therefore the health and safety of the public were not affected.

SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
SB	A	C	CKTBRK	A	Z

(17) LER/RO REPORT NUMBER: EVENT YEAR 81 — SEQUENTIAL REPORT NO. 058 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
E	X	Z	2	0000	Y	N	L	W120

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The magnetic overload switch on Unit D breaker was adjusted incorrectly and it could not be readily determined what caused the unit C breaker to trip. The Unit C breaker was reset and the unit D breaker was replaced. Preventative maintenance will be performed on Unit D.

FACILITY STATUS (28): X — % POWER (29): 000 — OTHER STATUS (30): Mode 3 — METHOD OF DISCOVERY (31): A — DISCOVERY DESCRIPTION (32): Operator Observation

ACTIVITY RELEASED (33): Z — CONTENT OF RELEASE (34): Z — AMOUNT OF ACTIVITY (35): NA — LOCATION OF RELEASE (36): NA

PERSONNEL EXPOSURES — NUMBER (37): 000 — TYPE (38): Z — DESCRIPTION (39): NA

PERSONNEL INJURIES — NUMBER (40): 000 — DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY — TYPE (42): Z — DESCRIPTION (43): NA

PUBLICITY — ISSUED (44): N — DESCRIPTION (45): NA

NRC USE ONLY

NAME OF PREPARER: R. W. Ouellette — PHONE: (704) 373-7530

8106290226