

TEXAS UTILITIES GENERATING COMPANY

2601 ERYAN TOWER • DALLAS, TEXAS 75201

June 23, 1981
TXX-3349

R. J. GARY
EXECUTIVE VICE PRESIDENT
AND GENERAL MANAGER

Mr. G. L. Madsen, Chief
Reactor Projects Branch
U. S. Nuclear Regulatory Commission
Office of Inspection & Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76012

Docket Nos. 50-445
50-446

COMANCHE PEAK STEAM ELECTRIC STATION
HVAC COOLING SYSTEM
FILE NO: 10110

Dear Mr. Madsen:

In accordance with 10 CFR 50.55(e), we verbally reported to your Mr. R. G. Taylor on March 30, 1981, deficiencies associated with the HVAC System supplying cooling to the rooms containing vital AC power converters and DC battery chargers.

On April 24, 1981 we submitted an interim report logged TXX-3307 which addressed the technical aspects of the deficiency. We advised you at that time that we, in conjunction with our AE's QA staff, were examining the QA program aspects of this deficiency. We have completed our examination and have concluded that the problem is not a result of a QA program deficiency, but a design evolution resulting from increasing loads and equipment qualification program considerations.

Our corrective actions will be completed as described in the TXX-3307 April 24, 1981 report.

If we can provide any additional information, please advise.

Very truly yours,

R. J. Gary
R. J. Gary

RJG:kh

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement - (15 copies)
c/o Distribution Services Branch, DDC, ADM.
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8106290

356

5