

CEPA



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 9, 1981

Docket No. 50-334



Mr. J. J. Carey, Vice President
Duquesne Light Company
Nuclear Division
Post Office Box 4
Shippingport, Pennsylvania 15077

Dear Mr. Carey:

SUBJECT: ENVIRONMENTAL QUALIFICATION OF SAFETY-RELATED ELECTRICAL EQUIPMENT

RE: Beaver Valley Power Station, Unit No. 1, License No. DPR-66

Reference: Order for Modification of License Concerning the Environmental Qualification of Safety-Related Electrical Equipment, October 24, 1980

This letter transmits the preliminary results of our review of environmental qualifications of safety-related electrical equipment at your facility. This evaluation was based on your submittals received over the past months.

The facility license was modified by the referenced Order of October 24, 1980, to require that all safety-related electrical equipment be qualified to specified requirements not later than June 30, 1982. In addition, the Order noted that a licensee is obligated to modify or replace inadequate equipment promptly.

The staff's review of your submittals has resulted in our identifying a number of potential equipment deficiencies involving a lack of proper documentation, inadequate justification of assumed environmental conditions such that conformance to the DOR guidelines, as required by the Order, cannot be demonstrated. You are requested to review our identified deficiencies, and their ramifications, and provide us your overall finding regarding continued safe operation of your facility. Accordingly, in order to determine whether your license should be modified or suspended, you are required pursuant to 10 CFR 50.54(f), to provide within 10 days of receipt of this letter, a written statement, signed under oath or affirmation supporting the safe operation of your facility, that takes into account the NRC staff's preliminary list of deficiencies.

The purpose of this statement is to provide the NRC with needed assurance, by the licensee, regarding the continued safety of the facility until you can provide an item-by-item reevaluation in a detailed documented manner at a later date. A negative finding on your part concerning the safety of continued operation would result in a unit shutdown, and should be reported as a Licensee Event Report (LER) within twenty-four (24) hours of the determination to the appropriate NRC Regional Office. Include in the LER the

P


Mr. J. J. Carey

-2-

actions you have taken for the immediate resolution of the matter. A copy of any such LER should be sent to the Director, Division of Licensing, Office of Nuclear Reactor Regulation.

Please submit a copy of your reply to us via telecopy.

Sincerely,



Thomas A. Novak, Assistant Director
for Operating Reactors
Division of Licensing

Enclosure:
Evaluation Report

cc w/enclosure
See next page

Mr. J. J. Carey
Duquesne Light Company

cc: Mr. R. J. Washabaugh, QA Manager
Duquesne Light Company
Quality Assurance Department
Post Office Box 4
Shippingport, Pennsylvania 15077

Mr. J. A. Werling
Station Superintendent
Duquesne Light Company
Beaver Valley Power Station
Post Office Box 4
Shippingport, Pennsylvania 15077

Mr. T. D. Jones, Manager
Nuclear Operations
Duquesne Light Company
Post Office Box 4
Shippingport, Pennsylvania 15077

Mr. F. J. Bissert, Manager
Nuclear Support Services
Duquesne Light Company
Nuclear Division
Post Office Box 4
Shippingport, Pennsylvania 15077

Mr. R. M. Mafrice, Nuclear Engineer
Duquesne Light Company
435 Sixth Avenue
Pittsburgh, Pennsylvania 15219

Mr. R. E. Martin, Nuclear Engineer
Duquesne Light Company
435 Sixth Avenue
Pittsburgh, Pennsylvania 15219

Mr. N. R. Tonet, Manager
Nuclear Engineering
Duquesne Light Company
Nuclear Division
Post Office Box 4
Shippingport, Pennsylvania 15077

Mr. J. D. Sieber, Manager
Nuclear Safety & Licensing
Duquesne Light Company
Nuclear Division
Post Office Box 4
Shippingport, Pennsylvania 15077

Gerald Charnoff, Esquire
Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Karin Carter, Esquire
Special Assistant Attorney General
Bureau of Administrative Enforcement
5th Floor, Executive House
Harrisburg, Pennsylvania 17120

Mr. Roger Tappan
Stone & Webster Engineering Corporation
P. O. Box 2325
Boston, Massachusetts 02107

Mr. F. Noon
R & D Center
Westinghouse Electric Corporation
Building 7-303
Pittsburgh, Pennsylvania 15230

Marvin Fein
Utility Counsel
City of Pittsburgh
313 City-County Building
Pittsburgh, Pennsylvania 15219

Mr. John A. Levin
Public Utility Commission
P. O. Box 3265
Harrisburg, Pennsylvania 17120

Irwin A. Popowsky, Esquire
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, Pennsylvania 17120

Charles E. Thomas, Esquire
Thomas and Thomas
212 Locust Street
Box 999
Harrisburg, Pennsylvania 17108

Resident Inspector
U. S. Nuclear Regulatory Commission
Post Office Box 298
Shippingport, Pennsylvania 15077