

Rhine Schelde-Verolme Zware
Apparatenbouw b.v. (RSV-A)
Bucket No. 99900039/81-01

NOTICE OF NONCONFORMANCE

Based on the results of an NRC inspection conducted on March 23-25, 1981, it appears that certain of your activities were not conducted in accordance with NRC requirements as indicated below.

Criterion XIII of Appendix B to 10 CFR Part 50 states: "Measures shall be established to control the handling, storage, shipping, cleaning, and preservation of material and equipment in accordance with work and inspection instructions to prevent damage or deterioration. When necessary for particular products, special protective environments, such as inert gas atmosphere, specific moisture content levels, and temperature levels, shall be specified and provided."

Contrary to the above, measures have not been established to control storage and preservation of the Black Fox Unit No. 1 reactor vessel in accordance with work and inspection instructions, to prevent damage or deterioration, while the completed vessel is being stored prior to shipment. (See Details Section, paragraph B.3.a.).