

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | M | E | M | Y | P | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 0 | 9 | 7 | 0 | 5 | 0 | 8 | 8 | 1 | 8 | 0 | 6 | 1 | 8 | 8 | 1 | 9

8 REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

2 | With the reactor plant in refueling shutdown mode, the main steam generator

3 | safety valve settings were checked as per T.S.4.2. Four of the six valves were

4 | found to be outside the 1% criteria. Valve settings were reset. There was no

5 | adverse effects on public health or safety.

9 SYSTEM CODE [C][C] (11) CAUSE CODE [E] (12) CAUSE SUBCODE [B] (13) COMPONENT CODE [V][A][L][V][E][X] (14) COMP. SUBCODE [J] (15) VALVE SUBCODE [B] (16)

17 LER NO. REPORT NUMBER [8][1] (17) EVENT YEAR [8][1] (21) SEQUENTIAL REPORT NO. [0][0][9] (24) OCCURRENCE CODE [0][3] (28) REPORT TYPE [] (30) REVISION NO. [0] (32)

ACTION TAKEN [E] (18) FUTURE ACTION [Z] (19) EFFECT ON PLANT [Z] (20) SHUTDOWN METHOD [Z] (21) HOURS [0][0][0][0] (22) ATTACHMENT SUBMITTED [N] (23) NRC-4 FORM SUB. [N] (24) PRIME COMP. SUPPLIER [A] (25) COMPONENT MANUFACTURER [C][7][1][0] (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The root cause of this occurrence is unknown at this time. All affected

11 | valves were readjusted and subsequent testing was satisfactory.

5 FACILITY STATUS [H] (28) % POWER [0][0][0] (29) OTHER STATUS [NA] (30) METHOD OF DISCOVERY [B] (31) DISCOVERY DESCRIPTION [Surveillance Test] (32)

6 ACTIVITY RELEASED [Z] (33) CONTENT [Z] (34) AMOUNT OF ACTIVITY [NA] (35) LOCATION OF RELEASE [NA] (36)

7 PERSONNEL EXPOSURES NUMBER [0][0][0] (37) TYPE [Z] (38) DESCRIPTION [NA] (39)

8 PERSONNEL INJURIES NUMBER [0][0][0] (40) DESCRIPTION [NA] (41)

9 TYPE OF DAMAGE TO FACILITY [Z] (42) DESCRIPTION [NA] (43)

10 PUBLICITY [N] (44) DESCRIPTION [NA] (45)

POOR ORIGINAL

8106300191

NRC USE ONLY