

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	A	L	J	M	F	2	2	0	0	-	0	C	0	0	0	-	0	0	3	4	1	1	1	1	4	5
LICENSEE CODE								LICENSE NUMBER								LICENSE TYPE								CAT 58			

7	8	L	6	0	5	0	0	0	3	6	4	7	0	6	0	2	8	1	8	0	6	2	4	8	1	9	
REPORT SOURCE				DOCKET NUMBER								EVENT DATE								REPORT DATE							

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0	1	At 1430 on 6/2/81, while performing FNP-2-STP-2i3.4B (Steam Generator 2C FT-495 Loop																											
0	3	Calibration). The FT495 instrumentation loop was declared inoperable when it failed to																											
0	4	meet the surveillance test voltage requirements. Tech. Spec. 3.3.1, in part, requires																											
0	5	the FT495 instrumentation loop to be operable. Tech. Spec. 3.3.1 action statement																											
0	6	requirements were met. Health/safety of the public was not affected.																											
0	7																												
0	8																												
0	9																												

0	9	I	A	11	E	12	G	13	I	N	S	T	R	U	14	T	15	Z	16
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE					

17	8	1	0	1	8	0	3	L	0
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE	

A	18	Z	19	Z	20	Z	21	0	0	0	0	N	23	N	24	N	25	W	1	2	0
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1	0	Investigation of the out of Spec. voltage condition revealed a faulty comparator card.																											
1	1	The card was replaced and following the successful completion of the calibration proce-																											
1	2	dure, instrumentation loop FT495 was returned to service at 1530 on 6/2/81.																											
1	3																												
1	4																												

1	5	E	28	0	3	2	29	NA	30	B	31	Surveillance Test												32
FACILITY STATUS		% POWER		OTHER STATUS				METHOD OF DISCOVERY		DISCOVERY DESCRIPTION														

1	6	Z	33	Z	34	NA	35	NA	36
ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY				LOCATION OF RELEASE	

1	7	0	0	0	37	Z	38	NA	39
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			

1	8	0	0	0	40	NA	41
PERSONNEL INJURIES		NUMBER		DESCRIPTION			

1	9	Z	42	NA	43
LOSS OF OR DAMAGE TO FACILITY		DESCRIPTION			

2	0	N	44	NA	45
PUBLICITY ISSUED		DESCRIPTION			

POOR ORIGINAL