

50.55e DMB



KANSAS GAS AND ELECTRIC COMPANY

GLENN L. KOESTER
VICE PRESIDENT - NUCLEAR

June 22, 1981

Mr. G.L. Madsen, Chief
Reactor Projects Branch
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011



KMLNRC 81-090
Re: Docket No. 50-482
Subj: Potential 50.55(e) Report on
Nonconforming Rockbestos Cable

Dear Mr. Madsen:

On May 22, 1981, Mr. E.W. Creel made a telephone report to Mr. W. Hubacek regarding nonconformance of specification requirements on approximately 20,000 feet of Rockbestos cable delivered to the Wolf Creek Generating Station Unit 1 site.

An investigation is currently being conducted to determine the location of all the remaining Rockbestos cable on site. Preliminary data indicates that approximately 130,000 feet of cable is involved. This cable has been placed on hold until the nonconforming lab test results have been dispositioned.

The results of this investigation and the action to be taken will be reported to your office on or before August 31, 1981.

If you have any questions regarding this matter, please contact us.

Yours very truly,

Glenn L. Koester
1E27
~~1E27~~
3/0

GLK.bb

cc: TVandel, Resident NRC Inspector

6106800 431

S