

APPENDIX I TO "SAFE SHUTDOWN ANALYSIS"  
RESPONSE TO 10CFR50 APPENDIX R  
FIP" PROTECTION - SECTION III.J  
EMERGENCY LIGHTING

JAMES A. FITZPATRICK NUCLEAR POWER PLANT  
POWER AUTHORITY OF THE STATE OF NEW YORK

JUNE 1981

810630 0454

TABLE OF CONTENTS

| <u>SECTION</u> |                        | <u>PAGE</u> |
|----------------|------------------------|-------------|
|                | LIST OF FIGURES        | 1           |
| A.1            | PURPOSE                | 2           |
| A.2            | SUMMARY OF RESULTS     | 2           |
| A.3            | ASSUMPTIONS            | 2           |
| A.4            | DEFINITIONS            | 3           |
| B.1            | METHOD OF ANALYSIS     | 5           |
| C.1            | METHOD OF PRESENTATION | 6           |

# LIST OF FIGURES

| <u>Figure</u> | <u>Title</u>                                              |
|---------------|-----------------------------------------------------------|
| 5-1           | Area Plan Administration Building El. 300'-0"             |
| 5-2           | Area Plan Administration Building El. 284'-8" and 286'-0" |
| 5-3           | Area Plan Administration Building El. 300'-0"             |
| 5-4           | Area Plan Reactor Building El. 300'-0"                    |
| 5-5           | Area Plan Reactor Building El. 272'-0"                    |
| 5-6           | Area Plan Reactor Building El. 300'-0"                    |
| 5-7           | Area Plan Administration Building El. 284'-8" and 286'-0" |
| 5-8           | Area Plan Administration Building El. 272'-0"             |
| 5-9           | Area Plan Reactor Building El. 272'-0"                    |
| 5-10          | Area Plan Reactor Building El. 227'-6" and 242'-8"        |
| 5-11          | Area Plan Turbine Building El. 244'-0" and 252'-0"        |
| 5-12          | Area Plan Screenwell El. 255'-6" and 260'-0"              |
| 5-13          | Area Plan Reactor Building El. 326'-0"                    |
| 5-14          | Area Plan Turbine Building El. 272'-0"                    |
| 5-15          | Area Plan Screenwell & Emer. Gen. Bldg. El. 272'-0"       |

## SECTION A

### A.1 PURPOSE

The purpose of this report is to identify the emergency lighting requirements for those areas of the FitzPatrick Plant needed for operation of safe shutdown equipment as defined in the "Safe Shutdown Analysis" report dated September 1979 and revised October 1980. This report also identifies the emergency lighting required for ingress and egress routes to those areas. This study addresses the requirements set forth in the NRC's 10CFR Part 50, Appendix R, Section III.J, "Emergency Lighting".

### A.2 SUMMARY OF RESULTS

The present study recommends the installation of new emergency lighting for local operation of equipment (i.e. MOV's, pumps, MCC, etc.) required for safe shutdown. In addition, new emergency lighting is recommended along operator routes for ingress and egress to safe shutdown equipment.

The new emergency lighting recommended in this study will be provided by individual battery packs which will meet the eight hour requirement of Section III.J of Appendix R. The approximate number of new eight hour battery packs shown on Figures 5-1 thru 5-15 totals 115. This number may be revised during the installation phase to accommodate actual site configurations of equipment in addition to special lighting requirements at operating equipment or panels. Where battery packs (with integrally mounted lamps) cannot be located adjacent to equipment or panels, battery packs with remote lamps will be used to provide proper illumination.

Lighting levels of approximately 1/2 to 1 foot candle will be maintained for access to equipment, and approximately 3 foot candles will be maintained for equipment operation.

In general, the battery packs will be normally supplied from the local AC lighting circuit in the area, so that the battery pack lights will automatically go on should the AC lighting in the area fail.

Maintenance for battery packs will be performed in accordance with the manufacturer's recommendations.

### A.3 ASSUMPTIONS

The following are the assumptions and design bases used for the Safe Shutdown Analysis, and are also applicable for the Emergency Lighting Analysis.

1. The only consequence of fire that is considered unacceptable will be the inability to safely shutdown and maintain the plant in a safe shutdown mode.
2. It is assumed that:
  - a. The reactor is operating at 100 percent power when a fire occurs.
  - b. Only onsite emergency power is available in achieving safe shutdown.
  - c. The reactor is isolated from the main condenser.
3. It was assumed that there is a 72 hr. period in which to achieve cold shutdown. During this 3-day period, credit may be taken for manual system operation, as well as for reasonable repairs, etc.
4. No single or concurrent failures other than those directly attributable to the fire were considered.
5. It was assumed that for any fire in a given fire zone all shutdown equipment and cable within that area is lost.
6. Loss of a cable does not automatically mean loss of components connected to that cable. Each cable was evaluated to determine whether it is essential to the functioning of the components to which it is connected before it is concluded that the component is lost.

Other failures due to hot shorts, opens, or grounds were also considered.
7. Fire areas or zones are identical to those identified in the Safe Shutdown Analysis Report.
8. No credit is taken in this analysis for the existing Emergency AC or DC Lighting Systems.

#### A.4 DEFINITIONS

1. Safe shutdown means hot shutdown or cold shutdown.
2. Hot shutdown means the reactor mode switch is in the shutdown position, \* and the average reactor coolant temperature is greater than 212°F.
3. Cold shutdown means the reactor mode switch is in the shutdown position, and the average reactor coolant temperature is less than or equal to 212°F.

4. Fire Area - an area completely enclosed by fire rated barriers.
5. Fire Zone - subdivision of a fire area defined for convenience of analysis.

\* When the mode switch is in the shutdown position, the reactor has scrammed.

## SECTION B

### B.1 METHOD OF ANALYSIS

The procedure shown below was followed for each fire zone or area defined in the "Safe Shutdown Analysis" report to determine the new emergency lighting required.

1. Review the report to evaluate the systems needed to achieve cold shutdown.
2. Identify the local or manual operation (remote from the control room) of equipment needed for the systems identified above as needed for safe shutdown.
3. Determine the areas in which this equipment is located.
4. Determine an operator path from the control room to the required areas.
5. Locate new emergency lighting in these areas and along the ingress and egress routes.

## SECTION C

### C.1 METHOD OF PRESENTATION


The attached figures 5-1 thru 5-15 show the approximate number of new 8 hour battery packs required to satisfy the requirements of Section III.J "Emergency Lighting". The actual number and location may be modified during installation due to actual site configurations.

Each figure shows the location of the equipment required for safe shutdown as identified in the Safe Shutdown Analysis Report. The battery packs are located to provide access to this equipment as well as to provide proper illumination at the equipment.



POOR ORIGINAL

FIGURE 5-1



SYMBOLS


- - EQUIPMENT
- ⌘ - EMERGENCY LIGHTING (EXIST.)
- - BATTERY PACK (NEW) (18)

FIGURE 5-1

SEE FIGURE 5-3  
FOR ADDITIONAL BATTERY  
PACKS IN THIS AREA

|                                             |      |
|---------------------------------------------|------|
| POWER AUTHORITY OF THE STATE OF NEW YORK    |      |
| JAMES A. FITZPATRICK<br>NUCLEAR POWER PLANT |      |
| AREA PLAN<br>ADMINISTRATION BLDG            |      |
| FL                                          | 300' |

FIGURE 5-2





- - EQUIPMENT
- ☒ - EMERGENCY LIGHTING (EXIST.)
- - BATTERY PACK (NEW) (4)

SEE FIGURE 5-7  
FOR ADDITIONAL BATTERY  
PACKS IN THIS AREA

POWER AUTHORITY OF THE STATE OF A. T. TEXAS  
JAMES A. FITZPATRICK  
JULIE ANN POWEN PLANT  
AREA PLAN  
ADMINISTRATION BLDG  
EL 284' & 286'

POOR ORIGINAL

FIGURE 5-3



SYMBOLS

- - EQUIPMENT
- X - EMERGENCY LIGHTING (EXIST.)
- - BATTERY PACK (NEW) (4)

FIGURE 5-3

SEE FIGURE 5-1  
FOR ADDITIONAL BATTERY  
PACKS IN THIS AREA

|                                             |      |
|---------------------------------------------|------|
| POWER AUTHORITY OF THE STATE OF NEW YORK    |      |
| JAMES A. FITZPATRICK<br>Nuclear Power Plant |      |
| AREA PLAN<br>ADMINISTRATION BLDG            |      |
| FL.                                         | 300' |




FIGURE 5-4


SEE FIGURE 5-6  
FOR ADDITIONAL BATTERY  
PACKS IN THIS AREA

● 合 格 考 生 可 以 參 加 2018 年 10 月 27 日 舉 行 的 第 一 次 考 試

**JAMES A FITZPATRICK**  
NUCLEAR POWER PLANT

AREA PLAN  
REACTOR BLDG

EL. 300'



# EQUIPMENT


- 1 ACCESS TUNNEL TO TONKUS RD
- 2 COMPENSATE TRANSFER PUMP (2)
- 3 COOLING COND. & REFRIG. (2)
- 4 CHD. WTR. COND. & REFRIG. (2)
- 5 CHD. WTR. COND. & REFRIG. (2)
- 6 EQUIPMENT TUNNEL TO TONKUS
- 7 ACCESS TO EL. 204.6
- 8 ACCESS TO EL. 202.0
- 9 ACCESS TO EL. 202.0
- 10 ACCESS TO EL. 202.0
- 11 ACCESS TO EL. 202.0
- 12 ACCESS TO EL. 202.0
- 13 ACCESS TO EL. 202.0
- 14 ACCESS TO EL. 202.0
- 15 ACCESS TO EL. 202.0
- 16 ACCESS TO EL. 202.0
- 17 ACCESS TO EL. 202.0
- 18 ACCESS TO EL. 202.0
- 19 ACCESS TO EL. 202.0
- 20 ACCESS TO EL. 202.0

# SYMBOLS

- EQUIPMENT
- EMERGENCY LIGHTING (EXT. T.)
- BATTERY PACK (NEW) (1)

FIGURE 5-5

SEE FRAME 5-9  
FOR ADDITIONAL BATTERY  
PACKS IN THIS AREA





POOR ORIGINAL

REACTOR BUILDING AREA  
JANIS A. H. J. J. J. J.  
REACTOR BUILDING AREA  
EL 272







# SYMBOLS

- - EQUIPMENT
- ⌘ - EMERGENCY LIGHTING (EXIST.)
- - BATTERY PACK (NEW) (3)

FIGURE 5-7

SEE FIGURE 5-2  
FOR ADDITIONAL BATTERY  
PACKS IN THIS AREA

|                                                    |
|----------------------------------------------------|
| POWER AUTHORITY OF THE STATE OF A. D. WORLD        |
| JAMES S. A. FETZPATRICK<br>MCCLELLAN POWER PLANT   |
| AREA PLAN<br>ADMINISTRATION BLDG<br>EL 284' & 286' |

FIGURE 5-7

POOR ORIGINAL

POOR ORIGINAL

FIGURE 5-8





FIGURE 5-8

POWER AUTHORITY OF THE STATE OF NEW YORK  
JAMES A. FITZPATRICK  
NUCLEAR POWER PLANT  
AREA PLAN  
ADMINISTRATION BLDG  
AUX BLDG  
EL 272'






# EQUIPMENT

- 1 ACCESS TUNNEL TO TORUS (2)
- 2 COOLING WATER PUMP (2)
- 3 COOLING COILS & THERMOSTATS (2)
- 4 CRD HTD COOLING COILS
- 5 CRD WATER PUMP (2)
- 6 EQUIPMENT TUNNEL TO TORUS
- 7 ACCESS TO EL 296.5'
- 8 ACCESS TO EL 292.0'
- 9 ACCESS TO EL 292.0'
- 10 CRD WATER PUMP (2)
- 11 CRD WATER PUMP (2)
- 12 PANEL MCC C132, C134
- 13 PANEL MCC C133
- 14 PANEL MCC C142, C143
- 15 PANEL MCC C143, C142
- 16 PANEL MCC C142
- 17 PANEL MCC C143
- 18 RECUM. PUMP (2)
- 19 RUSH 14.5 EXCHANGER (2)
- 20 STORAGE GAS THERMIST (2)
- 21 FASTEN 1-400 (2)

## SYMBOLS

- - EQUIPMENT
- - EMERGENCY LIGHTING (EXIST.)
- - BATTERY PACK (NEW) (5)



POOR ORIGINAL

FIGURE 5-9


SEE FIGURE 5-5  
FOR ADDITIONAL BATTERY  
PACKS IN THIS AREA

POWER DISTRIBUTION SYSTEM  
JAMES A. FILLPATRICK  
NATIONAL BUREAU OF STANDARDS


AREA PLAN  
REACTOR BLDG

EL. 272'


POOR ORIGINAL




PART PLAN  
EL 227'-6"



PART PLAN  
EL 227'-6"



PLAN  
EL 227'-6"



# EQUIPMENT

- 1 CORE SPRAY PUMP 10 P-2A, 20
- 2 CORE SPRAY HOLDING PUMP (2)
- 3 EQUIP DRAIN SUMP
- 4 EQUIP DRAIN SUMP COOLER (2)
- 5 FLOOR DRAIN SUMP (2)
- 6 GLAND PUMP CONDENSER
- 7 HPCI PUMP
- 8 HPCI TURBINE
- 9 HPCI TURBINE LUBE OIL C. OILER
- 10 PANEL BMCC-1
- 11 PANEL BMCC-2
- 12 PANEL BMCC-3
- 13 PANEL BMCC-4
- 14 PANEL MCC-21-C153
- 15 PANEL MCC-21-C153
- 16 RCIC PUMP
- 17 RCIC TURBINE
- 18 RHR PUMP 10 P-3A, 3B, 3C & 3D


# SYMBOLS

- - EQUIPMENT
- - EMERGENCY LIGHTING (EXIST.)
- - BATTERY PACK (NEW) (19)

FIGURE 5-10

POWER AND LIGHTING OF THE BLDG. OF NEW YORK  
JAMES A. FITZPATRICK  
AREA PLAN  
REACTOR BLDG.  
EL 227' & 242'

POOR ORIGINAL



EQUIPMENT

- 1 AIR COMPRESSORS(13)
- 2 AIR DRYERS(13)
- 3 AIR RECEIVERS(13)
- 4 BREATHING AIR ACC TANK
- 5 CARDOX UNIT, 10 TON
- 6 CLCW HEAT EXCHANGERS(3)
- 7 CLCW PUMPS(13)
- 8 CONDENSERS(12)
- 9 COND AIR REMOVAL PUMPS(12)
- 10 COND BOOSTER PUMPS(13)
- 11 COND SAMPLE PUMPS(12)
- 12 CONDENSATE PUMPS(13)
- 13 DEMINERALIZERS(16)
- 14 DRAIN COOLERS(12)
- 15 EQUIP DRAIN SUMP
- 16 FLOOR DRAIN SUMP(13)
- 17 HYD FLUID PWR UNIT
- 18 HYDROGEN SEAL OIL UNIT
- 19 OFF GAS SAMPLE EQUIP
- 20 PANEL, H, & STATOR H<sub>2</sub>O
- 21 PANEL, MCC 71C231 & 71C241
- 22 PANEL, MCC 71C431 & 71C441
- 23 H<sub>2</sub> FEED PUMPS(12)
- 24 H<sub>2</sub> FEED PUMP SEAL WATER COOLER
- 25 SERVICE WATER PUMP STR
- 26 STATOR WINDING LIQUID COOLING UNIT
- 27 SWGR, 600V, 71L23/24
- 28 SWGR, 600V, 71L43/44
- 29 TURBINE LUBE OIL TANKS(12)

SYMBOLS

- - EQUIPMENT
- ⌘ - EMERGENCY LIGHTING (EXIST.)
- - BATTERY PACK (NEW) (6)

FIGURE 5-11

POWER DIVISION OF THE STATE OF ALABAMA  
JAMES A. FITZPATRICK  
Nuclear Power Plant  
AREA PLAN  
TURB BLDG & HTR BAY  
EL 244' & 252'



- SYMBOLS

- - EQUIPMENT
- ✕ - EMERGENCY LIGHTING (EXIST.)
- - BATTERY PACK (NEW) (A)

FIGURE 5-12



Department of State of New York

JAMES A. FITZPATRICK

ARE A PLAN  
SCREENWELL

EL 255' & 260'

POOR ORIGINAL



# EQUIPMENT

- 1 CLEANUP PRECOAT PUMP
- 2 CLEANUP PRECOAT TANK
- 3 CLEANUP BLSH-FEED TANK
- 4 FAN121
- 5 FAN MOTOR121
- 6 FILTER121
- 7 FUEL POOL CLEAN UP
- 8 RECIRC PUMP121
- 9 FUEL POOL HEAT EXCH121
- 10 LIQUID POISON PUMP121
- 11 PANEL, MCC 71-C131
- 12 RWCU HOLDING PUMP121
- 13 REACTOR BLDG COOLING
- 14 WATER MAKEUP TANK
- 15 STANDBY LIQUID CONTROL TM
- 16 TEST TANK
- 17 SWGR, 600V 71 L13/14

# SYMBOLS

- - EQUIPMENT
- - EMERGENCY LIGHTING (EX. T.)
- - BATTERY PACK (NEW) (5)

FIGURE 5-13

FIGURE 5-13

POWER AUTHORITY OF THE STATE OF NEW YORK


JAMES A. FITZPATRICK  
NUTLEY, NEW JERSEY

AREA PLAN  
REACTOR BLDG

EL 326'

POOR ORIGINAL





# EQUIPMENT


- 1 AIR EJECTION
- 2 CO<sub>2</sub> UNIT
- 3 CONTROLLER (2)
- 4 CONTROLLER PANEL - 710PP
- 5 EXHAUST SWITCHBOARD
- 6 FLOOD DRAIN SAMPLE TANK (2)
- 7 FLOOD DRAIN SAMPLE TANK (2)
- 8 FLOOD UNIT
- 9 GEN. NEUT. TRANSF. AND RES.
- 10 GLAND STEAM EXHAUSTER
- 11 MOISTURE SEPARATION DRAIN IN (2)
- 12 PANEL MCC C201
- 13 PANEL MCC C252
- 14 PANEL MCC C261
- 15 PANEL MCC C262
- 16 PANEL MCC C331
- 17 PANEL MCC C341
- 18 PANEL MCC C434
- 19 PANEL MCC C444
- 20 HEATER
- 21 HPS MG SET (2)
- 22 H<sub>2</sub> FEED PUMP TURB. EXHAUST (2)
- 23 SWITCHGEAR, 600 V (4)
- 24 SWITCHGEAR, 4160 V (5)
- 25 TURBINE BY-PASS STEAM CHEST
- 26 TURBINE LUBE OIL TANK
- 27 UNINTERRUPTABLE MG SET-710PS-1
- 28 VACUUM PRIMING PUMP (2)
- 29 VACUUM TANK
- 30 WASTE SAMPLE TANK

FIGURE 5-14

POWER SUPPLY OF THE SIZE OF THE TANK

JAMES A. FITZPATRICK  
NUCLEAR ENGINEER

AREA PLAN  
TURB. BLDG. HTR. BAY  
ELEC. BAY  
EL 272'




## SYMBOLS

- - EQUIPMENT
- II - EMERGENCY LIGHTING (EXIST.)
- - BATTERY PACK (NEW) (14)

FIGURE 5-14

POOR ORIGINAL



| EQUIPMENT |                                | ZONE     |
|-----------|--------------------------------|----------|
| 1         | AIR RECEIVERS                  | B1,C1    |
| 2         | CONTROL PANEL (4)              | B2,C2,D2 |
| 3         | DAY TANK (4)                   | B1,C1,D1 |
| 4         | DUST COLLECTOR                 | C4       |
| 5         | EMERGENCY DIESEL GENERATOR (4) | B1,C1,D1 |
| 6         | FERRIC SULPHATE FEEDER         | C4       |
| 7         | FERRIC SULPHATE PUMP (2)       | C4       |
| 8         | HYDRATED LIME HOPPER           | C4       |
| 9         | LAKE SAMPLE TANK               | C4       |
| 10        | MIXED BED EXCHANGER            | C4       |
| 11        | PANEL MCC C334,C344            | B4       |
| 12        | SWITCHGEAR, 4160 V (2)         | B2,C2    |
| 13        | VACUUM DEAERATOR               | C5       |
| 14        | VACUUM PUMP                    | C4       |

#### SYMBOLS

- - EQUIPMENT
- ⌈ - EMERGENCY LIGHTING (EXIST.)
- - BATTERY PACK (NEW) (2)

FIGURE 5-15

|                                              |
|----------------------------------------------|
| POWER AUTHORITY OF THE STATE OF NEW YORK     |
| JAMES A. FITZPATRICK<br>NUCLEAR POWER PLANT  |
| AREA PLAN<br>SCREENWELL &<br>EMER. GEN. BLDG |
| EL 272'                                      |

FIGURE 5-15

POOR ORIGINAL