



HE COMMECTIONT FLIGHT AND POWER COMPANY HE IMARTICATE LICTIFIC LIGHT COMPANY SETTERE MASSACHUSETTS FLICOFT - COMPANY OLYOKE WATER FORMER COMPANY ORTOREST UTLIFIES EDITIONE COMPANY ORTOREST UTLIFIES EDITIONE COMPANY General Offices @ Selden Street, Berlin, Connecticut

P.O. BOX 270 HARTFORD, CONNECTICUT 06101 (203) 666-6911

June 26, 1981

Docket No. 50-336 A01379



Director of Nuclear Reactor Regulation Attn: Mr. Robert A. Clark, Chief Operating Reactors Branch #3 U. S. Nuclear Regulatory Commission Washington, D.C. 20555

Reference: (1) W. G. Counsil letter to D. G. Eisenhut dated December 31, 1980.

Gentlemen:

Millstone Nuclear Power Station, Unit No. 2 Auxiliary Feedwater Flow Indication

Item II.E.1.2 described in NUREG-0737 requires that safety grade auxiliary feedwater flow indication be provided at Millstone Unit No. 2 by July 1, 1981. In Reference (1), Northeast Nuclear Energy Company (NNECO) documented its intention to comply with the required in-service date in NUREG-0737 for Item II.E.1.2.

Due to an oversight on the part of the equipment vendor, NNECO will not receive control board mounting hardware for the auxiliary feedwater flow indicators in time to support the required in-service date of July 1, 1981. This is documented in the attached letter from the vendor to NNECO.

Upon receipt of the subject hardware, NNECO will expedite the installation of the auxiliary feedwater flow indicators. The revised in-service date for this system is conservatively estimated to be August 1, 1981. NNECO has determined that the slight deviation from the schedule provided for in NUREG-0737 for this system is acceptable as the automatic initiation of the auxiliary feedwater system at Millstone Unit No. 2 is operational and provides increased assurance that adequate feedwater will be available to remove decay heat. Current auxiliary feedwater flow indication, although not safety-grade, will provide adequate indication of auxiliary feedwater flow until the safety-grade system installation is complete.

8107010414

We trust you find this information satisfactory and concur in the revised in-service date for the auxiliary feedwater flow indicators.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

W. G. Counsil Senior Vice President

1

The Foxboro Company

Foxboro, MA 02035 U.S.A. (617) 543-8750

June 18, 1981

Northeast Nuclear Energy Co. P. O. Box 270 Hartford, Connecticut 06101

Attention: Bob McCarthy

Reference: P.O. No. 526665 Foxboro S.O. No. 80N-42911

Gentlemen:

Due to an oversight, we neglected to order the Model N-2AX+H096 Housing and the N-2AX+RB01 Retaining Bar which is necessary to mount the Model N-257 on your order. The material has now been ordered and will be shipped on July 1, 1981.

We regret any inconvenience this may cause.

Very truly yours,

THE FOXBORO COMPANY

oan Weir

Joan Weir Power Systems Engineering

cas

cc: Northeast Nuclear Energy Co. P. O. Box 128 Waterford, Connecticut 06385 Attn: Jeff Cataudella

