## TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER - DALLAS, TEXAS 75201

Log # TXX-3353 File # 903.11

June 20, 1981

Mr Spottswood Burwell Licensing Project Manager U. S. Nuclear Regulatory Commission Office of Nuclear Reactor Regulation Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION QUALIFICATION OF 18 INCH CONTAINMENT PURGE AND VENT VALVES

Dear Mr. Burwell:

The subject valves, valve actuators and associated equipment are qualified to operate (i.e. close) against 50 lb/in2 containment pressure. Further, the closing time, including lag time, is less than 5 seconds.

If you have any questions, please call.

cc: R. D. Calder

J. T. Merritt

R. E. Ballard

J. C. Kuykendall

R. A. Jones

Sincerely,