NRC FORM 366
(7-77)

U.S. NUCLEAR REGULATORY COMMISSION

# LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | N J S G S 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 1 1 (7) | 0 5 2 3 8 1 (8) | 0 6 2 2 8 1 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | Action Statement 3.4.5.b was entered at 1551 hours on May 23, 1981, when valve
0 3 | position indication could not be obtained when valve 2PR6 was repositioned. The
0 4 | valve was declared inoperable and power to the valve operator was removed.
0 5 |
0 6 |
0 7 |
0 8 | 80
7 8 9

0 9 | SYSTEM CODE C J (11) | CAUSE CODE E (12) | CAUSE SUBCODE B (13) | COMPONENT CODE V A L V E X (14) | COMP. SUBCODE E (15) | VALVE SUBCODE D (16)
7 8 9 10 11 12 13 18 19 20

(17) LER RO REPORT NUMBER | EVENT YEAR 8 1 | — | SEQUENTIAL REPORT NO. 0 2 7 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER L (25) | COMPONENT MANUFACTURER V 0 8 5 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Maintenance Department Work Order #MD947233 was issued to investigate and repair
1 1 | failed valve 2PR6. The motor operator limit switch was adjusted and 2PR6 was tested
1 2 | satisfactorily. Action Statement 3.4.5.b was terminated at 2305 hours on June 11, 1981.
1 3 |
1 4 | 80
7 8 9

1 5 | FACILITY STATUS E (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Personnel Observation
7 8 9 10 12 13 44 45 46 80

1 6 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A
7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES
1 7 | NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N/A
7 8 9 11 12 13 80

PERSONNEL INJURIES
1 8 | NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A
7 8 9 11 12 80

LOSS OF OR DAMAGE TO FACILITY (43)
1 9 | TYPE Z (42) | DESCRIPTION N/A
7 8 9 10 80

PUBLICITY
2 0 | ISSUED N (44) | DESCRIPTION (45) N/A | NRC USE ONLY
7 8 9 10 68 69 80

8107060274 810622
PDR ADOCK 05000311
S PDR

NAME OF PREPARER J. J. Espey PHONE: 609-935-0998

GPO 917-926