APPENDIX A

NOTICE OF VIOLATION

Duquesne Light Company Beaver Valley, Unit 2 Docket No.: 50-412 License No.: CPPR-105

As a result of the inspection conducted on May 5, 1981 through May 7, 1981, and in accordance with the Interim Enforcement Policy, $45 \, \text{FR} \, 66754$ (October 7, 1980), the following violation was identified:

10 CFR 50, Appendix B, Criterion XIII, states in part, "Measures shall be established to control the handling, storage. . . to prevent damage or deterioration."

The Beaver Valley Power Station, Unit 2, PSAR Section 17, paragraph 17.2.1.13A, also states, "The DLC QAP establishes measures to control the handling, storage, shipping, cleaning and preservation of material and equipment in accordance with work and inspection instructions to prevent damage or deterioration."

The Duquesne Light Procedure D.L.C. FCA-11, paragraph 8.6.3, states in part, "Material must be maintained as nearly as practical in its required storage level during transit" and S.I.C.P 13.2, Revision 2, Level D states, "Reasonably removed from actual construction area and traffic. . ."

Contrary to the above, on May 5, 1981, ASME Safety Related piping was temporarily stored in the cable vault area and on the ground outside the containment building without adequate protection from damage.

This is a Severity Level IV Violation (Supplement I.E.).

Pursuant to the provisions of 10 CFR 2.201, Duquesne Light Company is hereby required to submit to this office within twenty-five days of the date of this Notice, a written statement or explanation in reply including the corrective steps which have been taken and results achieved; corrective steps which will be taken to avoid further violations; and the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

Dated

JUN 1 5 1981

Eldon J. Brunner, Acting Director Division of Resident and

Project Inspection