JUN 1 8 1981

Docket Nos .: 50-369 and 50-370

> Mr. William O. Parker Vice President - Steam Production Duke Power Company P.O. Box 33189 Charlotte, North Carolina 28242

Dear Mr. Parker:

Subject: Staff Evaluation of Item 1.C.1 for Westinghouse Facilities (McGuire Nuclear Station, Units 1 and 2)

We have completed our interim review of the Westinghouse Owners Group submittal for Action Plan item I.C.1, Guidance for the Evaluation and Development of Procedures for Transients and Accidents. A copy of Mr. Eisenhut's May 28, 1981 letter to Mr. Jurgensen, Chairman, Westinghouse Owners Group is enclosed for your information. As indicated in the enclosure, further work will be necessary in order to produce a document which satisfies the staff positions in a timely matter.

Sincerely,

DISTRIBUTION DOCKET FILE

B#4 Rdg

DEisenhut

KJabbour EAdensam JLee SHanauer RTedesco RVollmer TMurley

RMattson

OELD OIE (3)

L/PDR

NRC/PDR

RHartfield, MPA

bcc: TERA/NSIC/TIC

ACRS (16)

Elinor G. Adensam, Acting Chief

Licensing Branch No. 4 Division of Lice sing

Enclosure: As stated

cc: See next page

8107070200 810618 DR ADDCK 05000

KJabbour:eb EAdensan RTedesco 6/16/81 V81 6/12/81 NRC FORM 318 (16/80) NRCM 9240

Mr. William O. Parker, Jr.
Vice President, Steam Production
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

cc: Mr. W. L. Porter
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Mr. R. S. Howard Power Systems Division Westinghouse Electric Corporation P. O. Box 355 Pittsburgh, Pennsylvania 15230

Mr. E. J. Keith
EDS Nuclear Incorportated
220 Montgomery Street
San Francisco, California 94104

Mr. J. E. Houghtaling NUS Corporation 2536 Countryside Boulevard Clearwater, Florida 33515

Mr. Jesse L. Riley, President The Carolina Environmental Study Group 854 Henley Place Charlotte, North Carolina 28207

J. Michael McGarry, III, Esq. Debevoise & Liberman 1200 Seventeenth Street, N. W. Washington, D. C. 20036

Ms. M. J. Graham Resident Inspector McGuire NPS c/o U. S. Nuclear Regulatory Commission Post Office Box 216 Cornelius, North Carolina 28031

Shelley Blum, Esq. 1402 Vickers Avenue Durham, North Carolina 27707 Robert M. Lazo, Administrative Judge Atomic Safety and Licensing Board U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Dr. Emmeth A. Luebke, Administrative Judge Atomic Safety and Licensing Board U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Dr. Richard F. Cole, Administrative Judge Atomic Safety and Licensing Board U. S. Nuclear Regulatory Commission Washington, D. C. 20555

## NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20055

MAY 2 8 1981

Robert W. Jurgensen, Chairman Westinghouse Owners Group American Electric Power Service Corporation 2 Broadway New York, New York 10004

Dear Mr. Jurgensen:

In your letter dated March 18, 1981 (06-54), you summarized a meeting held on February 20, 1981 between representatives of the NRC staff, Westinghouse Owners, and Westinghouse Electric Corporation. The purpose of the meeting was to discuss the Westinghouse Owners Group (WOG) activities in response to NUREG-0737, Clarification of TMI Action Plan Requirements, Item I.C.1, Guidance for the Evaluation and Development of Procedures for Transients and Accidents. Following the meeting summary, you requested that the staff acknowledge the acceptability of the program described in the meeting.

As indicated in a meeting with Tom Anderson, of Westinghouse, on April 8, 1981, we have concerns about the acceptability of the WOG program. The last submittal of generic WOG guidelines, including the Inadequate Core Cooling Guidelines, required the operator to diagnose a specific event using the diagnostic procedure included in the guidelines. Subsequent failures were, essentially, addressed by entry into one of the inadequate core cooling guidelines. As indicated in the february meeting and discussed in your letter, the guidelines do not provide smooth transitions from the event procedures to direct the operator if subsequent multiple or consequential failures occur. This leaves the operator with no guidance until entry conditions for the Inadequate Core Cooling Guidelines are reached. Furthermore, the guidelines do not address subsequent reevaluation of plant conditions to ensure that the expected plant response is occurring.

Our second concern is your proposed schedule for completing the program recognizing that development of emergency operating procedures is a dynamic process with no absolute end point. However, we are concerned that continual, major rewriting of emergency operating procedures is a burden on plant operating staffs and confusing to the operators who must relearn the procedures. In the February meeting, WOG representatives indicated thay they expect to have the initial development phase of the guidelines completed in July 1981, and would not expect major changes to the guidelines to result from the phases to be completed in January 1982 and Jul, 1982. You also state in your letter that the initial phase will address over 98 percent of the total risk. However, we were also told in the meeting that the guidelines to be submitted in July would probably not differ greatly from those already submitted. Considering our concerns with the existing guidelines, as addressed above, we do not see how the July submittal can be responsive to NUREG-0737, Item I.C.1 without significant change. We believe that additional work is necessary.

# 8106170284

The staff has not completed its review of WCAP 9691 or the probability estimates presented in the February meeting, and the Owners Group has not addressed the broad range of initiating events, including natural phenomena such as earthquakes, in the analysis presented to date. Therefore, we cannot assess the overall adequacy of the proposed program. Unless our concerns, as stated herein, are satisfied, the ability of licensees to meet the schedule for revising their procedures may be compromised.

As indicated in the April 8, 1981 meeting, we have serious doubts that the full range of initiating events and subsequent failures can be addressed within the event specific framework adopted by the Westinghouse Owners Group. If your additional work to date provides more insight into resolution of these concerns, we would be available to meet with you at your convenience.

By copy of this letter, each licensee and applicant of a Westinghousetype plant, is being advised of our evaluation of your submittal.

Sincerely,

Darrell G. (Eisenhut, Director Division of Licensing

cc: E. Murphy
W Licensees
W Applicants