

LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | I | L | Z | I | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 58

CON'T  
0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 9 | 5 | 7 | 0 | 5 | 2 | 9 | 8 | 1 | 8 | 0 | 6 | 2 | 6 | 8 | 1 | 9  
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 RPT JRT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During normal operation, when the miscellaneous vents rad monitor  
0 3 | ORT-PR18A, B was placed back in service, the rad/chem technician  
0 4 | (RCT) failed to install particulate + iodine filters. They were  
0 5 | found missing on 6/4/81. T.S.4.12.1 & 3.14.1.A were violated. Other  
0 6 | monitors for the rooms monitored by ORT-PR18 showed no abnormal read-  
0 7 | ings during the time in question. There were no safety implications  
0 8 | & the health & safety of the general public were not affected.  
7 8 9 80

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE  
M | C | 11 | A | 12 | D | 13 | Z | Z | Z | Z | Z | Z | 14 | Z | 15 | Z | 16  
9 10 11 12 13 18 19 20

(17) LER/RO REP'T NUM BER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.  
8 | 1 | 0 | 2 | 7 | 0 | 3 | L | 0  
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER  
H | 18 | Z | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | N | 23 | N | 24 | Z | 25 | Z | 9 | 9 | 9 | 26  
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The RCT stated that he simply forgot to install the filters. New  
1 1 | filters were installed on 6/4/81. The RCT was instructed to be more  
1 2 | aware in the future of requirements for placing rad monitors back  
1 3 | in service. No further action is deemed necessary.  
1 4 | \_\_\_\_\_  
7 8 9 80

1 5 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION  
E | 28 | 0 | 9 | 5 | 29 | NA | B | 31 | During RCT Surveillance  
7 8 9 10 12 13 44 45 46 80

1 6 | ACTIVITY CONTENT RELEASED OF RELEASE | AMOUNT OF ACTIVITY | LOCATION OF RELEASE  
Z | 33 | Z | 34 | NA | NA  
7 8 9 10 11 44 45 80

1 7 | PERSONNEL EXPOSURES NUMBER | TYPE | DESCRIPTION  
0 | 0 | 0 | 37 | Z | 38 | NA  
7 8 9 11 12 13 80

1 8 | PERSONNEL INJURIES NUMBER | DESCRIPTION  
0 | 0 | 0 | 40 | NA  
7 8 9 11 12 80

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE | DESCRIPTION  
Z | 42 | NA  
7 8 9 10 80

2 0 | PUBLICITY ISSUED DESCRIPTION  
N | 44 | NA  
7 8 9 10 80

NRC USE ONLY