



(LTR) Report No. 10-2 Rev. C

Date: December 3, 1980

RELEASED BY LOFT CDCS *sk*

Report No. RE-1-80-004

USMRC-P394

# NRC Research and Technical Assistance Report

## INTERNAL TECHNICAL REPORT

Title: HYBRID COMPUTER SIMULATION OF THE LOFT PLANT

Organization: Simulation and Controls Analysis Section  
Control Systems Design and Analysis Branch

# NRC Research and Technical Assistance Report

Author: F. K. Hyer/C. D. Clayton



Checked By: *J. W. Sielinsky*  
J. W. Sielinsky

Approved By: *G. R. Burdick*  
G. R. Burdick

Courtesy release to the public on request. This document was prepared primarily for internal use. Citation or quotation of this document or its contents is inappropriate.

THIS REVISION COMPLETELY SUPERSEDES ALL PREVIOUS ISSUES TO LTR 10-2

~~THIS DOCUMENT HAS NOT RECEIVED PATENT CLEARANCE AND IS NOT TO BE TRANSMITTED TO THE PUBLIC DOMAIN~~

8109020207 801203  
PDR RES  
8109020207 PDR

**LOFT TECHNICAL REPORT**

TITLE HYBRID COMPUTER SIMULATION OF THE LOFT PLANT		LTR No. 10-2-Rev.
Author F. K. Hyer, C. D. Clayton		Released By LOFT CDCS
Performing Organization Control Systems Design and Analysis Branch		Date December 3, 1980
LOFT Review and Approval <i>E.C. [Signature]</i> <i>[Signature]</i> <i>[Signature]</i>		Project System Engineer <i>[Signature]</i> 11/28/80
RSB Mgr.	PSB Mgr.	PCSB Mgr.

See incorporated DRR-L-4661

SUMMARY

A real-time hybrid computer simulation of the LOFT Facility has been developed to predict dynamic plant response to both normal and abnormal operating conditions. This report contains a detailed description of the analytical basis for the LOFT plant simulation. The current simulation contains the following plant components: reactor core, vessel, primary coolant loop, pressurizer, PPS, high pressure injection, steam generator, air-cooled condenser, condensate receiver, feedwater subcooler, steam generator water level control system and air-cooled condenser pressure control system.

DISPOSITION OF RECOMMENDATIONS

No disposition required.

**NRC Research and Technical  
 Assistance Report**

THIS REVISION COMPLETELY SUPERSEDES ALL PREVIOUS ISSUES OF LTR 10-2.

TABLE OF CONTENTS

SUMMARY.....	i
LIST OF FIGURES AND TABLES.....	iv
LIST OF APPENDICES.....	v
1.0 INTRODUCTION.....	1
1.1 Reactor Core Model.....	1
1.2 Primary Coolant Loop Model.....	1
1.3 Pressurizer Model.....	3
1.4 Plant Protection System Model.....	4
1.5 Steam Generator and Associated Controller Models..	4
1.6 Air-Cooled Condenser Simulation.....	4
1.7 Condensate Receiver Simulation.....	5
1.8 Feedwater System Model.....	5
1.9 Program Documentation.....	5
2.0 REACTOR CORE MODEL.....	7
2.1 Reactor Kinetics.....	7
2.2 Reactivity Calculations.....	9
2.3 Decay Heat Generation.....	12
2.4 Core Thermal Model.....	13
3.0 PRIMARY COOLANT LOOP SIMULATION.....	17
3.1 Primary Coolant Flow.....	17
3.2 Primary Coolant Density.....	24
3.3 Primary Coolant Heat Transfer.....	24
3.4 Primary Coolant Temperature.....	25
3.5 Primary Coolant Piping Wall Temperature.....	26
3.6 Primary Coolant Makeup and Drain.....	26
3.7 Primary Coolant Boron Concentration.....	27
4.0 PRESSURIZER MODEL.....	29
4.1 Pressurizer Pressure and Level.....	29
4.2 Surge Flow.....	31
4.3 Spray.....	32
4.4 Pressurizer Heaters.....	33
4.5 Relief Valves.....	34
4.6 Pressurizer Ambient Losses.....	34
4.7 Pressurizer Boil-Off and Condensation.....	34
5.0 PLANT PROTECTION SYSTEM.....	36
5.1 Time Constants.....	36
5.2 Time Delays.....	36
5.3 ECCS.....	37

TABLE OF CONTENTS

6.0	STEAM GENERATOR AND ASSOCIATED CONTROLLERS.....	39
6.1	Steam Generator Secondary Side.....	39
6.2	Main Steam Control Valve.....	46
6.3	Steam Generator Water Level Controller.....	47
7.0	AIR-COOLED CONDENSER.....	50
7.1	Air-Cooled Condenser Air Flow.....	50
7.2	Air-Cooled Condenser Heat Transfer.....	54
8.0	CONDENSATE RECEIVER MODEL.....	58
8.1	Condensate Receiver Mass Transport.....	58
8.2	Condensate Receiver Mass and Energy Balances.....	59
8.3	Condensate Receiver Pressure.....	61
9.0	FEEDWATER SYSTEM.....	65
9.1	Subcooler.....	65
9.2	Feedwater Piping.....	66
9.3	Feed Flow.....	66
10.0	PROGRAM OPERATION AND CONTROL.....	69
10.1	Analog Initialization.....	69
10.2	Program Execution.....	69
10.3	Digital Program Initialization.....	69
10.4	Main Operating Program.....	70
	REFERENCES.....	77
	APPENDICES	

NRC Research and Technical  
 Assistance Report

FIGURES AND TABLES

1-1	LOFT Reactor Plant Schematic Diagram.....	2
1-2	Data File Formats.....	6
2-1	Reactor Kinetics Parameters.....	9
2-2	Control Rod Height Versus Time After Scram.....	11
2-3	Decay Heat Power.....	13
2-4	Core Thermal Coefficients.....	15
2-5	Core Heat Transfer Coefficients.....	16
3-1	Primary Loop Model.....	18
3-2	Primary Coolant Flow Relationships.....	19
3-3	Flow Constants.....	22
3-4	Natural Circulation Node Heights.....	23
3-5	Primary Coolant Parameter Summary.....	28
5-1	PPS Simulation.....	38
6-1	Steam Generator.....	40
6-2	Pressure Versus Volume and Enthalpy.....	45
6-3	Main Steam Valve $C_v$ Versus Stem Position.....	48
6-4	Steam Generator Water Level Control Schematic.....	49
7-1	Air-Cooled Condenser Fan Blade Positioner.....	52
7-2	Air Flow Versus Fan Pitch Angle.....	53
8-1	Specific Volume Versus Enthalpy - Subcooled Water.....	62
8-2	$dv/dh$ - Saturated Water.....	63
8-3	Specific Volume Versus Enthalpy - Superheated Steam.....	64
9-1	Feed Valve $C_v$ .....	68
10-1	PLAN14 Operating Commands.....	71
10-2	MAIN14 Block Diagram.....	76

## NRC Research and Technical Assistance Report

APPENDICES

- A. PCS Flow Calculations
- B. PCS Density Approximation
- C. Primary Coolant Node Descriptions
- D. Thermal Dynamic Properties Used in the Pressurizer Model
- E. Steam Generator Volume Versus Level Calculations
- F. Analysis of Steam Generator Shrink Data Recorded During Power Range Scrams
- G. Computer Program Used to Generate the Pressure Versus Volume and Enthalpy Table
- H. Analog Wiring Schematics
- I. Condensate Velocity in the Air-Cooled Condenser Tubes
- J. Feedwater System Calculations
- K. Analog/Digital Interface
- L. PLAN14 Digital Program Listing
- M. Input Array
- N. Recursive Solution for PCS Steady State Temperatures
- O. Output Parameters

NRC Research and Technical  
Assistance Report

## 1.0 INTRODUCTION

A hybrid computer simulation of the LOFT plant has been developed to analyze dynamic plant performance under both normal and abnormal operating conditions. The present simulation includes the major components of the primary system, secondary system and their associated control systems. Figure 1-1 is a schematic of the current simulation.

### 1.1 Reactor Core Model


The reactor core model simulates the heat generated within the boundaries of the core and the associated heat transfer from the fuel to the clad surface. Provisions are made for a percentage of the heat to be deposited directly into the coolant. No direct structural heating is simulated.

The power generated within the core is made up of neutron power and fission product decay power. The neutron power production is calculated using the standard point neutron kinetics equations with six delay groups. The reactivity effects of the moderator density, fuel doppler, boron concentration, and rod bank position are computed. The power generated by decay heat as a function of time is an input to the reactor core model.

The core heat transfer is modeled with a single fuel node and a single clad node separated by a variable width gas gap to obtain the basic transitory distribution of heat in the core material. The conductivity of fuel, gap, and clad are combined and used to calculate the heat transfer from the fuel to the clad. The heat transfer from the clad to the water flowing through the core is calculated by the loop flow model using the Dittus-Boelter forced-convection heat transfer correlation.

### 1.2 Primary Coolant Loop Model

The loop model performs the following functions:



INEL-A-2781-1

FIGURE 1-1  
LOFT REACTOR PLANT SCHEMATIC DIAGRAM

1. Transportation of water around the primary loop at the flow rate specified.
2. Computation of heat transfer to and from the primary water and computation of the corresponding change in water temperature.
3. Computation of the primary system surge rates based on the average water density change as well as computation of the enthalpy of the pressurizer insurge and spray.

Fifty-one control volumes are used in the loop flow model to simulate the actual primary system volume. The transportation of water around the loop is accomplished by moving a slug of water from one control volume, then mixing it with the next downstream volume. The size of the water slug moved is proportional to the system flow rate.

The heat transferred from clad surface to coolant and from primary coolant to the steam generator secondary is computed by the loop flow model. Also, the heat transferred to or from the pipe and plenum walls is computed. The exterior surface of these walls is assumed to be perfectly insulated. Turbulent convective heat transfer is assumed. The heat transfer coefficient is computed as a function of primary coolant flow rate.

The surge flow to and from the pressurizer is obtained by computing the density change of the water contained in the primary system. The enthalpy of the pressurizer surge and spray is computed as a function of the water temperature at the appropriate locations in the loop.

### 1.3 Pressurizer Model

The pressurizer model simulates the pressurizing system of the primary loop. Simulation of the pressurizer is based on a computation of the thermodynamic conditions within the pressurizer. The steam can be either saturated or superheated. The water can be either saturated or subcooled.

The pressurizer control systems include the spray, the heaters, the power-operated relief valve, and the code relief valves. The response times of these systems is assumed to be negligible compared to the pressure rate of change.

#### 1.4 Plant Protection System Model

The reactor plant protection system model compares power, temperature, flow and pressure measurements against corresponding scram setpoint values and initiates protective action if a setpoint is exceeded. The model of the PPS includes the time response of the associated instrumentation. By associating a time constant with a particular protective system, the model is capable of computing an "indicated" parameter value (as opposed to the actual value of this parameter). The indicated value is then used to actuate the PPS, thereby simulating actual plant operation.

#### 1.5 Steam Generator and Associated Controller Models

The steam generator model simulates the secondary side of the steam generator. Energy, mass, and volume balances are computed to satisfy the saturation conditions assumed to exist in the homogeneous steam and water mixture inside the shroud. The subcooled condition of the water in the downcomer is also taken into account.


The water level control system which regulates the feedwater flow is simulated. This controller has steam flow, feedwater valve position and steam generator level as the controller inputs.

The steam flow control valve is simulated as a manually controlled valve except under certain conditions. The steam valve is automatically closed if the pressure is below a low-pressure setpoint in coincidence with a reactor trip. The steam valve is automatically opened if the pressure is above a high-pressure setpoint. Control system logic can be disabled to allow analysis of system response in the event of control logic or equipment failure.

#### 1.6 Air-Cooled Condenser Simulation

The air-cooled condenser simulation includes the fluid flow and heat transfer processes occurring in the three air-cooled condenser bays. The water in the air-cooled condenser tubes is assumed to be saturated. The heat transfer is based on an empirical heat transfer correlation. A mass

PDP TAPE  
A B C D E F G H I J K L M N O P Q R S T U V W X Y Z



RAD 50 format. First 3 words contain file name and type (e.g. FILENMDAT).

512 bytes of ASCII format. (1-72) Title, (452-455) Number of samples.


64-8 byte ASCII words in each record. Heading and subheading for 128 data channels (e.g., 'PCS PRES', 'PSIA').

128 floating point, 4 byte, numbers in each record. Each record contains 128 data channels corresponding to one time frame.

Same format as data records.

33 integer, 2 byte, words.

CDC TAPE  
FILE



First word - file name and type. Second word - number of samples +3. Next 8 words - title.

256 ASCII words. Same order as on PDP tape.

52 ASCII words. Same format as on PDP tape.

Copied in floating point format from PDP tape record for record.

50 integer words

FIGURE 1-2  
DATA FILE FORMATS

balance is performed to determine the condensate in the tubes. A heat balance is performed between the air-side and the condensate side of the tubes. The air-side heat transfer coefficient is a function of the airflow across the finned tubes. Fan blade angle is used to determine the airflow. The fan blade pitch is adjusted to control condensate receiver pressure.

### 1.7 Condensate Receiver Simulation

The mass in the condensate receiver is separated into two phases, the liquid phase which can be subcooled or saturated and the gas phase which is either superheated or saturated. Separate mass and energy balances are computed for each phase. The pressure difference between the air-cooled condenser and condensate receiver is neglected.

### 1.8 Feedwater System Model

The feedwater system is divided into two nodes. The first node includes water from the condensate receiver to the subcooler outlet. The subcooler heat transfer coefficient is selected such that 10<sup>0</sup>F subcooling is achieved during normal full power operations. The second node includes the feedwater pump, control valve and piping to return the water to the steam generator downcomer.

### 1.9 Program Documentation

A complete set of the analog wiring diagrams are included in Appendix H. Appendix K is a table of the Analog/Digital Interface and Appendix L contains a complete listing of the digital program used for the simulation. Appendix M lists all the parameters in the input array with their nominal values. Data generated by the simulation consists of the 128 data channels listed in Appendix O. The data is stored on PDP-11 disk or tape and can be converted to a CDC 7600 tape file for further use by the customer. Both these file structures are shown in Figure 1-2.

## 2.0 REACTOR CORE MODEL

The reactor core model simulates power generated by the reactor and is subdivided into four separate categories:

1. Reactor kinetics
2. Reactivity calculations
3. Decay heat generation
4. Core thermal model

The dynamic and steady-state behavior of the LOFT core is modeled using the point neutron kinetics equations with reactivity feedback from fuel temperature, moderator density, boron concentration, and control rod assembly position. Decay heat generation following reactor scram is included in the simulation.

### 2.1 Reactor Kinetics

Equations:

$$\frac{dP}{dt} = \frac{(\rho - \beta)}{\lambda} P + \sum_{i=1}^6 \lambda_i C_i \quad (2-1)$$

$$\frac{dC_i}{dt} = \frac{\beta_i}{\lambda} P - \lambda_i C_i; \quad i = 1, 2, \dots, 6 \quad (2-2)$$

Where:

- t = Time (seconds)
- P = Reactor power
- C<sub>i</sub> = Concentration of the i-th group of delayed neutrons
- β = Effective fraction of delayed neutrons
- β<sub>i</sub> = Delayed fraction of the i-th group of neutrons
- ρ = Reactivity
- λ<sub>i</sub> = Decay constant for the i-th neutron group (sec<sup>-1</sup>)
- λ = Prompt neutron generation time (seconds)

Let

$$f_i = \frac{\beta_i}{\beta}, \quad r = \frac{\rho}{\beta}, \quad \psi_i = \frac{\lambda}{\beta} C_i$$

Then equations 2-1 and 2-2 are expressed as:

$$\frac{dP}{dt} = (\beta/\lambda) \left\{ (r-1) P + \sum_1^6 \lambda_i \psi_i \right\} \quad (2-3)$$

$$\frac{d\psi_i}{dt} = f_i P - \lambda_i \psi_i; \quad i = 1, 2, \dots, 6 \quad (2-4)$$

The analog circuitry shown in Appendix H, Figure H-1, is used to solve equations 2-3 and 2-4. Reactivity, in dollars, is transmitted to the analog console by two digital/analog channels to maintain adequate resolution during steady-state and transient conditions. The values of the parameters used in the kinetics circuitry are listed in Table 2-1.

The circuit is initialized by the initialization subroutine (INIT), which sets  $\psi_i$  equal to  $(f_i/\lambda_i)P$  for each delayed neutron group. Hand-set potentiometer P149 is provided to balance out small accumulated errors. The circuit integrators are held at the initial condition values until logic switch 011 is returned to its mid position.

For simulations where no change in reactor power is desired, potentiometer P140 and switch 051 are provided to supply a constant power signal to the core thermal circuitry.

The down position of logic switch 011 is used to reset amplifier 053 if an overload condition should arise during initialization.

Table 2-1

Reactor Kinetics Parameters

Neutron Generation Time	$\lambda$	$21.9 \times 10^{-6}$ sec. (note 1)
Delayed Neutron Fraction	$\beta$	.007259 (reference 1)
<u>Delayed Neutron Group</u>	<u>Fraction <math>\beta_i/\beta</math> (reference 2)</u>	<u>Decay Constant <math>\lambda_i</math> (sec<sup>-1</sup>) (reference 2)</u>
1	.038	.0127
2	.213	.0317
3	.188	.115
4	.407	.311
5	.128	1.40
6	.026	3.87

Note 1. The value for  $\lambda$  given in Reference 1 is  $19.52 \times 10^{-6}$ . The value listed in this table is given because the hybrid simulation uses a .03  $\mu$ f capacitor to simulate  $\lambda/\beta \times 10$ .

2.2 Reactivity Calculations

The simulation computes the total reactivity in dollars as a sum of the following:

## 2.2.1 Moderator Reactivity

$$\rho_m = \alpha_t \cdot \left( \begin{array}{l} \text{average density} \\ \text{of core water} \\ \text{(nodes 1-4)} \end{array} \right)$$

$\alpha_t$  is specified in the input array in units of  $\$/(\text{lbm}/\text{ft}^3)$

## 2.2.2 Doppler Reactivity

$$\rho_f = \alpha_f \cdot \left( \begin{array}{c} \text{fuel} \\ \text{temperature} \end{array} \right)$$

$\alpha_f$  is specified in the input array in units of  $\$/^\circ\text{F}$ .

## 2.2.3 Boron Reactivity

$$\rho_B = \alpha_B \cdot \left( \begin{array}{c} \text{Average core} \\ \text{boron concentration} \\ \text{(nodes 1-4)} \end{array} \right)$$

$\alpha_B$  is specified in the input array in units of  $\$/\text{ppm}$ .

2.2.4 Control Rod Reactivity

Control rods in the LOFT plant simulation are modeled as an integral worth rod bank. Three methods of rod motion are provided:

2.2.4.1 Control rod shims can be made from the analog control panel. Reactivity is added or subtracted at a rate of  $.01\$/\text{sec}$ . No change is made to the rod height.

2.2.4.2 A control rod ramp can be simulated by specifying the total change of reactivity and the total time interval for this reactivity change as input parameters. The ramp is automatically stopped when rod motion caused by a reactor scram is initiated. The indicated rod height remains constant until the scram occurs so that the scram is always initiated from 54 inches.

2.2.4.3 Reactor scrams are simulated by a subroutine which performs a table look up of control rod position and reactivity versus time. Reactivity versus time is specified in the input array. Indicated control rod height versus time after scram is given in Table 2-2. This table is based on calculated rod drop times not plant data.

Table 2-2Control Rod Height Versus Time After Scram

<u>Time (seconds)</u>	<u>CRDM Position (inches)</u>
0.000	54.0
0.075	53.9
0.160	52.8
0.245	51.4
0.331	49.5
0.417	47.2
0.503	43.6
0.589	39.3
0.672	34.6
0.753	29.2
0.830	23.7
0.905	19.7
0.977	16.2
1.050	13.5
1.127	11.1
1.211	9.0
1.265	8.0
1.336	7.0
1.403	5.9
1.514	4.1
1.590	3.0
1.910	0.0

### 2.3 Decay Heat Generation

The simulation uses the simplified method given in section 3.6 of Reference 3 for determining an upper bound on the decay heat fraction. The model assumes an infinite constant power history and neglects the effect of fission product neutron capture.

Equation:

$$P_d(t)/P_{\max} = 1.02 F(t, \infty)/Q \quad (2-5)$$

Where:

$P_d(t)$  = Total decay heat power at time  $t$  seconds after shutdown.

$P_{\max}$  = Initial steady state power.

$F(t, \infty)$  = Decay heat per fission  $t$  seconds after shutdown. These values are given in Table 4 of Reference 3.

$Q$  = Total recoverable energy associated with one fission of  $U^{235}$ . Equals 199.9 MeV (Reference 4).

Table 2-3 lists the values of  $P_d/P_{\max}$  which are used by the simulation. Decay heat values are obtained by interpolating the logarithm of the time after shutdown into this table. Total reactor power is found by summing the neutron power and decay heat power. (See Appendix H, Figure H-1.)

Table 2-3

Decay Heat Power

<u>Time</u> <u>(seconds)</u>	<u>log (t)</u>	<u>F(t,∞)</u>	<u>P<sub>d</sub>/P<sub>max</sub></u>
.1	-1	13.18*	.06725
1	0	12.31	.06281
10	1	9.494	.04844
100	2	6.198	.03163
1000	3	3.796	.01937

\*Calculated using Reference 3, Table 7, for t = 0.

$$F(0, \infty) = \sum_{i=1}^{23} \alpha_i / \lambda_i$$

2.4 Core Thermal Model

The transfer of energy between the fuel and the cladding is modeled by the following equations which assume a uniform distribution of power and temperature and constant heat capacities.

$$(MC_p)_f \frac{dT_f}{dt} = f \cdot P - K_{fc} (T_f - T_c) \quad (2-6)$$

$$(MC_p)_c \frac{dT_c}{dt} = K_{fc} (T_f - T_c) - \dot{Q}_{cp} \quad (2-7)$$

Where:

- $T_f$  = average fuel temperature ( $^{\circ}F$ )
- $T_c$  = average cladding temperature ( $^{\circ}F$ )
- $P$  = Total reactor power (Btu/sec)
- $f$  = Fraction of the power generated in the fuel

$(MC_p)_f$  = Heat capacity of the fuel (BTU/°F)

$K_{fc}$  = Overall fuel to cladding heat transfer coefficient (Btu/sec-°F)

$\dot{Q}_{cp}$  = Heat transferred from the cladding to the primary coolant (Btu/sec)

$(MC_p)_c$  = Heat capacity of the cladding (Btu/°F)

The overall heat transfer coefficient,  $K_{fc}$ , is a combination of the conductance of the fuel, gap and clad.

$$\frac{1}{K_{fc}} = \frac{1}{K_f(T_f)} + \frac{1}{K_{gap}(T_f, T_c)} + \frac{1}{K_c(T_c)} \quad (2-8)$$

The value of  $K_{fc}(T_f, T_c)$  is approximated by the following family of straight lines:

$$K_{fc} = K_0(T_f) + S_1(T_f) * T_c \quad (2-9)$$

Tables 2-4 and 2-5 list the values of the coefficients used by the simulation model. These coefficients are based on values obtained from Reference 14. Appendix H, Figure H-2, shows the analog circuitry used to solve equations 2-6 and 2-7.

Table 2-4

Core Thermal Coefficients

<u>Parameter</u>	<u>Source</u>	<u>Value</u>	<u>Reference</u>
f	$1 - \left( \frac{\text{core direct heat}}{.0187} \right) - \left( \frac{\text{core bypass direct heat}}{.0303} \right) =$	.9510	16 (Table III)
M <sub>f</sub>	(2.505 lbm/rod) x (1300 rods) =	3256.6 lbm	5 (page II-2-27)
M <sub>c</sub>	(0.514 lbm/rod) x (1300 rods) x $\frac{66'' \text{ active length}}{69.1875 \text{ clad length}}$	637.4 lbm	6 (Table V)
(C <sub>p</sub> ) <sub>f</sub>	Representative value for fuel temperatures between 800 <sup>0</sup> F and 1600 <sup>0</sup> F	.07646 Btu/ lbm <sup>0</sup> F	6 (Figure 75)
(C <sub>p</sub> ) <sub>c</sub>	Representative for clad wall temperatures less than 1500 <sup>0</sup> F	.07671 Btu/ lbm <sup>0</sup> F	6 (Table V)

15

Table 2-5Core Heat Transfer Coefficients

$$K_{fc} = K_o(T_f) + S_1(T_f) * T_c$$

<u>T<sub>f</sub>(°F)</u>	<u>K<sub>o</sub></u>	<u>S<sub>1</sub></u>
450	50.510	.007525
750	52.171	.005607
1050	53.097	.004100
1350	53.707	.002879
1650	54.339	.001782
1950	55.286	.000732
2250	56.869	-.000429
2550	59.474	-.001889

### 3.0 PRIMARY COOLANT LOOP SIMULATION


The loop flow model simulates the heat transfer process in a single closed loop. A block diagram of the primary loop model and its interconnections with the other plant systems is shown in Figure 3-1. Primary coolant values of temperature, pressure, and flow are updated once each time step.

#### 3.1 Primary Coolant Flow

Primary coolant flow is calculated in units of cubic feet per second. It is a combination of forced flow from the primary coolant pumps and natural circulation. The initial total flow value is specified in the input array in units of lbm/hr. The flows in various regions of the primary system are related as shown in Table 3-2.

For simulating loss of flow accidents, such as pump coastdowns and reflood assist bypass valve openings, a forced flow versus time curve is entered in the input array. These flow curves are obtained from the SICLOPS program (Reference 8) and from actual plant data. The time function of forced flow can be activated automatically at the start of the transient or it can be controlled manually using logic switch 010.

3.1.1 Natural circulation is calculated using the following model:






FIGURE 3-1  
PRIMARY LOOP MODEL

TABLE 3-2

PRIMARY COOLANT FLOW RELATIONSHIPS

<u>Location</u>	<u>Nodes</u>	<u>Value</u>
Core	1-4, 15, 16	95% of vessel forced flow plus core natural circulation flow
Core bypass	51	5% of vessel forced flow plus bypass natural circulation flow
Vessel	39-46	Variable forced flow plus core and bypass natural circulation flows
Loop	5-14, 17, 19-38	Sum of vessel and reflood flows
Upper plenum bypass	18	20% of vessel forced flow
Reflood assist bypass	47-50	Variable with time

where:

- W = flow rate (cu ft/sec)
- R = flow resistance
- H = gravity head (psid)

and subscripts

- C = core
- BP = core bypass
- L = loop

During normal operation the forced flow is much greater than the natural circulation flow. Under these conditions the natural circulation is added to the forced flow using a perturbation technique. That is:

$$W_{\text{TOTAL}} = W_{\text{FORCE}} + W_{\text{NC}}; W_{\text{NC}} = \frac{dW}{dH} H \quad (3-1)$$

From the head-flow relationship,  $H = kW^2$ ,

$$\frac{dW}{dH} = \frac{1}{2kW} \quad (3-2)$$

k is the flow resistance constant calculated in Appendix A.2 and given in Table 3-3.

W is approximated as follows:

$$W = W_0 F(t) \quad (3-3)$$

$W_0$  = nominal flow rate given in Table 3-3

$F(t)$  = forced flow fraction, normalized to the initial value of the forced component of flow

By combining equations 3-1, 3-2, and 3-3, the natural circulation contribution to the flow is:

$$W_{NC} = \frac{1}{R} H \quad (3-4)$$

$$R = 2kW_0 F(t) \quad (3-5)$$

When forced flow is reduced such that the perturbation method is no longer applicable, natural circulation flow is assumed to be a linear function of the gravity head. The total flow is formed as the sum of the forced and natural circulation flow components.

$$W_{NC} = \frac{1}{R_0} H \quad (3-6)$$

$$R_0 = 2kW_0 f_0 \quad (3-7)$$

The value of  $k$  is the same as was used in equation 3-5. The  $f_0$  factor is specified in the input array. In order to maintain continuity during a loss of flow transient, the transition between the perturbation method and the linear head loss method is made when  $F(t) = f_0$ .

The solution of the flow network given above is obtained by using either equation 3-4 or 3-6 to determine the head loss terms.

$$H_L - H_C - W_C R_C - W_L R_L = 0 \quad (3-8)$$

$$H_{BP} - H_C - W_C R_C + W_{BP} R_{BP} = 0 \quad (3-9)$$

$$W_L = W_C + W_{BP} \quad (3-10)$$


The simultaneous solution of these equations for  $W_C$ ,  $W_L$  and  $W_{BP}$  is given in Appendix A.

Natural circulation gravity heads are computed by summing the products of the density and the heights of each vertical node in each flow loop. The node heights are shown in Figure 3-4 and listed in Table 3-5.

TABLE 3-3

FLOW CONSTANTS

<u>Symbol</u>	<u>Parameter</u>	<u>Value</u>
$k_C$	Core flow resistance	.05483 psi/(ft <sup>3</sup> /sec) <sup>2</sup>
$k_{BP}$	Core bypass flow resistance	19.7935 psi/(ft <sup>3</sup> /sec) <sup>2</sup>
$k_L$	Primary loop flow resistance	.08852 psi/(ft <sup>3</sup> /sec) <sup>2</sup>
$W_0$	Nominal flow rate	
	Core	19 ft <sup>3</sup> /sec
	Core bypass	1 ft <sup>3</sup> /sec
	Primary loop	20 ft <sup>3</sup> /sec



INEL-A-13 947-1

FIGURE 3-4

NATURAL CIRCULATION NODE HEIGHTS

### 3.2 Primary Coolant Density

The density in each node is computed with the following empirical equation:

$$\rho = 41.58 + .0890337 T - 1.44741 \times 10^{-4} T^2 + (P - 2200)(.00025 + 3.89 \times 10^{-7} \exp(.01287 T_{ave})) \quad (3-11)$$

Where T is the node temperature in  $^{\circ}\text{F}$ ,  $T_{ave}$  is the average temperature of nodes 25 and 26, and P is loop pressure in psia.

See Appendix B for a derivation of this equation. The operating range for this approximation is 400 to 650 $^{\circ}\text{F}$ , and 1400 to 3000 psia.

### 3.3 Primary Coolant Heat Transfer

The heat transfer model assumes forced convection, with turbulent flow and subcooled water. The heat transferred into each node is determined by the following equation:

$$\dot{Q} = UA (T_{WALL} - T_{NODE}) + \dot{Q}_{DIR} \quad (3-12)$$

The overall heat transfer coefficient, UA, is formed by combining the heat transfer coefficient of the film,  $h_{DB}$ , and the conductivity of the wall surface, K, as given in the following equation:

$$\frac{1}{UA} = \frac{1}{K} + \frac{1}{H_{DB}}; \quad H_{DB} = h_{DB}A \quad (3-13)$$

$H_{DB}$  is the Dittus-Boelter film coefficient which is dependent on the fluid velocity as follows:

$$H_{DB} = H_{ref} \left( \frac{\dot{V}}{\dot{V}_{ref}} \right)^{.8} \quad (\text{Reference 7, Section 6.114}) \quad (3-14)$$

$$\dot{V}_{ref} = 30.764 \text{ ft}^3/\text{sec}$$

The values of  $H_{ref}$  and  $K$  for each node are listed in Table 3-5.

In the reactor core,  $T_{WALL}$  is the cladding temperature which is calculated in the analog core thermal model.

For the steam generator nodes,  $T_{WALL}$  is the secondary saturation temperature and the thermal conductivity,  $k$ , includes a boiling heat transfer coefficient for the secondary side of the tubes. The effect of tube dry-out is modeled by reducing the overall heat transfer coefficient when the steam quality surrounding the tubes is less than  $X_{DNB}$  according to the following equation:

$$UA' = \dots \quad (3-15)$$

$X_{DNB}$  is specified in the input array. The dryout factor,  $f$ , is discussed in section 6.1.6.

$\dot{Q}_{DIR}$  is the heat deposited by radiation directly into the core and core bypass nodes. See Table 2-4 for the fraction of reactor power that is included in  $\dot{Q}_{DIR}$ .

### 3.4 Primary Coolant Temperature

Primary coolant temperatures are updated using the following equations:

$$T_{NEW} = T_{OLD} + \dot{Q} \Delta t / mc_p \quad (3-16)$$

$$T_{NODE} = T_{NEW} + \frac{\dot{V} \Delta t}{V} (T_{IN} - T_{NEW}) \quad (3-17)$$

$T_{NEW}$  = node temperature resulting from heat transfer

$T_{OLD}$  = node temperature from previous time step

$\dot{Q} \Delta t$  = total heat transferred into the node during the step.  $\dot{Q}$  for the core and core bypass nodes includes direct heat.

- $mc_p$  = heat capacity of fluid and structure (see Table 3-5)  
 $T_{NODE}$  = updated node temperature resulting from the ideal mixing of  $T_{NEW}$  and  $T_{IN}$   
 $\dot{V}$  = fluid volumetric flow in the node ( $ft^3/sec$ )  
 $\Delta t$  = time step duration specified in the input array  
 $V$  = node volume (see Table 3-5)  
 $T_{IN}$  =  $T_{NEW}$  of the upstream node as shown in Figure 3-1. Reverse flow is only modeled for the core bypass node (51).

### 3.5 Primary Coolant Piping Wall Temperature

The wall temperature of each node, except the core and steam generator nodes, is updated as follows:

$$T_{WALL} = T'_{WALL} - \dot{Q}\Delta t/mc_p \quad (3-18)$$

$T'_{WALL}$  = wall temperature during the previous time step

$\dot{Q}\Delta t$  = total heat transferred into the node during the time step

$mc_p$  = heat capacity of the wall (see Table 3-5)

### 3.6 Primary Coolant Makeup and Drain

Injection and let down from the primary coolant system is controlled from the analog console. When Logic Switch 110 is UP injection occurs. When Logic Switch 111 is UP primary coolant is drained from the loop. Injection and drain rates are specified in the input array in gpm. The program assumes a density of  $62.38 \text{ lbm}/ft^3$  ( $60^\circ F$ ) for both drain and makeup. This allows a feed and bleed with no net mass change to be simulated by specifying the same gpm value for both rates.

Injection flow is added to node 27 which simulates injection via the purification system. A temperature difference of  $100^\circ F$  is used to update the node temperature.

### 3.7 Primary Coolant Boron Concentration

Primary coolant boron concentration in each node is maintained using the following ideal mixing equation:

$$C = C_{OLD} + \frac{\dot{V}\Delta t}{V} (C_{IN} - C_{OLD}) \quad (3-19)$$

$C_{OLD}$  = Boron concentration during previous time step

$\dot{V}\Delta t$  = total volume of fluid entering node during the time step

$C_{IN}$  = boron concentration of fluid entering the node

In addition to boron mixing with upstream nodes, mixing due to injection flow and pressurizer surge flow is also included. Reverse flow in the core bypass node (51) is accounted for.

The initial loop and pressurizer boron concentrations are specified in the input array. Pressurizer boron concentration can be set equal to the loop concentration (node 21) by selecting DAP switch 10 to the ON position.

The boron concentration of the injection flow is controlled by DAP switch 2. In the OFF position the injection concentration is zero (de-mineralized water). With the switch in the ON position the injection concentration is as specified in the input array.

TABLE 3-5  
PRIMARY COOLANT PARAMETER SUMMARY

NODE	LOCATION	1 WATER VOLUME (ft <sup>3</sup> )	2 HEAT CAPACITY (Btu/°F)	3 HEAT CAPC. WALL (Btu/°F)	4 FILM HEAT TRANSFER (Btu/Sec °F)	5 STRUCTURE HEAT TRANS (Btu/Sec °F)	6 HEIGHT (ft)	NOTES																																		
1-4	Core	2.54	151.00	NA	342.55	Note 6	1.375	<p>1. See Appendix C for calculation details of the listed values.</p> <p>2.</p> <table border="1"> <thead> <tr> <th>Column Number</th> <th>Program Array Names</th> </tr> </thead> <tbody> <tr><td>1</td><td>V</td></tr> <tr><td>2</td><td>HC</td></tr> <tr><td>3</td><td>HCWAL</td></tr> <tr><td>4</td><td>HREF</td></tr> <tr><td>5</td><td>CK</td></tr> <tr><td>6</td><td>Z</td></tr> </tbody> </table> <p>3. The heat capacity, column 2, is computed as: <math>(\rho V c_p)_{\text{water}} + (\rho V c_p)_{\text{structure}}</math>.</p> <table border="1"> <thead> <tr> <th>Nodes</th> <th><math>c_p</math> (Btu/lbm °F)</th> <th><math>\rho</math> lbm/ft<sup>3</sup></th> <th>Assumed Conditions</th> </tr> </thead> <tbody> <tr> <td>26-46</td> <td>1.2577</td> <td>46.5333</td> <td>2250 psia, 555°F</td> </tr> <tr> <td>1-14, 47-51</td> <td>1.3191</td> <td>45.1467</td> <td>2250 psia, 575°F</td> </tr> <tr> <td>15-25</td> <td>1.4058</td> <td>43.5777</td> <td>2250 psia, 595°F</td> </tr> <tr> <td>structure</td> <td>0.11</td> <td>495</td> <td>stainless steel</td> </tr> </tbody> </table> <p>4. The film heat transfer, column 4, equals the film heat transfer coefficient, <math>h_{DB}</math>, times the surface area. The <math>h_{DB}</math> calculation uses a flow rate of 30.7640 ft<sup>3</sup>/sec.</p> <p>5. The structure heat transfer, column 5, in general is calculated using the formula <math>kA/L</math>. Where <math>k</math> is the conductivity coefficient, <math>A</math> is the surface area and <math>L</math> is 1/4 the thickness of the slab.</p> <p>6. The structure heat transfer coefficients in the core and steam generator (nodes 1-14) are specified in the input array. This allows for adjustments to establish fuel temperature and steam generator pressure at the desired initial conditions.</p>	Column Number	Program Array Names	1	V	2	HC	3	HCWAL	4	HREF	5	CK	6	Z	Nodes	$c_p$ (Btu/lbm °F)	$\rho$ lbm/ft <sup>3</sup>	Assumed Conditions	26-46	1.2577	46.5333	2250 psia, 555°F	1-14, 47-51	1.3191	45.1467	2250 psia, 575°F	15-25	1.4058	43.5777	2250 psia, 595°F	structure	0.11	495	stainless steel
Column Number	Program Array Names																																									
1	V																																									
2	HC																																									
3	HCWAL																																									
4	HREF																																									
5	CK																																									
6	Z																																									
Nodes	$c_p$ (Btu/lbm °F)	$\rho$ lbm/ft <sup>3</sup>	Assumed Conditions																																							
26-46	1.2577	46.5333	2250 psia, 555°F																																							
1-14, 47-51	1.3191	45.1467	2250 psia, 575°F																																							
15-25	1.4058	43.5777	2250 psia, 595°F																																							
structure	0.11	495	stainless steel																																							
5-14	SG Tubes	2.43	144.59	NA	588.64	Note 6	±1.408																																			
15-16	Upper PLN.	6.87	536.25	61.65	10.80	4.37	2.735																																			
17	UP PLN. Out	7.40	526.41	62.49	11.29	4.57	-1.751																																			
18	UP PLN. . . P.	12.30	1333.94	237.75	63.15	2.45	NA																																			
19-23	Hot Leg	2.76	168.93	83.28	23.84	1.56	0																																			
24	SG Inlet	11.84	725.62	143.66	20.64	1.14	-2.583																																			
25	SG Tube SH	1.56	95.57	242.92	378.15	49.31	-0.958																																			
26	SG Tube SH	1.56	91.30	242.92	384.81	49.31	0.958																																			
27	SG Outlet	11.84	693.21	143.66	21.00	1.14	2.583																																			
28-31	Cold Leg	3.00	175.6	90.00	25.90	1.68	2.833, 0, -2.083																																			
32-33	Pumps	3.50	204.84	124.46	40.99	3.11	-0.75, 0																																			
34-37	Cold Leg	2.87	167.59	94.14	31.14	1.74	0																																			
38	RV Inlet	9.65	564.85	1588.40	165.89	17.51	1.858																																			
39-43	DWNCMR	5.07	296.99	1057.87	131.75	12.06	2.514																																			
44-46	Lower PLN	7.91	462.76	115.68	3.15	1.19	0, 0, -1.707																																			
47	RABV	3.28	195.21	101.03	29.74	1.87	NA																																			
48		7.64	455.10	207.29	137.94	7.83	NA																																			
49		6.69	398.59	181.13	120.81	6.85	NA																																			
50		3.28	195.21	101.03	29.74	1.87	NA																																			
51	Core Bypass	0.49	29.18	1185.56	11657.53	48.77	10.97																																			

4.0 PRESSURIZER MODEL

The pressurizer model is divided into two separate thermodynamic systems corresponding to the steam and water regions. Simulation of the pressurizer response is based upon mass and energy balances in both regions.

4.1 Pressurizer Pressure and Level

The pressure existing in the pressurizer is computed from a volume balance performed by the analog circuit shown in Appendix H, Figure H-4. This circuit performs a continuous iteration on the following equation:

$$V = M_W v_W(h_W, P) + M_G v_G(h_G, P) \quad (4-1)$$

Where  $V$  = Total volume of the pressurizer  
34.76 cu ft

$M_W$  = mass in water region

$h_W$  = average specific enthalpy of the water region

$M_G$  = mass in steam region

$h_G$  = average specific enthalpy of the steam region

$P$  = pressurizer pressure

$v(h, P)$  = average specific volume of the water or steam regions. These are computed as functions of specific enthalpy and pressure in the AD-10. See figures and tables in Appendix D.

At each time step the mass and energy terms are updated as follows:

$$M_W = M_W^i - \Delta M_{SUR} + \Delta M_{SPR} - \Delta M_{BOIL/COND} \quad (4-2)$$

$$H_W = H_W^i - \Delta H_{BOIL/COND} + \Delta H_{HTR} + h_f \Delta M_{SPR} - h_{SUR} \Delta M_{SUR} - \Delta H_{AMB} + J V_W \Delta P \quad (4-3)$$

$$M_G = M_G^i - \Delta M_{RV} + \Delta M_{BOIL/COND} \quad (4-4)$$

$$H_G = H_G^i - h_g \Delta M_{RV} - (h_f - h_{SPR}) \Delta M_{SPR} - \Delta H_{AMB} + \Delta H_{BOIL/COND} + J V_G \Delta P \quad (4-5)$$

$$h_W = H_W/M_W \quad (4-6)$$

$$h_G = H_G/M_G \quad (4-7)$$

Where

$M'_W, H'_W, M'_G, H'_G$  = mass and enthalpy in the water and steam regions. Primes indicate values from the previous time step.

$h_W, h_G$  = specific enthalpy of the water and steam regions

$\Delta M_{SUR}$  = amount of mass leaving the water region via the surge line

$\Delta M_{SPR}$  = amount of mass added as spray

$\Delta M_{BOIL/COND}$  = amount of mass transferred between the water and steam regions as boil off or condensation

$\Delta H_{BOIL/COND}$  = amount of energy transferred between the water and steam regions by boiling or condensation

$\Delta H_{HTR}$  = energy added to the water by the heaters

$h_f$  = specific enthalpy of water at saturation

$h_{SUR}$  = specific enthalpy of the surge line fluid

$\Delta H_{AMB}$  = ambient heat loss term

$J$  = conversion factor = 0.1851 Btu/(cu ft psi)

$\Delta M_{RV}$  = mass lost via the relief valves

$\Delta P$  = change in pressurizer pressure during previous time step

$h_{SPR}$  = specific enthalpy of the spray fluid

$V_W, V_G$  = volume of water and steam regions

Pressurizer level is computed from the following equation:

$$\text{Level (in)} = \frac{V_W}{(\text{cu ft})} \times \frac{2.02}{(\text{in/ cu ft})} \quad (4-8)$$

where  $V_W$  is the volume of the water region obtained from ADC 100.

Pressurizer initialization is accomplished by specifying the desired pressure and liquid level in the input array. The INIT subroutine computes values for the mass and enthalpy of the steam and water regions and initializes the analog circuitry. Handset pot P150 is provided to allow fine adjustment of the pressure.

Loop pressure is computed using the following equation:

$$P_L = P_p - K \dot{V} |\dot{V}| \quad (4-9)$$

Where

$P_L$  = Loop pressure

$P_p$  = Pressurizer pressure

$\dot{V}$  = Surge line volumetric flow rate from the pressurizer to the loop (cu ft/sec)

$K$  = surge line resistance, specified as an input parameter

## 4.2 Surge Flow

The mass flow in the surge line is generated by thermal expansion or compression of the primary loop coolant, and makeup, drain, and spray flows.

The primary loop thermal expansion/compression term is computed by comparing the total loop mass (sum of the volume of each node times density) with the mass from the previous time step. This mass difference is added or subtracted from the surge flow. Due to the incremental nature of the numerical procedure a small but finite amount of "noise" exists in the computation of loop density. In order to eliminate cooldown of the pressurizer water

caused by these small density changes, a threshold value is specified in the input array. If the mass difference is smaller than the threshold value, it is not used in the current step but is included with the mass difference of the next time step.

The spray flow term is added to the surge flow to account for the spray mass which is lost from the primary loop mass and is made up by pressurizer outsurge.

Makeup and drain flows are explained in Section 3.6.

The enthalpy and specific volume of the surge line fluid depends upon the direction of the flow. For outsurges they equal the values of the pressurizer water. For insurges the specific volume equals the inverse of the hot leg density, node 21, and the enthalpy is approximated using the following equation:

$$h = 1.25 T - 140 \quad (4-10)$$

where  $T$  is the temperature ( $^{\circ}\text{F}$ ) of node 21. See Appendix D, Figure D-13 for a comparison of this approximation and steam table data.

#### 4.3 Spray

Automatic spray flow is initiated whenever pressurizer pressure increases to the spray setpoint (specified in the input array). The spray reset point is 25 psi below the setpoint. Automatic spray can be initiated using analog DAP switch 15. Spray can be manually initiated using switch 13.

Spray flow is calculated using the following formula:

$$\Delta M_{SP} = W_0 \left( \frac{\dot{V}}{22} \right) \times \rho_{34} \times \Delta t \quad (4-11)$$

Where

- $\Delta M_{SP}$  = Mass transfer via the sprayline in one time step
- $\frac{\dot{V}}{22}$  = Loop flow rate ratio - accounts for spray flow changes caused by PCS pump speed
- $\rho_{34}$  = Density of cold leg node 34
- $\Delta t$  = Duration of the time step
- $W_0$  = Nominal spray flow when automatic spray is on, otherwise the continuous spray flow. Both flow values are specified in the input array.

Spray flow enthalpy is approximated using equation 4-10, where T is the temperature of node 34. The spray is assumed to absorb enough energy from the steam that it enters the water at saturation temperature. The energy difference between the spray enthalpy and saturated water enthalpy is subtracted from the steam region. Because the spray flow is included in the surge flow, the net effect of spray on the water region is no change to the mass and an energy addition equal to  $(h_f - h_w) \cdot \Delta M_{SPR}$ . Equation 4-13 is used to approximate saturation enthalpy.

#### 4.4 Pressurizer Heaters

Two banks of heaters are simulated. Separate pressure setpoints are specified for each bank in the input array. The reset dead bands are 30 psi for the cycling heaters and 15 psi for the backup heaters. Each bank supplies 24 KW to the water region when activated. DAP switch 1 can be used to override the heater logic.

As an aid in establishing plant conditions, additional energy can be added to the pressurizer. When DAP switch 6 is in the down position, a variable amount of power, specified in the input array in Btu/sec, is added to the pressurizer.

#### 4.5 Relief Valves

The operation of the pressurizer steam relief valves are simulated by subtracting mass and energy from the steam region. The mass flow rate of the power-operated valve is 7200 lbm/hr and the combined flow from both safety relief valves is 45,232 lbm/hr (reference 6, Table XII). The setpoints and reset dead bands are specified in the input array with both safety relief valves sharing the same setpoints.

The power-operated relief valve can be controlled at the console using DAP switch 14 to open the valve and switch 15 to override the automatic operation.

#### 4.6 Pressurizer Ambient Losses

Ambient losses in the pressurizer are divided equally between the steam and water regions. The heat transfer coefficient UA, is specified in the input array. The total heat lost is calculated as follows:

$$\Delta H_{AMB} = UA (T_{PZR} - T_{AMB}) \quad (4-12)$$

where

$$T_{PRZ} = \text{Pressurizer Temperature (approximated by } h_f)$$

$$T_{AMB} = \text{Ambient Temperature } 100^{\circ}\text{F.}$$

#### 4.7 Pressurizer Boil-Off and Condensation

In addition to calculating the pressurizer pressure, the analog circuitry shown in Appendix H, Figure H-4, also determines the steam quality in the water and steam regions. If the quality of the steam region is less than 1, condensation occurs and  $M_G(1-X_G)$  pounds of steam are transferred to the water at fluid saturation enthalpy. Boil-off occurs whenever water region quality exceeds 0. In this case,  $M_W X_W$  pounds of water are transferred to the steam region at gas saturation enthalpy.

The approximations used to calculate  $h_f$  and  $h_g$  are plotted in Appendix D and are as follows:

$$h_f = 438.1 + 0.117 \times \text{pressure (Figure D-10)} \quad (4-13)$$

$$h_g = 1320.x - 0.09 \times \text{pressure (Figure D-11)} \quad (4-14)$$

The tables used to determine the quality of the steam and water are also shown and plotted in Appendix D.

## 5.0 PLANT PROTECTION SYSTEM

The plant protection system (PPS) provides for automatic control rod scram and/or emergency core cooling (ECC) when any of the monitored parameters equal or exceed their setpoint. Table 5-1 summarizes the simulated PPS system.

### 5.1 Time Constants

Instrument channel time constants are modeled as a first order system described by the following equation:

$$\tau \frac{dX_M}{dt} + X_M = X_A \quad (5-1)$$

where

- $\tau$  = time constant
- $X_M$  = measured output signal
- $X_A$  = actual value of the parameter being measured

The solution of differential equation 5-1 is approximated by the Euler one-step numerical method. Setpoints and time constants are specified in the input array. Scram signals can be inhibited using console DAP switch 4.

### 5.2 Time Delays

After a scram condition is detected a time delay is used to simulate the actual PPS and control rod circuitry response. The duration of the time delay is specified in the input array. When the scram delay time has expired, the control rod scram is initiated (see section 2.2.4.3).

5.3 ECCS

Upon receipt of an ECCS signal, high pressure injection is initiated at a specified flow rate and boron concentration (see sections 3.6 and 3.7).

TABLE 5-1

PPS SIMULATION

<u>Parameter</u>	<u>Instrument Channel Time Constant</u>	<u>Trip Condition</u>	<u>Notes</u>
<u>RSS</u>			
average reactor power	yes	high power	peak power trip not simulated
hot leg temperature	yes	high temperature (node 20)	
loop pressure	yes	high or low loop pressure	
PCS flow	yes	low mass flow (node 23)	
RABV	included in setpoint	high RABV volumetric flow	actual plant trip is based on RABV valve position
loss of pump generator field current	included in setpoint	simulated by a timed trip	
manual scram	no	console DAP switch 11	
<u>ECCS</u>			
loop pressure	yes	low pressure	

6.0 STEAM GENERATOR AND ASSOCIATED CONTROLLERS6.1 Steam Generator Secondary Side

The secondary side of the steam generator is modeled as two nodes:

- (1) Downcomer liquid region
- (2) Steam generator saturated liquid/steam mixture including steam dome and piping to the Main Steam Valve.

The relationship of the two nodes is shown in Figure 6-1.

6.1.1 The downcomer node is assumed to consist of subcooled incompressible liquid. The mass and energy equations are as follows:

$$\frac{dM_D}{dt} = W_{FW} + W_{RECIR} - W_D \quad (6-1)$$

$$\frac{dh_D}{dt} = W_{FW} \cdot (h_{FW} - h_D) + W_{RECIR} \cdot (h_f - h_D) + J v_D \frac{dP}{dt}$$

$M_D$  = downcomer mass

$h_D$  = downcomer specific enthalpy

$h_{FW}$  = feedwater specific enthalpy

$h_f$  = steam generator saturated liquid specific enthalpy

$W_D$  = downcomer flow


$W_{RECIR}$  = recirculation flow

$W_{FW}$  = feedwater flow

$v_D$  = downcomer specific volume, approximated by saturated liquid specific volume

$P$  = steam generator pressure

$J$  = conversion factor 0.1851 Btu/(cu ft psi)



INEL-A-13 935

FIGURE 6-1  
STEAM GENERATOR

6.1.2 The mass and energy equations for the saturated portion of the steam generator are as follows:

$$\frac{dM_{SG}}{dt} = W_D - W_{RECIR} - W_{STM} \quad (6-3)$$

$$\begin{aligned} \frac{dh_{SG}}{dt} = & W_D \cdot (h_D - h_{SG}) - W_{RECIR}(h_f - h_{SG}) \\ & - W_{STM} \cdot (h_g - h_{SG}) + \dot{Q}_{SG} + Jv_{SG} \frac{dp}{dt} \end{aligned} \quad (6-4)$$

$M_{SG}$  = steam generator mass

$h_{SG}$  = steam generator specific enthalpy

$h_g$  = saturated steam specific enthalpy

$\dot{Q}_{SG}$  = rate of heat input from the primary coolant

$v_{SG}$  = steam generator specific volume

$W_{ST}$  = steam flow, including relief valve flow

If the downcomer flow,  $W_D$ , is negative its associated enthalpy term is added to  $h_D$  instead of  $h_{SG}$ .

6.1.3 The recirculation flow rate,  $W_{RECIR}$ , is determined by assuming that the steam quality in the shroud riser is proportional to the average shroud steam quality.

$$X_{riser} = \beta \bar{X}_{shroud} = \frac{W_{STM}}{W_{STM} + W_{RECIR}} \quad (6-5)$$

$\beta$  is empirically determined in Appendix F-2 to be a function of power as follows:

$$\beta = 2.8523 + \frac{21974}{\dot{Q}_{SG}} \quad (6-6)$$

The following additional relationships are used to determine  $W_{RECIR}$ :

$$\bar{X}_{shroud} = (v_{shroud} - v_f) / (v_g - v_f) \quad (6-7)$$

$$v_{shroud} = \frac{V_{shroud}}{M_{shroud}} \quad (6-8)$$

$$M_{\text{shroud}} = M_{\text{SG}} - M_{\text{dome}} \quad (6-9)$$

$$M_{\text{dome}} = \frac{(V_{\text{TOT}} - V_{\text{shroud}} - v_f M_D)}{v_g} \quad (6-10)$$

$\bar{x}_{\text{shroud}}$  = steam quality in the shroud

$x_{\text{riser}}$  = steam flow quality in shroud riser

$\beta$  = proportionality factor

$v_{\text{shroud}}, v_f, v_g$  = specific volumes of the shroud, downcomer, saturated fluid, and saturated gas

$V_{\text{shroud}}$  = shroud volume, 88.8 cu ft

$M_{\text{shroud}}$  = mass in the shroud

$M_{\text{dome}}$  = mass in the dome and steam piping up to the main steam valve

$V_{\text{TOT}}$  = total steam generator and steam piping volume, 235 + 41 = 276 cu ft (reference 6, Table XXXIV, page 260)

6.1.4 Downcomer flow is determined by solving the following natural circulation equation:

$$\begin{aligned} & (\rho_D L_D - \rho_{\text{riser}} L_{\text{riser}} - \rho_{\text{drum}} L_{\text{drum}}) / 1728 \\ & = k_1 (v_D W_D)^2 + k_2 (v_f W_{\text{RECIR}} + v_g W_{\text{STM}})^2 \end{aligned} \quad (6-11)$$

$L_D$  = downcomer level (inches)

$L_{\text{riser}}$  = height of the riser section of the shroud, 64.44 inches

$L_{\text{drum}}$  = height of the drum section of the shroud, 97.31 inches

$\rho_D$  = downcomer density

$\rho_{\text{riser}}$  = density in the riser section

$\rho_{\text{drum}}$  = density in the drum section

$$k_1 = \text{downcomer flow loss coefficient} \\ 2.2028 \times 10^{-2} \text{ psi}/(\text{cu ft}/\text{sec})^2 \quad (\text{Appendix F-2})$$

$$k_2 = \text{shroud flow loss coefficient,} \\ 7.8888 \times 10^{-4} \text{ psi}/(\text{cu ft}/\text{sec})^2 \quad (\text{Appendix F-2})$$

For very small gravity head differences equation 6-11 becomes numerically unstable. This is corrected by substituting  $10W_{DL}$  for  $W_D^2$  whenever  $W_D$  is less than 10 cu ft/second.  $W_{DL}$  is the laminar downcomer flow and is a linear function of the driving head.

Appendix E contains steam generator dimensions, volume calculations, and the following downcomer level relationship.

$$V_D = M_D v_f$$

$$L_D = \begin{cases} 4.8098 V_D & \text{for } V_D \leq 19.41 \text{ cu ft} \\ 0.9241 V_D + 75.43 & \text{for } V_D > 19.41 \text{ cu ft} \end{cases} \quad (6-12)$$

The riser and drum densities are calculated as follows:

$$\rho_{\text{riser}} = \frac{1}{v_f + X_{\text{riser}} v_{fg}} \quad (5-13)$$

$$\rho_{\text{drum}} = \frac{M_{\text{shroud}} - \rho_{\text{riser}} \cdot V_{\text{riser}}}{V_{\text{DRUM}}} \quad (6-14)$$

$$V_{\text{riser}} = 17.13 \text{ ft}^3$$

$$V_{\text{drum}} = 71.67 \text{ ft}^3$$

6.1.5 Steam generator pressure is determined by a two-dimensional table lookup. The table inputs are  $h_{SG}$  and  $\log(v_{SG})$  (see Figure 6-2). Table values are interpolated logarithmically for specific volume and linearly for specific enthalpy. The variable  $\log(v_{SG})$  is used to provide a more uniform configuration of the table. Appendix G shows the method used to generate the table.

6.1.6 The steam generator dryout factor,  $f$ , discussed in Section 3.3 accounts for the fraction of the secondary heat transfer area in which departure from nuclear boiling (DNB) has occurred.  $f$  is calculated by assuming that the steam quality in the drum is linearly distributed with height.

$$f = \frac{L_{\text{DNB}}}{L_{\text{DRUM}}} \quad .01 \leq f \leq 1.0 \quad (6-15)$$


$L_{\text{DNB}}$  is the height where the steam quality equals  $x_{\text{DNB}}$ . The method used to compute  $L_{\text{DNB}}$  is given in Appendix F-3. The resulting equations yield the following:

$$f = \begin{cases} 1 - (x_{\text{RISER}} - x_{\text{DNB}})2x_{\text{DRUM}}/x_{\text{RISER}}^2 \\ \text{for } 2x_{\text{DRUM}} < x_{\text{RISER}} \end{cases} \quad (6-16)$$

$$\begin{cases} 1 - (x_{\text{RISER}} - x_{\text{DNB}})/2(x_{\text{RISER}} - x_{\text{DRUM}}) \\ \text{for } 2x_{\text{DRUM}} > x_{\text{RISER}} \end{cases} \quad (6-17)$$

$$.01 \leq f \leq 1.0$$

6.1.7 Two relief valves are included in the steam generator model. When their respective high-pressure setpoints are exceeded they relieve 25 lbm/second of steam each (Reference 15), with a one-second response time constant. The reset deadbands are 55 and 56 psi, respectively, and the setpoints are specified in the input array.



INEL A 13 945

FIGURE 6-2  
PRESSURE VS. VOLUME AND ENTHALPY

6.1.8 Saturation values of temperature, specific volume and enthalpy are determined as a function of pressure using a table lookup. The tables extend from 100 to 1600 psia in 100 psia increments.

## 6.2 Main Steam Control Valve

The Main Steam Control Valve (MSCV) stem position is controlled with an automatic and manual controller. The valve is manually controlled from the console using logic switch 112 to open or shut the valve. In the manual mode valve ramp rate can be multiplied by a factor of 0.1 using DAP switch 5.

The automatic controller uses the following logic:

- (a) The valve is demanded to open when the steam generator pressure exceeds the high pressure set point.
- (b) The valve is demanded to shut when the steam generator pressure is less than the low pressure set point and a PPS scram condition has been detected.
- (c) Automatic operation overrides manual control.

The ramp rate, response time constant, pressure set points, and dead-band are specified in the input array.

Steam flow in lbm/sec is calculated using the following formulas:

$$W_S = C_V \sqrt{\bar{P} \cdot \Delta P} \quad (6-18)$$

$$\bar{P} = \frac{P_{SG} + P_{CR}}{2} \quad (6-19)$$

$$\Delta P = P_{SG} - P_{CR} \quad (6-20)$$

where,

$W_S$  = steam flow (lbm/sec)

$P_{SG}$  = steam generator pressure (psia)

$P_{CR}$  = condensate receiver pressure (psia)

$C_V$  = valve flow characteristic (see Table 6-3)

Steam valve leakage can be simulated by specifying the fraction of 50 MW assumed to be leaking past the MSCV when it indicates shut. The INIT program calculates a minimum steam flow,  $W_{MIN}$ , and steam flow equals  $W_S$  from the valve  $C_V$  or  $W_{MIN}$ , whichever is greater.

$$W_{MIN} = \left( \begin{array}{c} \text{leakage} \\ \text{fraction} \end{array} \right) \times 50 \text{ MW} \times \frac{W_S}{\text{power}} \Bigg|_{\text{initial values}} \quad (6-18)$$

### 6.3 Steam Generator Water Level Controller

The steam generator water level control circuitry uses inputs of steam flow and steam generator water level to determine the proper feed valve position. Figure 6-4 schematically shows the control circuitry. The feed valve is positioned to the control signal with a one-second time constant.

Upon receipt of a PPS scram signal the model initiates a delay then overrides the water level controller and shuts the feed valve. The delay time and valve ramp rate are specified in the input array.


TABLE 6-3

MAIN STEAM VALVE C<sub>v</sub> VERSUS STEM POSITION

<u>Stem Position (%)</u>	<u>C<sub>v</sub> (lbm/sec/psi)</u>
0	0
10	.0223
20	.0289
30	.0388
40	.0520
50	.0685
60	.0907
70	.1196
80	.1592
90	.2170
100	.2805

See reference 6, Figure 154, where

$$C_v = \frac{(2.1) \sqrt{2}}{3600} \times (\text{the } C_v \text{ listed in engineering units})$$



- $L_0$  = Level set point (specified as an input parameter)  
 $L_{SG}$  = Indicated level signal (1 sec time constant)  
 $W_{SG}$  = Steam generator steam flow  
 $Z$  = Feed valve control signal

INEL-A-13 937

FIGURE 6-4

STEAM GENERATOR WATER LEVEL CONTROL SCHEMATIC

## 7.0 AIR-COOLED CONDENSER

Steam from the main steam control valve is condensed in the air-cooled condenser. The condenser is divided into three bays. Each bay has 230 tubes and two adjustable blade air fans. The LOFT simulation models each bay separately. Pressure in the condenser is assumed to be uniform and equal to the receiver pressure.

### 7.1 Air-Cooled Condenser Air Flow

Air flow through the air-cooled condenser (ACC) is adjusted by changing the blade angle on the fans (total of six). The blade angle controller (shown in Figure 7-1) is used to maintain a constant pressure at the ACC inlet. The positioner setpoint is determined by the INIT subroutine and depends upon the initial condenser pressure specified in the input array.

ACC air flow in cfm ( $\dot{V}_{fan}$ ) is a function of the blade angle and is determined by a table lookup of plant data as shown in Table 7-2. The mass flow rate per bay is calculated as follows:

$$W_{air} = 2\dot{V}_{fan} \times \left( \frac{1 \text{ min}}{60 \text{ sec}} \right) \times \rho_{air} \quad (7-1)$$


$$\rho_{air} = \frac{33.72}{T}, T \text{ in } ^{\circ}\text{R}, 25.45" \text{ Hg} \quad (7-2)$$

(See Reference 9, page 1946)

The simulation uses the average air temperature of bay 1 to compute the density.

The ACC model can be operated with air flow to bay 2 and/or 3 secured by selecting BAYSW(2) and/or (3) in the input array to zero. The normal value for these variables is one. Transient air flow conditions are simulated by reducing the air flow from its initial value to a preset minimum at a constant rate. The minimum values for each bay

and the flow reduction rate are specified in the input array. Only the bays selected by setting AIRSW(1), (2), and/or (3) in the input array to one are affected by the transient. The normal values in the AIRSW array are zero.



$f_{CO} = 0.75 \text{ Hz (reference 13)}$

$\tau = \frac{1}{2 \pi f_{CO}} = 0.2122 \text{ sec}$

INEL A-13 936

FIGURE 7-1  
AIR-COOLED CONDENSER FAN BLADE POSITIONER


TABLE 7-2AIR FLOW VS FAN PITCH ANGLE

<u>Pitch Angle</u> <u>(degrees)</u>	<u>Air Flow</u> <u>1000 cu ft/min/fan</u>
0	0
2	65
4	84
6	100
8	114
10	126
12	137
14	148
16	156
18	164
20	170
22	174

Reference 11, Figure 4, page 11, louvers 100% open.

7.2 Air-Cooled Condenser Heat Transfer

The heat transfer through the condenser tubes is modeled as follows:



$T_{SAT}$  = saturation temperature of the condensate obtained from the condensate receiver pressure by a table lookup

$T_{TUBE}$  = tube temperature

$\bar{T}_{AIR}$  = log mean air temperature

$U_{Fi}$  = heat conduction across the inside film

$U_{FOUL}$  = heat conduction across tube deposits

$U_{TUBE}$  = heat conduction across the tube

$U_{Fo}$  = heat conduction across the outside film

$Mc_p$  = heat capacity of tubes

The heat conduction correlations are from reference 10, modified as follows:

$U_{Fi}$ : (page 7)

$$\frac{1}{h_i} = 1.29 \times 10^{-5} W_{STM}^{1/3} \frac{\text{hr. ft}^2 \text{ OF}}{\text{Btu}} \quad (7-3)$$

$$h_i = \frac{10^5}{1.29} W_{STM}^{-1/3} \times (2)^{1/3} \times (3600)^{-1/3} \times \frac{\text{hr}}{3600 \text{ sec}} \quad (7-4)$$

converts the length term  
from per fan to per bay

converts W from lbm/hr  
to lbm/sec

$$U_{Fi} = h_i = 1.77 W_{STM}^{-1/3} \frac{\text{Btu}}{\text{sec ft}^2 \text{ OF}} ; W_{STM} = W_{COND} \text{ lbm/sec} \quad (7-5)$$

U<sub>FOUL</sub>: (page 3)

$$r_i = .001 \frac{\text{hr ft}^2 \text{ } ^\circ\text{F}}{\text{BTU}} \quad (7-6)$$

$$U_{\text{FOUL}} = \frac{1}{r_i} \left( \frac{1}{3600} \right) = .2778 \frac{\text{Btu}}{\text{sec ft}^2 \text{ } ^\circ\text{F}} \quad (7-7)$$

U<sub>TUBE</sub>: (page 6)

$$r_w = .0184 \frac{\text{hr ft}^2 \text{ } ^\circ\text{F}}{\text{Btu}} \quad (7-8)$$

$$U_{\text{TUBE}} = \frac{1}{r_w} \left( \frac{1}{3600} \right) = .0151 \frac{\text{Btu}}{\text{sec ft}^2 \text{ } ^\circ\text{F}} \quad (7-9)$$

U<sub>FO</sub>: (page 9)

$$\frac{1}{h_o} = 1620 W_{\text{air}}^{-.72} \frac{\text{hr ft}^2 \text{ } ^\circ\text{F}}{\text{Btu}} \quad (7-10)$$

$$h_o = \frac{1}{1620} W_{\text{air}}^{.72} \times \frac{1}{2}^{.72} \times (3600)^{.72} \times \left( \frac{\text{hr}}{3600 \text{ sec}} \right) \quad (7-11)$$

converts  $W_{\text{air}}$  from fan  
flow to bay flow

converts  $W$  from  
lbm/hr to lbm/sec

$$U_{\text{FO}} = h_o = 3.784 \cdot 10^{-5} W_{\text{air}}^{.72} \frac{\text{Btu}}{\text{sec ft}^2 \text{ } ^\circ\text{F}} \quad (7-12)$$

The heat transfer equations used from the tube to the air are derived as follows:

$$\dot{Q}_{\text{air}} = W_{\text{air}} c_p (T_{\text{out}} - T_{\text{amb}}) = UA \cdot \overline{\Delta T} \quad (7-13)$$

$W_{\text{air}}$  = air flow per bay (lbm/sec)

$\dot{Q}_{\text{air}}$  = heat rejected to air (Btu/sec)

$c_p$  = heat capacity of air (from reference 9,  
page 1909, at 100<sup>°</sup>F) = 0.242 Btu/lbm<sup>°</sup>F

$T_{out}$  = air temperature at outlet of bay

$T_{amb}$  = ambient air temperature. Specified in the input array.

$U$  = heat transfer coefficient =  $\left(\frac{1}{U_{Fo}} + \frac{1}{U_{TUBE}}\right)^{-1}$

$A$  = external area per bay. From reference 6, page 258, Table XXXIII, =  $168,383 \text{ ft}^2/3 = 56,128 \text{ ft}^2$

$\overline{\Delta T}$  = mean log temperature difference

$$= (T_{out} - T_{amb}) / \ln \frac{T_{TUBE} - T_{AMB}}{T_{TUBE} - T_{OUT}} \quad (7-14)$$

From equations 7-13 and 7-14:

$$\Delta T_{air} = T_{OUT} - T_{AMB} = (T_{TUBE} - T_{AMB}) \cdot \left(1 - e^{-\frac{UA}{W_{air} c_p}}\right) \quad (7-15)$$

and

$$\dot{Q}_{air} = W C_p \cdot \Delta T_{air}$$

The average bay air temperature is computed as  $T_{AMB} + 1/2 \Delta T_{air}$ .

The heat transfer from the steam to the tube is computed by:

$$\dot{Q}_{cond} = UA (T_{SAT} - T_{TUBE}) \quad (7-16)$$

$$U = \left(\frac{1}{U_{Fi}} + \frac{1}{U_{FOUL}}\right)^{-1}$$

$A$  = inside surface area. From reference 10, page 6,  $D = 1 - 2 (.083) = .834$  inches.

$$A = (230)(44 \text{ ft}) \left(\frac{\pi \cdot .834}{12}\right) = 2210 \text{ ft}^2$$

The tube temperatures are updated as follows:

$$(Mc_p) \frac{d}{dt} T_{\text{TUBE}} = \dot{Q}_{\text{COND}} \cdot \dot{Q}_{\text{air}} \quad (7-17)$$

$$C_p = .12 \text{ BTU/lbm}^\circ\text{F}$$

$$M = (490 \text{ lbm/ft}^3) \cdot \frac{\pi}{4} (1^2 - .83^2) \text{ in}^2 \left( \frac{\text{ft}^2}{144 \text{ in}^2} \right) \cdot$$

$$(44 \text{ ft/tube}) \cdot (230 \text{ tubes})$$


$$= 8414 \text{ lbm}$$

$$Mc_p = 1009.68 \text{ BTU/}^\circ\text{F}$$

(tube dimensions from reference 6, page 258,  
Table XXXIII)

8.0 CONDENSATE RECEIVER MODEL8.1 Condensate Receiver Mass Transport

The mass transport in the condenser and receiver is modeled as follows:



$$W_{\text{cond}} = \dot{Q}_{\text{cond}} / \begin{pmatrix} h_g & - & h_f \\ \text{SG} & & \text{CR} \end{pmatrix} \quad (8-1)$$

$h_g$  and  $h_f$  are determined by a table lookup of pressure in the steam generator and condensate receiver, respectively.

$$W_G = W_{\text{STM}} - \Sigma W_{\text{cond}} \quad (8-2)$$

$$W_f = M_{\text{cond}} \cdot v_{\text{cond}} / \bar{L}_{\text{TUBE}} \quad (8-3)$$

$v_{\text{cond}}$  = velocity of condensate traveling down the tube = 1 ft/sec (Appendix I)

$\bar{L}_{\text{TUBE}}$  = average length of tube traversed by the condensate = 44 ft/2 = 22 ft

$W_{\text{relief}}$  = relief valve flow, activated on high condensate receiver pressure. Values for flow, pressure setpoint, and dead-band are specified in the input array.

## 8.2 Condensate Receiver Mass and Energy Balances

The mass and energy equations for the condensate receiver are as follows:

$$\frac{d M_{\text{cond}}}{dt} = W_{\text{cond}} - W_f \quad (8-4)$$

$$\frac{d M_W}{dt} = W_f - W_{FW} - \frac{\overline{\Delta M}_{B/C}}{\Delta t} \quad (8-5)$$

$$\frac{d M_{\text{STM}}}{dt} = W_G + \frac{\overline{\Delta M}_{B/C}}{\Delta t} - W_{\text{relief}} \quad (8-6)$$

$$\begin{aligned} \frac{d H_W}{dt} = & h_f W_{\text{cond}} - \bar{h}_W W_{FW} - \frac{\overline{\Delta H}_{B/C}}{\Delta t} \\ & + J V_W \Delta P \end{aligned} \quad (8-7)$$

$$\begin{aligned} \frac{d H_{\text{STM}}}{dt} = & h_{g \text{ SG}} W_G + \frac{\overline{\Delta H}_{B/C}}{\Delta t} - \bar{h}_{\text{STM}} W_{\text{relief}} \\ & + J V_{\text{STM}} \Delta P \end{aligned} \quad (8-8)$$

$M_{\text{cond}}$  = mass of the condensate in the ACC tubes

$M_W$  = mass of water in the CR

$M_{\text{STM}}$  = mass of steam in the CR and ACC

$H_W$  = enthalpy of water in the CR

$H_{STM}$  = enthalpy of steam in the CR and ACC

$\overline{\Delta M}_{B/C}$  = net mass exchange resulting from boiloff and condensation during the time step  $\Delta t$ .

$$= M_W X_W - M_{STM} (1 - X_{STM})$$

$X_W$  and  $X_{STM}$  = steam quality in water and steam regions

$\overline{\Delta H}_{B/C}$  = net enthalpy exchange resulting from boiloff and condensation during the time step  $\Delta t$ .

$$= M_W X_W h_g - M_{STM} (1 - X_{STM}) h_f$$

$h_g$  = specific enthalpy of saturated steam at  $P_{CR}$

$h_f$  = specific enthalpy of saturated liquid at  $P_{CR}$

$h_{gSG}$  = specific enthalpy of saturated steam at  $P_{SG}$

$\bar{h}_W = H_W/M_W$

$\bar{h}_{STM} = H_{STM}/M_{STM}$

$J$  = conversion factor = 0.1851 Btu/(cu ft psi)

$\Delta P$  = net change in  $P_{CR}$  during time step  $\Delta t$ .

$P_{CR}$  = condensate receiver pressure

$P_{SG}$  = steam generator pressure

$V_W$  = volume of water in condensate receiver

$V_{STM}$  = volume of steam in condensate receiver

8.3 Condensate Receiver Pressure

The Condensate Receiver Pressure is determined by iterating the pressure until the calculated volume ( $\bar{V}$ ) equals the actual volume ( $V_{CR}$ ). If  $\bar{V} > V_{CR}$  the pressure is increased. If  $\bar{V}$  is less than  $V_{CR}$  the pressure is decreased.

$$\begin{aligned} \bar{V} = & (M_{\text{cond}} v_f) + M_W (v_f + \frac{dv}{dh} (\bar{h}_W - h_f)) \\ & + M_{\text{STM}} (v_f + \frac{dv}{dh} (\bar{h}_{\text{STM}} - h_f)) \end{aligned} \quad (8-9)$$

$$\begin{aligned} V_{CR} = & 126.02 \text{ MSCV to ACC} \\ & 135.30 \text{ ACC} \\ & 72.31 \text{ ACC to CR} \\ & \underline{412.23 \text{ CR}} \quad (\text{Reference 6, page 260, Table XXXIV}) \\ & 745.86 \text{ ft}^3 \end{aligned}$$

$$v_f = \text{specific volume of saturated water at } P_{CR}$$

For subcooled water,

$$\frac{dv}{dh} = 13.828 \times 10^{-6} \quad (\text{see Figure 8-1}) \quad (8-10)$$

For saturated water, steam and superheated steam,

$$\begin{aligned} \frac{dv}{dh} = & 2.28 \times 10^{-4} + .496124/P_{CR} \\ & (\text{see Figures 8-2 and 8-3}) \end{aligned} \quad (8-11)$$




FIGURE 3-1  
SPECIFIC VOLUME VS. ENTHALPY-SUBCOOLED WATER

INEL-A-13 940




FIGURE 8-2  
 $dv/dh$  - SATURATED WATER




FIGURE 8-3  
SPECIFIC VOLUME VS. ENTHALPY - SUPERHEATED STEAM

INEL-A-13 939

9.0 FEEDWATER SYSTEM

Feedwater leaving the condensate receiver passes through the sub-cooler, main feed pump, and feed regulating valve before returning to the steam generator.

9.1 Subcooler

The equations used for the subcooler region are as follows:

$$M_{sc} \frac{dh_{sc}}{dt} = W_{FW} (h_W - h_{sc}) - \dot{Q}_{sc} \quad (9-1)$$

$$\dot{Q}_{sc} = UA (T_{sc} - T_{amb}) = \frac{UA}{C_p} (h_{sc} - h_{amb}) \quad (9-2)$$

$M_{sc}$  = mass of water in subcooler region

from reference 6, page 260, Table XXXIV

7.62 CR to SC  
 .50 subcooler  
 8.12 cu ft

$\rho$  @ 300 psi sat = 52.94 lbm/cu ft

$M_{sc} = 430$  lbm

$\frac{UA}{C_p} = 2.3$  lbm/sec (Appendix J)

$h_{amb} = 100$  BTU/lbm

$h_{sc}$  = specific enthalpy of water in the subcooler region

$W_{FW}$  = feedwater flow

$h_W$   
 CR = specific enthalpy of water in the condensate receiver

## 9.2 Feedwater Piping

The equations used in the feedwater piping are:

$$M_{FW} \frac{dh_{FW}}{dt} = W_{FW} (h_{sc} - h_{FW}) \quad (9-3)$$

$M_{FW}$  = mass of feedwater (from reference 6, page 260, Table XXXIV)

4.72 SC to feed pump  
 1.20 feed pump  
 7.02 feed pump to control valve  
18.27 control valve to steam generator  
 31.21 cu ft

$\rho$  @ 300 psi 10<sup>0</sup>F subcooled = 53.36 lbm/cu ft

$M_{FW}$  = 1665 lbm

$h_{FW}$  = specific enthalpy of feedwater

## 9.3 Feed Flow

Feed flow is determined as follows:

$$W_{FW} = C_V \sqrt{\rho(P_p - P_{SG})} \quad (9-4)$$

$W_{FW}$  = feedwater mass flow rate (lbm/sec)

$C_V$  = valve characteristic (from reference 12, figure 2)

$$C_V = 1.0725 X \quad 0 < X \leq .75$$

$$C_V = 1.0725 (2 X - .75) \quad .75 < X \leq 1.0$$

See figure 9-1 for a comparison of the  $C_V$  curve and power range testing data.

$\rho$  = feedwater density = 53.36 lbm/ft<sup>3</sup> at  
300 psi, 10<sup>0</sup>F subcooled

$P_p$  = feed pump discharge pressure (psi) =  
 $P_{CR} + P_o - RW_{FW}^2$  (9-5)

$P_o$  = shutoff head discharge pressure.  
Specified in the input array.

$R$  = pump internal resistance factor =  
.02330 psi/(lbm/sec)<sup>2</sup> (see Appendix J).


$P_{SG}$  = steam generator pressure (psi)

$P_{CR}$  = condensate receiver pressure (psi)

Solving equations 9-4 and 9-5 explicitly for  $W_{FW}$  yields:

$$W_{FW} = C_V \sqrt{\frac{P_{CR} + P_o - P_{SG}}{1 + C_V^2 \rho R}} \quad (9-6)$$

FIGURE 9-1  
FEED VALVE  $C_V$



No. 10 X 10 TO THE INCH 46-0780  
 7 X 10 TOCHES MADE IN U.S.A.  
 KEUPPEL & ESSER CO.

## 10.0 PROGRAM OPERATION AND CONTROL

The simulation is run on a PDP-11 with an Applied Dynamics, AD-5, analog console and an AD-10 function generator. The operating system is RSX-11M, version 3.2.

### 10.1 Analog Initialization

The values of the analog potentiometers are preset using an Interactive Hybrid Interpreter (IHI) program called COFSETØ. This program sets the pots to a tolerance of  $\pm 0.015\%$  of the total range. The source program listing is in Appendix H, Figure H-7.

The AD-10 function generator is loaded with the values given in Appendix H, Figures H-8 through H-12 by an AD-10 program called F12V.

Both of these programs are activated from the operating terminal by a command file named HYSETUP.

### 10.2 Program Execution

The simulation computer program is named PLAN14. Table 10-1 lists the commands used to control the program.

### 10.3 Digital Program Initialization

The INIT14 subroutine initializes the program to precomputed steady state values. This is accomplished by using the same modeling equations used for the dynamic solutions except that the time derivatives are set to zero. Because this computation is performed by a separate subroutine which is independent of the dynamic solution, INIT14 serves as a check of the main program implementation.

The steady state temperatures in the primary coolant loop are determined by using a recursive solution which is given in Appendix N.

Iterative solutions are used to determine the initial steam generator shroud mass and air-cooled condenser mass flow rate.

Input parameters used for initialization are:

1. Reactor Power (MW)
2. Hot Leg Temperature ( $^{\circ}$ F)
3. Pressurizer Pressure (PSIA)
4. Pressurizer Level (inches)
5. Condensate Receiver Pressure (PSIA)
6. Steam Generator Level Setpoint (inches)
7. PCS Loop Boron Concentration (ppm)

#### 10.4 Main Operating Program

The main operating program is contained in the MAIN14 subroutine. This subroutine cycles once each frame time as specified in the input array. Figure 10-2 is a block diagram of the logic flow paths. Appendix H, Figure H-2, shows the analog clock and data counter display used by this subroutine.

TABLE 10-1

PLAN14 OPERATING COMMANDS

<u>Digital Commands</u>	<u>Name</u>	<u>Action</u>
PR	Parameters	<ol style="list-style-type: none"> <li>1. Checks that the previous data file is closed.</li> <li>2. Requests the name of the data file to be accessed.</li> <li>3. Reads the title, input array, and status array from the specified file into memory.</li> <li>4. Decodes run time and scram time from the status array.</li> </ol>
T0	Title/Open	<ol style="list-style-type: none"> <li>1. Checks that the previous data file is closed.</li> <li>2. Requests file name, title, and maximum number of samples.</li> <li>3. Opens a data file.</li> <li>4. Initializes QIO parameters.</li> </ol>
OP	Open	<ol style="list-style-type: none"> <li>1. Same as T0 except, file name, title, and maximum number of samples is taken from memory.</li> </ol>
CH	Change	<ol style="list-style-type: none"> <li>1. Changes values in the input array by requesting index number and new values. Values can be inserted from the card reader or from the terminal.</li> </ol>
LI	List	<ol style="list-style-type: none"> <li>1. Lists on the printer the input array, status array, and, if a scram has occurred, run time, scram time, and scram type.</li> </ol>

TABLE 10-1 (continued)

<u>Digital Commands</u>	<u>Name</u>	<u>Action</u>
TR	Transient	<ol style="list-style-type: none"> <li>1. Requests the transient type as follows:               <ol style="list-style-type: none"> <li>1 - flow transient</li> <li>2 - not assigned</li> <li>3 - reactivity transient</li> <li>4 - feed valve transient</li> </ol> </li> <li>2. Initializes the transient logic variables.</li> </ol>
IC	Initial Condition	<ol style="list-style-type: none"> <li>1. Initializes the hybrid interface and analog console.</li> <li>2. Initializes the sample counter display.</li> <li>3. Pre computes steady state from inputted plant conditions. This provides for initialization and self check of the dynamic solution.</li> <li>4. Sets dots on analog console.</li> <li>5. Initializes the transient logic variables.</li> <li>6. Checks that a new data file is open.</li> </ol>
RN	Run	<ol style="list-style-type: none"> <li>1. Activates the main cycling program.</li> </ol>
DM	Dump	<ol style="list-style-type: none"> <li>1. Prints selected plant parameters.</li> </ol>
FD	Full Dump	<ol style="list-style-type: none"> <li>1. Same as DM plus printout of blank common is included.</li> </ol>

TABLE 10-1 (continued)

<u>Digital Commands</u>	<u>Name</u>	<u>Action</u>
SA	Save	<ol style="list-style-type: none"> <li>1. Encodes run time and scram time.</li> <li>2. Writes input and status arrays on the data file.</li> <li>3. Copies reader file onto the data file.</li> <li>4. Closes the data file.</li> </ol>
DS	Description/Save	<ol style="list-style-type: none"> <li>1. Same as SA, except program requests a description block which it adds to the title record.</li> </ol>
DE	Delete	<ol style="list-style-type: none"> <li>1. Deletes the data file from the disc.</li> </ol>
MC	MCR	<ol style="list-style-type: none"> <li>1. Issues a PAUSE command which allows operation of other system commands from the terminal.</li> <li>2. Execution of PLAN14 resumes when RES is entered on the terminal.</li> </ol>
EX	Exit	<ol style="list-style-type: none"> <li>1. Program execution is stopped.</li> </ol>
<u>Analog Controls</u>		
<u>DAP Switches</u>	<u>Variable Name</u>	<u>Action</u>
1	KNOHTR	<ol style="list-style-type: none"> <li>1. Inhibits pressurizer heater logic.</li> </ol>
2	ICONC	<ol style="list-style-type: none"> <li>1. Selects the boron concentration of the HPIS fluid: ON - borated water OFF - demineralized water</li> </ol>


TABLE 10-1 (continued)

Analog Controls

<u>DAP Switches</u>	<u>Variable Name</u>	<u>Action</u>
3	IZDP	1. Adds reactivity at 1¢/second.
4	ISCBP	1. Inhibits scram logic.
5	ISVRMP	1. Reduces steam valve ramp rate by 90%.
6	KHTR	1. Activates pressurizer start-up heaters.
7	ISMP	1. Initiates data recording and starts timer at zero. 2. Activates transient logic. 3. Enables scram logic.
8	ISMTD	1. Activates fast sample rate.
9	IZDM	1. Subtracts reactivity at 1¢/second.
10	ICPBP	1. Sets pressurizer boron concentration equal to the node 21 concentration.
11	KSCMN	1. Initiates a manual scram.
12	ID	1. Stops the cycling program and data recording.
13	KSPRA	1. Activates pressurizer spray.
14	KPOR	1. Activates power operated relief valve.
15	∠NSPPR	1. Inhibits pressurizer spray and power operated relief logic.

TABLE 10-1 (continued)

<u>Logic Switches</u>	<u>Variable Name</u>	<u>Action</u>
010 UP	IFLMN	1. Initiates manual flow transient.
011 UP	IDLZER	1. Holds analog integrators for the reactor kinetics and core thermal circuits in the IC mode. 2. Holds clad and steam generator temperatures at their pre-calculated steady state values. 3. Holds reactivity at zero.
011 DOWN	none	1. Resets the reactor kinetics circuitry.
110 UP	JINJ	1. Activates injection flow.
111 UP	JDRAIN	1. Activates drain flow.
112 UP	IOPMSV	1. Opens steam valve.
112 DOWN	ICLMSV	1. Closes steam valve.



INEL-B-13 933

FIGURE 10-2  
MAIN14 BLOCK DIAGRAM

REFERENCES

1. B. L. Ruston, "LOFT Core I, Computation of Parameters for the Reactor Kinetics Equations," LTR 111-53 (September 21, 1973).
2. Aerojet Nuclear Company, "RELAP4/MOD5: A Computer Program for Transient Thermal-Hydraulic Analysis of Nuclear Reactors and Related Systems, User's Manual," ANCR-NUREG-1335 (September 1976), Table III.
3. Proposed ANS 5.1 Standard, "Decay Energy Release Rates Following Shutdown of Uranium-Fueled Thermal Reactors," Revised June 1978.
4. K. Tasaka, "Fission Energy of U<sup>235</sup>, U<sup>238</sup>, and Pu<sup>239</sup> for LOFT Analysis," TAS-1-79 (January 12, 1979).
5. Aerojet Nuclear Company, "LOFT Integral Test System Design Basis Report, Final Draft," (January 1974).
6. TREE-1208, "LOFT System and Test Description (5.5 ft Nuclear Core 1 LOCEs)," NUREG/CR-0247 (July 1978).
7. S. Glasstone and A. Sesonske, "Nuclear Reactor Engineering," D. Van Nostrand Company, Inc., Princeton, New Jersey, (August 1962).
8. J. J. Feeley, "A Digital Simulation of the LOFT Reactor Coolant Loop Pumping System (SICLOPS)," LTR 1142-16 (August 24, 1977).
9. Lionel S. Marks, "Mechanical Engineers' Handbook," McGraw-Hill Book Company, Inc., New York, NY, 1949.
10. MPR Associates, Inc., letter to J. J. Feeley, "LOFT Project - Air Cooled Condenser Calculations," (July 10, 1974).
11. J. J. Feeley, "LOFT Air-Cooled Condenser Air Flow Test," LTR 115-25 (June 1977).
12. W. C. Townsend, "LOFT SCS Control Valve Characteristics," WCT-8-76 (November 2, 1976).
13. Moore Products Co., Dwg FRD-011, 5-12-66.
14. C. J. Hocesvar and T. W. Wineinger, THETA1-B, A Computer Code for Nuclear Reactor Core Thermal Analysis, IN-1445 (February 1971).
15. D. H. Stevenson and D. J. Hanson, "LOFT Overpressure Protection Report," LTR 1144-11 (May 16, 1972).
16. T. E. Young, "Energy Deposition in the LOFT Reactor at 54.71 MW", LTR 111-58, August 6, 1974.
17. "Design Information Report" (Unpublished GFE steam generator information notes).

APPENDIX APCS FLOW CALCULATIONS

## A.1 Solution of the Flow Network Equations

1. Given (Section 3.1.1)

$$H_L - H_C - W_C R_C - W_L R_L = 0$$

$$H_{BP} - H_C - W_C R_C + W_{BP} R_{BP} = 0$$

$$W_L = W_C + W_{BP}$$

2. Solve for
- $W_C$
- ,
- $W_{BP}$
- , and
- $W_L$
- .

3. In matrix form the equations are:

$$\begin{bmatrix} R_C & 0 & -R_L \\ R_C & -R_{BP} & 0 \\ 1 & 1 & 1 \end{bmatrix} \begin{bmatrix} W_C \\ W_{BP} \\ (-W_L) \end{bmatrix} = \begin{bmatrix} H_L - H_C \\ H_{BP} - H_C \\ 0 \end{bmatrix}$$

( $-W_L$  was used so that the flow network would be symmetrical.)

4. Determine the inverse of the R matrix

$$R^{-1} = \frac{\text{adj } R}{|R|}$$

$$R = \begin{vmatrix} R_C & 0 & -R_L \\ R_C & -R_{BP} & 0 \\ 1 & 1 & 1 \end{vmatrix} = -(R_C R_{BP} + R_L R_C + R_L R_{BP})$$

$$5. \text{adj } R = \begin{bmatrix} -R_{BP} & -R_C & (R_C + R_{BP}) \\ -R_L & (R_C + R_L) & -R_C \\ -R_L R_{BP} & -R_C R_L & -R_C R_{BP} \end{bmatrix}^T = - \begin{bmatrix} R_{BP} & R_L & R_L R_{BP} \\ R_C & -(R_C + R_L) & R_C R_L \\ -(R_C + R_{BP}) & R_C & R_C R_{BP} \end{bmatrix}$$

$$6. \begin{bmatrix} H_L - H_C \\ H_{BP} - H_C \\ 0 \end{bmatrix} = \begin{bmatrix} -1 & 0 & 1 \\ -1 & 1 & 0 \\ 0 & 0 & 0 \end{bmatrix} \begin{bmatrix} H_C \\ H_{BP} \\ H_L \end{bmatrix}$$

$$7. \begin{bmatrix} W_C \\ W_{BP} \\ (-W_L) \end{bmatrix} = \frac{-1}{|R|} \begin{bmatrix} R_{BP} & R_L & R_L R_{BP} \\ R_C & -(R_C + R_L) & R_C R_L \\ -(R_C + R_{BP}) & R_C & R_C R_{BP} \end{bmatrix} \begin{bmatrix} -1 & 0 & 1 \\ -1 & 1 & 0 \\ 0 & 0 & 0 \end{bmatrix} \begin{bmatrix} H_C \\ H_{BP} \\ H_L \end{bmatrix}$$

$$\begin{bmatrix} W_C \\ W_{BP} \\ (-W_L) \end{bmatrix} = \frac{-1}{|R|} \begin{bmatrix} -(R_{BP} + R_L) & R_L & R_{BP} \\ R_L & -(R_C + R_L) & R_C \\ R_{BP} & R_C & -(R_C + R_{BP}) \end{bmatrix} \begin{bmatrix} H_C \\ H_{BP} \\ H_L \end{bmatrix}$$

(note symmetry as a check of correctness)

$$8. W_C = \frac{-(R_{BP} + R_L) H_C + R_L H_{BP} + R_{BP} H_L}{R_C R_{BP} + R_L R_C + R_L R_{BP}}$$

$$W_{BP} = \frac{R_L H_C - (R_C + R_L) H_{BP} + R_C H_L}{R_C R_{BP} + R_L R_C + R_L R_{BP}}$$

$$W_L = \frac{-R_{BP} H_C - R_C H_{BP} + (R_C + R_{BP}) H_L}{R_C R_{BP} + R_L R_C + R_L R_{BP}}$$

## A.2 Derivation of the PCS Flow Resistances

1.  $H = kW^2$
2. LOFT Plant Data recorded during Power Range Testing, IP-01.07 Step 6.7.17, Att 8, Step 6.1, Natural Circulation Test 30 percent.

PLD 263:10:04:06 September 20, 1977

PDT-P139-030	Vessel $\Delta P$	= 24.6148 psid
PDE-PC-001	Pump $\Delta P$	= 68.6457 psid
FT-P139-27-1	PCS Flow	= 3.79162 MLBM/HR
TT-P139-32	Hot Leg Temp	= 544.1820F
PT-P139-002	Hot Leg Pres	= 2235.93 psig

3. Specific volume at 544.1820F and 2235.93 psig = .021176 ft<sup>3</sup>/lbm

$$4. \quad W = 3.79162 \times 10^6 \frac{\text{lbm}}{\text{hr}} \times .021176 \frac{\text{ft}^3}{\text{lbm}} \times \frac{\text{hr}}{3600 \text{ sec}}$$

$$= 22.3032 \text{ ft}^3/\text{sec}$$

5. Assume core flow is 95 percent of total.

$$W_C = (.95) (22.3032) = 21.1880 \text{ ft}^3/\text{sec}$$

6.  $k_C = 24.6148 \text{ psid}/(21.1880)^2 (\text{ft}^3/\text{sec})^2 = .05483 \text{ psi}/(\text{ft}^3/\text{sec})^2$

7. Assume core bypass flow is 5 percent of total.

$$W_{BP} = (.05) (22.3032) = 1.11516 \text{ ft}^3/\text{sec}$$

8.  $k_{BP} = 24.6148/(1.11516)^2 = 19.79347 \text{ psi}/(\text{ft}^3/\text{sec})^2$

9.  $k_L = (68.6457 - 24.6148)/(22.3032)^2$   
 $= .08852 \text{ psi}/(\text{ft}^3/\text{sec})^2$

10.  $2 k_C W_0 = (2) (.05483) (19) = 2.0835$

11.  $2 k_{BP} W_0 = (2) (19.79347) (1) = 39.5869$

12.  $2 k_L W_0 = (2) (.08852) (20) = 3.5408$

APPENDIX BPCS DENSITY APPROXIMATION

1. Density was calculated from the ASME Steam Table specific volume values at 2200 psia for each 20<sup>o</sup>F increment from 400<sup>o</sup>F to 640<sup>o</sup>F. See the data plotted on Figure B-1.
2. A second order least squares fit gave the following polynomial which is also plotted on Figure B-1.

$$\rho = 41.58 + 0.0890337T - 1.44741 \times 10^{-4} T^2$$

3. To find the dependence of the density on pressure  $\frac{\Delta\rho}{\Delta P}$  was tabulated over a pressure range of 1400 to 3000 psi at the following temperatures:

<u>T</u>	<u><math>\frac{\Delta\rho}{\Delta P}</math></u>
400	.000319
440	.000363
480	.000438
520	.000563
560	.000744
600	.001084 (pressure range 1800 - 3000 psi)
640	.001863 (pressure range 2200 - 3000 psi)

4. By inspection of the data (see Figure B-2) it was decided to use a least squares fit of the form:

$$\frac{\Delta\rho}{\Delta P} = 250 \times 10^{-6} + a e^{bx}$$

5. Evaluation of the coefficients yielded:

$$\frac{\Delta\rho}{\Delta P} = (250 + .389 e^{.01287T}) \times 10^{-6}$$

6. Combining the least squares temperature polynomial and the pressure correction formula gives:

$$\rho = 41.58 + 0.0890337T - 1.44741 \times 10^{-4} T^2 \\ + (P - 2200) (250 + .389 e^{.01287T}) \times 10^{-6}$$




FIGURE B-1

DENSITY AS A FUNCTION OF TEMPERATURE





FIGURE B-2

DERIVATIVE OF DENSITY WITH RESPECT TO PRESSURE  
AS A FUNCTION OF TEMPERATURE

APPENDIX CPRIMARY COOLANT NODE DESCRIPTIONSCore Nodes (1-4)1. Volume

R. L. Drexler's LOFT Volume Notes 4-17-79 give the volume for the 3 RELAP core nodes (53, 54, and 55) as:

53	3.3653
54	3.3843
55	<u>3.3923</u>

Total      10.1419 ft<sup>3</sup>

Water volume per LOFT node = 2.5355 ft<sup>3</sup>

2. Heat Capacity

$$\begin{aligned}
 C_p &= c_p \rho V \\
 &= (1.3191) (45.1467) (2.5355) \\
 &= 151.00 \text{ Btu/}^\circ\text{F}
 \end{aligned}$$

3. Wall Heat Capacity

The heat capacity of the core cladding is accounted for by the core thermal model, Section 2.4.

4. Heat Transfer Surface Area


$$A = 789.93 \text{ ft}^2 \quad (\text{Reference 6, Table V})$$

$$\text{Area per node} = 197.48 \text{ ft}^2$$

5. Heat Transfer Across Film

$$h_{DB} = 0.023 \frac{k}{D_H} Re^{0.8} Pr^{0.4} \quad (\text{Reference 7 Section 6.115})$$

$$D_H - \text{hydraulic diameter} = 4 \frac{\text{flow area}}{\text{wetted perimeter}} \quad (\text{Reference 7})$$



$$\text{fuel pin pitch} = 0.563 \text{ inches} \quad (\text{Reference 6 Table III})$$

$$\text{flow area} = 0.563^2 - \frac{\pi}{4} (0.422^2) = 0.1771 \text{ inches}^2$$

$$\text{perimeter} = \pi(0.422) = 1.3258 \text{ inches}$$

$$D_H = 0.5343 \text{ inches} = 0.04453 \text{ ft}$$

Reynolds Number

$$Re = \frac{\rho v D_H}{\mu} = \frac{\rho \dot{V} D_H}{A \mu}$$

$$\dot{V} = \text{reference flow} = 30.7640 \text{ ft}^3/\text{sec}$$

R. L. Drexler's Notes 4-17-79 give the following flow cross sections for the 3 RELAP core nodes (53, 54, and 55):

53	1.8460 ft <sup>2</sup>
54	1.8356 ft <sup>2</sup>
55	1.8504 ft <sup>2</sup>

$$\text{Average } A = 1.8440 \text{ ft}^2$$

Water properties from ASME 1967 Steam tables  
2250 psia and 575°F

$$\rho = 45.1467 \text{ lbm/ft}^3$$

$$\mu = 19.0875 \times 10^{-7} \frac{\text{lb} \cdot \text{sec}}{\text{ft}^2} \times 32.17 \text{ ft}^2/\text{sec} = 6.1404 \times 10^{-5} \text{ lbm/ft}$$

$$k = 0.3201 \text{ Btu/hr.ft.}^{\circ}\text{F} = 88.9167 \times 10^{-6} \text{ Btu/sec.ft.}^{\circ}\text{F}$$

$$P_r = 0.9292$$

$$Re = (45.1467) \left( \frac{30.7640}{1.8440} \right) (.04453) \left( \frac{1}{6.1404 \times 10^{-5}} \right) = 546,215$$

$$h_{DB} = (0.023) \frac{(88.9167 \times 10^{-6})}{(.04453)} (546,215)^{0.8} (0.9292)^{0.4}$$

$$= 1.7346 \text{ Btu/sec. ft}^2\text{.}^{\circ}\text{F}$$

$$H_{DB} = (1.7346) (197.48) = 342.55 \text{ Btu/sec}^{\circ}\text{F per node}$$

## 6. Structure Heat Transfer

Thermal conductivity

$$k = 7.51 + 2.09 \times 10^{-2} T - 1.45 \times 10^{-5} T^2 + 7.67 \times 10^{-9} T^3$$

k in W/m  $^{\circ}\text{K}$  and T in  $^{\circ}\text{K}$

$$\text{assume } T_{\text{clad}} = 655^{\circ}\text{F} : \quad \frac{655-32}{1.8} + 273.18 = 619.29^{\circ}\text{K}$$

$$k = 16.7138 \text{ W/m}^{\circ}\text{K} = 9.6571 \text{ Btu/hr ft}^{\circ}\text{F}$$

$$\text{Diameter} = 0.422 \text{ inches (Reference 6, Table III)}$$

$$\text{Thickness} = 0.0243 \text{ inches}$$

$$r_1 = 0.211 - \frac{0.0243}{2} = 0.19885$$

$$K = \frac{2\pi k h}{\ln \frac{r_2}{r_1}} N = \frac{(2\pi) (9.6571) \left( \frac{1}{3600} \right) (5.5) (1300)}{\ln \frac{0.211}{0.19885}}$$

$$K = 2031.99 \text{ Btu/sec }^{\circ}\text{F}$$

$$= 508.00 \text{ Btu/sec }^{\circ}\text{F per node}$$

(The simulation uses the value specified in the input array for this coefficient.)

7. Height

$$182.925 - 116.925 = 66''$$

$$= 5.5 \text{ ft}$$

$$= 1.3750 \text{ ft per node}$$

Steam Generator Tube Nodes (5-14)1. Volume

Dimensions from Reference 6 Table XII  
 Average tube length = 14.93 ft  
 Tube outside diameter = 0.50 inches  
 Nominal wall thickness = 0.049 inches  
 Number of Tubes = 1845

$$V = \frac{\pi}{4} D^2 L N = \frac{\pi}{4} (0.50 - 2 \times 0.049)^2 / 12^2 \times (14.93) \times (1845)$$

$$= 24.2793 \text{ ft}^3$$

$$= 2.4279 \text{ ft}^3 \text{ per node}$$

2. Heat Capacity

$$C_p = \rho V c_p = (45.1467) (2.4279) (1.3191)$$

$$= 144.59 \text{ Btu/}^\circ\text{F}$$

3. Wall Heat Capacity

The heat capacity of the steam generator secondary is accounted for in the steam generator model, Section 6.1.

4. Heat Transfer Surface Area

$$A = \pi D L N = \pi (0.402) / 12 \times (14.93) \times (1845)$$

$$= 2899.0 \text{ ft}^2$$

$$= 289.90 \text{ ft}^2 \text{ per node}$$

5. Heat Transfer Across Film

Reynolds Number

$$Re = \frac{\rho \dot{V} D_H}{A \mu} = \frac{\rho \dot{V}_{ref} D}{A \mu} = \frac{\rho \dot{V}_{ref}}{\frac{\pi}{4} D \mu}$$

$$Re = \frac{4(45.1467 \text{ lbm/ft}^3)(30.7640 \text{ ft}^3/\text{sec})}{\pi (0.0335 \text{ ft})(1845)(6.1404 \times 10^{-5} \text{ lbm/ft-sec})}$$

$$= 465,985$$

Dittus Boelter Heat Transfer Correlation

$$h_{DB} = .023 \frac{k}{D_H} Re^{0.8} Pr^{0.4}$$

$$= (.023) \frac{(88.9167 \times 10^{-6})}{0.0335} (465,985)^{0.8} (0.9292)^{0.4} = 2.0305 \text{ Btu/sec ft}^2 \text{ } ^\circ\text{F}$$

$$H_{DB} = (2.0305) (289.90) = 588.64 \text{ Btu/sec } ^\circ\text{F}$$

#### 6. Structure Heat Transfer

Heat transfer across tube for cylindrical geometry =  $\frac{2\pi k L N}{\ln(r_o/r_i)}$

$$k \text{ for Inconel 600} = 10.8 \text{ Btu/hr}\cdot\text{ft}\cdot^\circ\text{F}$$

$$= 0.003 \text{ Btu/sec}\cdot\text{ft}\cdot^\circ\text{F} \quad \text{Reference 6 Table XII}$$

$$K = \frac{2\pi (0.003) (14.93) (1845)}{\ln \frac{0.500}{0.402}} = 2380.1 \text{ Btu/sec } ^\circ\text{F}$$

Assume the heat transfer coefficient across the secondary film  
= 6000 Btu/hr·ft<sup>2</sup>·°F (See Reference 17)

Tube Area - Secondary Side

$$A = \pi D L N = \pi \left(\frac{.5}{12}\right) (14.93)(1845)$$

$$= 3605.7 \text{ ft}^2$$

$$\text{Total heat conductivity} = \left( \frac{1}{K} + \frac{1}{H_{Boil}} \right)^{-1}$$


$$= \left( \frac{1}{2380.1} + \frac{1}{\frac{6000}{3600} \times 3605.7} \right)^{-1} = 1704.9 \text{ Btu/sec } ^\circ\text{F}$$

$$= 170.49 \text{ Btu/sec } ^\circ\text{F/node}$$

(The simulation use the value specified in the input array for this coefficient.)

7. Height

Max height	107.5"	(Reference. 6 Table XV)
Min height	84.5"	
	$\frac{107.5 - 84.5}{192} \div 2$	$= 96" - 11.5" \text{ (height of tube sheet)}$
	$= 84.5"$	$= 7.0417 \text{ ft}$
	$= 1.4083 \text{ ft/node}$	

Upper Plenum Nodes 15 and 161. Volume

Drexler's upper plenum volume notes 2-21-79 starting on pg 747

Intermediate flow skirt area = 473.050 in<sup>2</sup>

Upper flow skirt area = 473.481 in<sup>2</sup>

(neglect bypass channels)

$$\begin{aligned} \text{Total Volume} &= (235.393-182.925) 473.05 + \\ &\quad (248.580-235.393) 473.481 = 31064 \text{ in}^3 \\ &= 17.9769 \text{ ft}^3 \end{aligned}$$

Page 807

Total displacement from 182.925 to 258.406 = 8408 in<sup>3</sup>

To adjust these displacement for our smaller volume

$$8408 \frac{248.580 - 182.925}{258.406 - 182.925} = 7313.5 \text{ in}^3 = 4.2323 \text{ ft}^3$$

$$\begin{aligned} \text{Water volume} &= 17.9769 \\ &\quad \underline{-4.2323} \end{aligned}$$

$$13.7449 \text{ ft}^3 = 6.8725 \text{ ft}^3 \text{ per node}$$

Internal Structure Volume

$$4.2323 \text{ ft}^3 = 2.1162 \text{ ft}^3 \text{ per node}$$

2. Heat Capacity

$$\begin{aligned} C_p &= (43.5777) (6.8725) (1.4058) + (495) (2.1162) (0.11) \\ &= 536.25 \text{ Btu/}^\circ\text{F} \end{aligned}$$

3. Wall Heat Capacity

$$\text{Height} = 248.58 - 182.925 = 65.655 \text{ in} = 5.4713 \text{ ft}$$

$$\text{Average cross section area} = \frac{17.9769}{5.4713} = 3.2857$$

$$\text{equiv dia } D = 2\sqrt{\frac{2.3857}{\pi}} = 2.0454 \text{ ft}$$

$$\text{assume core filler is } 0.75" \text{ thick - adds } 1.5" \text{ to dia} = 0.1250 \text{ ft}$$

$$V = \frac{\pi}{4} (2.1704^2 - 2.0454^2) 5.4713 = 2.2645 \text{ ft}^3$$

$$= 1.1323 \text{ ft}^3 \text{ per node}$$

$$C_p = (1.1323) (495) (0.11) = 61.6537 \text{ Btu/}^\circ\text{F}$$

4. Heat Transfer Surface Area

$$A = \pi D h = \pi (2.0454) (5.4713)$$

$$= 35.1576 \text{ ft}^2$$

$$= 17.5788 \text{ ft}^2 \text{ per node}$$

5. Heat Transfer Across Film

Reference 7 Section 6.117

$$h_{DB} = 0.148 (1 + 10^{-2}T - 10^{-5}T^2) \frac{v^{0.8}}{D^{0.2}}, \quad v \text{ in ft/hr and } D \text{ in ft}$$

$$h_{DB} = (0.5046) \frac{v^{0.8}}{D^{0.2}} \text{ for } T = 595^\circ\text{F}$$

$$\text{flow area (RLD's summary sheet)} = 2.5956 \text{ ft}^2$$

$$v = \frac{\dot{V}_{\text{ref}} \times 3600}{\text{flow area}} = \frac{30.7640 \times 3600}{2.5956} = 42,669 \text{ ft/hr}$$

$$h_{DB} = (0.5046) \frac{(42,669)^{0.8}}{(2.0454)^{0.2}} = 2212.5 \text{ Btu/hr ft}^2 \text{ }^\circ\text{F}$$

$$= 0.6146 \text{ Btu/sec ft}^2 \text{ }^\circ\text{F}$$

$$H_{DB} = (0.6146) (17.5788) = 10.8039 \text{ Btu/sec }^\circ\text{F}$$

6. Structure Heat Transfer

$$\begin{aligned}k \text{ for stainless steel} &= 14 \text{ Btu/hr ft } ^\circ\text{F} \\ &= 0.003889 \text{ Btu/sec ft } ^\circ\text{F}\end{aligned}$$


let  $L = 1/4$  the thickness of the slab

$$= 1/4 \frac{0.75}{12} = 0.01563 \text{ ft}$$

$$K = \frac{k A}{L} = \frac{(0.003889) (17.5788)}{0.01563} = 4.3739 \text{ Btu/sec } ^\circ\text{F}$$

7. Height

$$5.4713 \text{ ft} = 2.735 \text{ ft per node}$$

Upper Plenum Outlet Region - Node 171. Volume

R. L. Drexler's reactor vessel volume notes

From 248.58 to 252.74

cross section area = 479.91 inches<sup>2</sup> (pg 754)

volume = (479.91) (252.74 - 248.58) = 1996.4 in<sup>3</sup> = 1.1553 ft<sup>3</sup>

From 252.74 to 258.41 (transition area) (pg 806)

volumes 628.0 in<sup>3</sup>

645.0 in<sup>3</sup>

1260.0 in<sup>3</sup>

609.9 in<sup>3</sup>

3142.9 in<sup>3</sup> = 1.8188 ft<sup>3</sup>

From 258.41 to 269.59 (zone 2) (pg 803)

volume = 9967.9 in<sup>3</sup> = 5.7685 ft<sup>3</sup>

Total volume = 8.7426 ft<sup>3</sup>

zone 2 displacement = 1234 in<sup>3</sup> = 0.7141 ft<sup>3</sup> (pg 803)

zone 1 displacement which was not included in nodes 15 and 16

= 8408.0 - 7313.5 = 1094.5 in<sup>3</sup> = 0.6334 ft<sup>3</sup>

Total displacement = 1.3475 ft<sup>3</sup>

Water volume = 7.3951 ft<sup>3</sup>

2. Heat Capacity

$C_p = (43.5777) (7.3951) (1.4058) + (495) (1.3475) (0.11) = 526.41 \text{ Btu/}^\circ\text{F}$

3. Heat Transfer Surface Area

The node is approximated by 3 cylinders

$$\begin{aligned} \text{Volume of nozzles} &= 3075.4 \text{ in}^3 \text{ (includes both nozzles) (pg 802)} \\ &= 1.7797 \text{ ft}^3 \end{aligned}$$

$$\begin{aligned} \text{Length of nozzles} &= 1/2 (57.615 - 28.007) \\ &= 14.8040 \text{ in} \end{aligned}$$

$$\text{Nozzle diameter} = 11.5''$$

$$\begin{aligned} \text{Surface area of each nozzle} &= \pi DL \\ &= \pi (14.8040) (11.5) = 534.84 \text{ in}^2 \\ &= 3.7142 \text{ ft}^2 \end{aligned}$$

$$\begin{array}{r} \text{volume of node} \quad 8.7426 \\ \text{less volume of nozzles} \quad \underline{1.7797} \end{array}$$

$$\text{Volume of barrel} \quad 6.9629 \text{ ft}^3$$

$$\begin{aligned} \text{Height} &= 21.01'' = 1.7508 \text{ ft} \\ \text{ave barrel cross section} &= 3.9770 \text{ ft}^2 \end{aligned}$$

$$\text{equiv dia} = 2\sqrt{\frac{A}{\pi}} = 2.2503 \text{ ft}$$

$$\text{barrel surface area} = \pi Dh = 12.3773 \text{ ft}^2$$

$$\text{less area of nozzle} = \frac{\pi}{4} D^2 \times 2 = \frac{1.4426 \text{ ft}^2}{10.9347 \text{ ft}^2}$$

$$\begin{array}{r} \text{Total surface area} \quad 10.9347 \\ \quad \quad \quad \quad \quad \quad 3.7142 \\ \quad \quad \quad \quad \quad \quad \underline{3.7142} \\ \quad \quad \quad \quad \quad \quad 18.3631 \text{ ft}^2 \end{array}$$

4. Wall Heat Capacity

Assume surface is a slab 0.75" thick

$$V = 18.3631 \text{ ft}^2 \times \frac{0.75}{12} \text{ ft} = 1.1477 \text{ ft}^3$$

$$C_p = (1.1477) (495) (0.11) = 62.4923 \text{ Btu/sec}^\circ\text{F}$$

5. Heat Transfer Across Film

$$h_{DB} \text{ (same as nodes 15 and 16)} = 0.6146 \text{ Btu/sec ft}^2 \text{ } ^\circ\text{F}$$

$$H_{DB} = (0.6146) (18.3631) = 11.2860 \text{ Btu/sec } ^\circ\text{F}$$

6. Structure Heat Transfer

$$L = 0.01563 \text{ ft (same as nodes 15 and 16)}$$

$$A = 18.3631 \text{ ft}^2$$

$$k = .003889 \text{ Btu/sec ft}^2 \text{ } ^\circ\text{F}$$

$$\frac{kA}{L} = 4.5690 \text{ Btu/sec } ^\circ\text{F}$$

7. Height

$$21.01" = 1.7508 \text{ ft}$$

Upper Plenum Bypass - Node 18

Node extends from the top of the nozzles (STA 269.59) to the top of the CRDM's.

1. Volume

R. L. Drexler's notes

Water Volume = 12.30 ft<sup>3</sup> (page 821)

Displacements 32,224 in<sup>3</sup> = 18.6481 ft<sup>3</sup> (pg 785)

less spacers 4635 in<sup>3</sup> (pg 785)

and fillers 6614 in<sup>3</sup>

2555 in<sup>3</sup>

13,804 in<sup>3</sup>

= 7.9884 ft<sup>3</sup>

Internal structure volume

10.6597 ft<sup>3</sup>

2. Heat Capacity

$$C_p = (43.5777) (12.30) (1.4058) + (495) (10.6597) (0.11) \\ = 1333.94 \text{ Btu/}^\circ\text{F}$$

3. Heat Transfer Surface Area

Assume a cylinder which extends from 269.59 to 300.00.

Height = 30.41" = 2.5342 ft

Active Volume = Envelope - Spacers

= 37336 - 13804 (pg 821)

= 23532 in<sup>3</sup> = 13.6181 ft<sup>3</sup>

$$\text{Equiv dia} = 2\sqrt{\frac{V}{\pi h}} = 2\sqrt{\frac{13.6181}{\pi \cdot 2.5342}} = 2.6157 \text{ ft}$$

$$\text{Surface area} = \pi dh + \frac{\pi}{4} d^2 = 26.1983 \text{ ft}^2$$

4. Wall Heat Capacity

Assume 2" slab

$$V = 26.1983 \text{ ft}^2 \times \frac{2}{12} \text{ ft} = 4.3664 \text{ ft}^3$$

$$C_p = (495) (4.3664) (0.11) = 237.75 \text{ Btu/}^\circ\text{F}$$

### 5. Heat Transfer Across Film

Assume flow channel equals half of available free space.

$$\frac{\text{Structure vol}}{\text{Active vol}} = \frac{10.6597}{13.6181} = 78.28 \text{ percent of the volume is blocked.}$$

$$\text{Flow channel area} = (1 - .7828) \times 1/2 \times \text{cross section} = \frac{0.2172}{2} \times \frac{\pi}{4} \times 2.6157^2$$

$$= 0.5836 \text{ ft}^2$$

$$D = 2\sqrt{\frac{0.58326}{\pi}} = 0.8620 \text{ ft}$$

$$h_{DB} = (0.5046) \frac{v^{0.8}}{D^{0.2}}, \quad v = \frac{30.7640 \times 3600}{0.5836}$$

$$h_{DB} = 8678.2 \text{ Btu/hr ft}^2 \text{ }^\circ\text{F} = 2.4106 \text{ Btu/sec ft}^2 \text{ }^\circ\text{F}$$

$$H_{DB} = (2.4106) (26.1983) = 63.1536 \text{ Btu/sec }^\circ\text{F}$$

### 6. Surface Heat Transfer

assume 2" slab

$$L = \frac{1}{4} \frac{2}{12} = 0.04167$$

$$A = 26.1983$$

$$k = 0.003889 \text{ Btu/sec ft }^\circ\text{F}$$

$$\frac{kA}{L} = 2.4450 \text{ Btu/sec }^\circ\text{F}$$

Hot Leg Nodes 19-31. Volume

These nodes correspond to RELAP Nodes 3, 4, 5, and 6.  
From R. L. Drexler's loop volumes notes:

Node	<u>Vol</u>	÷	<u>Flow Area</u>	=	<u>Length</u>
3	2.92940		0.6827		4.2909
4	6.03149		0.6827		8.8348
5	3.27072		0.6827		4.7909
6	<u>1.55642</u>		0.8953		<u>1.7384</u>
	13.78803 ft <sup>3</sup>				19.6550 ft

$$\text{vol/node} = 2.7576 \text{ ft}^3$$

$$\text{equiv. dia} = 2\sqrt{\frac{V}{\pi L}} = 0.9451 \text{ ft}$$

2. Heat Capacity

$$C_p = (43.5777) (2.7576) (1.4058) = 168.93 \text{ Btu/}^\circ\text{F}$$

3. Wall Heat Capacity

14" Sch 160 pipe thickness 1.4" = 0.1167 ft      outside dia = 1.1784 ft

$$V = \frac{\pi}{4} (1.1784^2 - 0.9451^2) (19.6550) = 7.6477 \text{ ft}^3$$

$$\text{vol/node} = 1.5295 \text{ ft}^3$$

$$C_p = (1.5295) (495) (0.11) = 83.2813 \text{ Btu/}^\circ\text{F}$$

4. Heat Transfer Area

$$\pi DL = 58.3580 \text{ ft}^2$$

$$\text{area/node} = 11.6716 \text{ ft}^2$$

5. Heat Transfer Across Film

$$h_{DB} = \frac{0.5046}{D^{0.2}} v^{0.8}; v = \frac{30.7640 \times 3600}{\frac{\pi}{4} (0.9451)^2}, D = 0.9451$$

$$h = 7353.5 \text{ Btu/hr ft}^2 \text{ } ^\circ\text{F} = 2.0426 \text{ Btu/sec ft}^2 \text{ } ^\circ\text{F}$$

$$H_{DB} = (2.0426) (11.6716) = 23.8404 \text{ Btu/sec } ^\circ\text{F}$$

6. Heat Transfer Across Surface

$$\frac{kA}{L} = \frac{(0.003889) (11.6716)}{\frac{1}{4} \left( \frac{1.4}{12} \right)} = 1.5563 \text{ Btu/sec } ^\circ\text{F}$$

Steam Generator Inlet and Outlet Plenums - Nodes 24 and 271. Volume11.8447 ft<sup>3</sup> (Reference 6 Table XV)2. Heat Capacity

Hot leg

$$C_p = (43.5777) (11.8447) (1.4058) = 725.62 \text{ Btu/}^\circ\text{F}$$

Cold leg

$$C_p = (46.5333) (11.8447) (1.2577) = 693.21 \text{ Btu/}^\circ\text{F}$$

3. Heat Transfer Surface Area

Assume S/G plenums are sections of a sphere.

eqv. dia:

$$\frac{1}{4} \left( \frac{4}{3} \pi r^3 \right) = 11.8447$$

$$r = 2.2447 \text{ ft}$$

$$\frac{1}{4} \text{ area of sphere} = \frac{1}{4} \pi D^2 = \pi r^2 = 15.8295 \text{ ft}^2$$

(Tube sheet surface is included in next node.)

Assume partition surface and piping opening areas cancel.

4. Wall Heat Capacity

Assume 2" slab

$$15.8295 \text{ ft}^2 \times \frac{2}{12} \text{ ft} = 2.6383 \text{ ft}^3 \quad (\text{Use } C_p \text{ for stainless steel}$$

neglect Inconel clad.)

$$C_p = (2.6383) (495) (0.11) = 143.66 \text{ Btu/}^\circ\text{F}$$

5. Heat Transfer Across Film

$$\text{Hot leg} \quad h_{DB} = \frac{0.5046}{D^{0.2}} v^{0.8}$$

use average v and D

$$v \text{ in tubes} = \frac{30.7640 \times 3600}{\frac{.127}{144} \times 1845} = 68,062 \text{ ft/hr}$$

Reference 6 Table XV

$$v_{\text{inlet pipe}} = \frac{30.7640 \times 3600}{.8955} = 123,674 \text{ ft/hr}$$

$$v_{\text{ave}} = 95,868 \text{ ft/hr} \quad \text{16" sch 160 pipe}$$

$$95,868 = \frac{30.7640 \times 3600}{\frac{\pi}{4} D^2}$$

$$D = 1.2128 \text{ ft}$$

$$h_{\text{DB}} = \frac{0.5046}{(1.2128)^{0.2}} (95868)^{0.8} = 4693.8 \text{ Btu/hr ft}^2 \text{ } ^\circ\text{F}$$

$$= 1.3038 \text{ Btu/sec ft}^2 \text{ } ^\circ\text{F}$$

$$H_{\text{DB}} = (1.3038) (15.8295) = 20.6385 \text{ Btu/sec } ^\circ\text{F}$$

Cold leg

$$h_{\text{DB}} = 0.148 \left( 1 + \frac{T}{10^2} - \frac{T^2}{10^5} \right) \frac{v^{0.8}}{D^{0.2}}$$

$$h_{\text{DB}} = 0.5135 \frac{v^{0.8}}{D^{0.2}} \text{ for } T = 555^\circ\text{F}$$

$$v = \frac{V_{\text{ref}}}{\frac{\pi}{4} D^2}$$

$$\frac{v^{0.8}}{D^{0.2}} = \left( \frac{4V_{\text{ref}}}{\pi} \right)^{0.8} \frac{1}{D^{1.8}}$$

$$h_{\text{DB}} = 0.5135 \left( \frac{4}{\pi} 30.7640 \times 3600 \right)^{0.8} \frac{1}{D^{1.8}}$$

$$h_{\text{DB}} = \frac{6760.0}{D^{1.8}} \text{ Btu/hr ft}^2 \text{ } ^\circ\text{F} = \frac{1.8778}{D^{1.8}} \text{ Btu/sec ft}^2 \text{ } ^\circ\text{F}$$

$$\text{for } D = 1.2128 \text{ ft}$$

$$h_{\text{DB}} = 1.3269 \text{ Btu/sec ft}^2 \text{ } ^\circ\text{F}$$

$$H_{\text{DB}} = (1.3269) (15.8295) = 21.0042 \text{ Btu/sec } ^\circ\text{F}$$

6. Structure Heat Transfer

k for Inconel = 0.003 Btu/sec ft °F

$$L = 1/4 \frac{2}{12} = .04167 \text{ ft}$$

$$\frac{kA}{L} = 1.1396 \text{ Btu/sec } ^\circ\text{F}$$

7. Height

2'7" (Ref. 6, Fig. 87 Section AA) = 2.5833 ft

Steam Generator Tube Sheet Nodes 25 and 261. Volume3.12 ft<sup>3</sup> (Reference 6 Table XV)Volume per node = 1.56 ft<sup>3</sup>2. Heat Capacity

Hot leg

$$C_p = (43.5777) (1.56) (1.4058) = 95.5680 \text{ Btu/}^\circ\text{F}$$

Cold leg

$$C_p = (46.5333) (1.56) (1.2577) = 91.2939 \text{ Btu/}^\circ\text{F}$$

3. Heat Transfer Surface Area

(Dimensions from Reference 6, Table XV)

Tube OD 0.50"

Thickness 0.049"

Number of tubes 1845

Thickness of tube Sheet 11.5"

$$\text{tube ID} = (.500 - 2 \times 0.049) = 0.402"$$

$$A = \pi DhN = \frac{\pi (0.402) (11.5) (1845)}{144} = 186.08 \text{ ft}^2$$

4. Wall Heat Capacity

Tube bundle dia 48" (Reference 6 Table XV)

$$V = 1/2 \left( \frac{\pi}{4} D^2 h \right) - V_{\text{Tubes}} = 1/2 \left[ \frac{\pi}{4} \left( \frac{48^2}{12} \right) \frac{11.5}{12} \right] - 1.5600$$

$$= 4.4614 \text{ ft}^3$$

$$C_p = (495) (4.4614) (0.11) = 242.92 \text{ Btu/}^\circ\text{F}$$

5. Heat Transfer Across Film

Hot Leg

$$h_{DB} = (.5046) \frac{v^{0.8}}{D^{0.2}}$$

v in tubes from node 24 calculations = 68,062 ft/hr

$$D = \frac{0.402''}{12} = 0.03350 \text{ ft}$$

$$h_{DB} = 7315.8 \text{ Btu/hr ft}^2 \text{ } ^\circ\text{F} = 2.0322 \text{ Btu/sec ft}^2 \text{ } ^\circ\text{F}$$

$$H_{DB} = (2.0322) (186.08) = 378.15 \text{ Btu/sec } ^\circ\text{F}$$

Cold Leg

$$h_{DB} = \frac{(0.5135)}{3600} \frac{v^{0.8}}{D^{0.2}} = 2.0680 \text{ Btu/sec ft}^2 \text{ } ^\circ\text{F}$$

$$H_{DB} = (2.0680) (186.08) = 384.81 \text{ Btu/sec } ^\circ\text{F}$$

#### 6. Structure Heat Transfer

$$\text{Area of tube sheet on inlet side} = 1/2 \frac{\pi}{4} D^2$$

$$= \frac{\pi}{8} \left(\frac{48}{12}\right)^2 = 2\pi = 6.2832 \text{ ft}^2$$

$$\text{Equivalent area surrounding each tube} = \frac{6.2832}{1845}$$

$$= 0.003406 \text{ ft}^2 = 0.4905 \text{ in}^2$$

$$\text{Equivalent diameter} = 2\sqrt{\frac{0.4905}{\pi}} = 0.7903 \text{ in}$$

$$k \text{ for Inconel} = 0.003 \text{ Btu/sec ft } ^\circ\text{F}$$

$$K = \frac{2 \pi k h N}{\ln \frac{d_2}{d_1}} = \frac{2 \pi (0.003) \frac{11.5}{12} N}{\ln \frac{0.7903}{0.402}} = 49.3052 \text{ Btu/sec } ^\circ\text{F}$$

#### 7. Height

$$11.5'' = .9583 \text{ ft}$$

Cold Leg Nodes 28-311. Volume

These nodes correspond to RELAP nodes 12, 13, and 14. R. L. Drexler's loop volume notes.

<u>Node</u>	<u>Vol</u>	$\div$	<u>Flow Area</u>	=	<u>Length</u>
12	2.021910		0.895285		2.2584
13	3.947661		0.682704		5.7824
14	6.035087		0.682704		8.8400
	<u>12.004658</u>				<u>16.8808</u>

$$\text{vol/node} = 3.0012 \text{ ft}^3$$

2. Heat Capacity

$$C_p = (46.5333) (3.0012) (1.2577) = 175.65 \text{ Btu/}^\circ\text{F}$$

3. Heat Transfer Surface Area

$$\text{eqv. dia} = 2\sqrt{\frac{V}{\pi L}} = 0.9516 \text{ ft}$$

$$A = \pi dL = 50.4658 \text{ ft}^2$$

$$= 12.6165 \text{ ft}^2 \text{ per node}$$

4. Wall Heat Capacity

$$14'' \text{ sch 160 pipe thickness} = 0.1167 \text{ ft}$$

$$\text{outside diameter} = 0.95156 + 2(0.1167) = 1.1850 \text{ ft}$$

$$V = \frac{\pi}{4} (1.1850^2 - 0.9516^2) (16.8808) = 6.6116 \text{ ft}^3$$

$$= 1.6529 \text{ ft}^3 \text{ per node}$$

$$C_p = (495) (1.6529) (0.11) = 90.0004 \text{ Btu/}^\circ\text{F}$$

5. Heat Transfer Across Film

$$h_{DB} = \frac{1.8778}{D^{1.8}} = 2.0532 \text{ Btu/sec ft}^2 \text{ }^\circ\text{F}$$

$$H_{DB} = (2.0532) (12.6165) = 25.9042 \text{ Btu/sec }^\circ\text{F}$$

6. Structure Heat Transfer

$$\frac{kA}{L} = \frac{(0.003889)(12.6165)}{\frac{1}{4} \left(\frac{1.4}{12}\right)} = 1.6822 \text{ Btu/sec } ^\circ\text{F}$$

7. Height

Reference 6, Figure 83 and Table XIII

$$\begin{array}{l} \text{drop} = \frac{1' 2''}{1' 8''} \\ \qquad \qquad \frac{2' 10''}{2' 10''} \end{array} = 2.8333 \text{ ft} \quad \text{node 28}$$

$$\begin{array}{l} \text{rise} \quad \frac{1' 1''}{1' 0''} \\ \qquad \qquad \frac{2' 1''}{2' 1''} \end{array} = 2.0833 \text{ ft} \quad \text{node 31}$$

Primary Coolant Pumps Nodes 32 and 33

These nodes are not connected in parallel as are the actual PCP's. The properties of the pumps are lumped together and then split into two equal nodes in series.

1. Volume

3.5 ft<sup>3</sup> per node (Reference 6 Table XVII)

2. Heat Capacity

$$C_p = (46.5333) (3.5) (1.2577) = 204.8373 \text{ Btu/}^\circ\text{F}$$

3. Heat Transfer Surface Area

Assume the volume is contained in a 10" pipe

$$\begin{aligned} \text{of inside diameter} &= 0.7 \text{ ft} \\ \text{and outside diameter} &= 0.9 \text{ ft} \end{aligned}$$

$$A = \pi DL; \quad L = \frac{V}{\frac{\pi}{4} D^2} = 9.0946 \text{ ft}$$

$$A = 4 \frac{\pi DV}{\pi D^2} = 4 \frac{V}{D} = 4 \frac{3.5}{0.7} = 20.0000 \text{ ft}^2$$

4. Wall Heat Capacity

$$V = \frac{\pi}{4} (0.9^2 - 0.7^2) (9.0946) = 2.2857 \text{ ft}^3$$

$$C_p = (495) (2.2857) (0.11) = 124.46 \text{ Btu/}^\circ\text{F}$$

5. Heat Transfer Across Film

$$h_{DB} = \frac{1.8778}{D^{1.8}} \times (0.5)^{0.8} = 2.0495$$

accounts for the flow split

$$H_{DB} = (2.0495) (20.0000) = 40.9900 \text{ Btu/sec } ^\circ\text{F}$$

6. Structure Heat Transfer

$$\frac{kA}{L} = \frac{(0.003889)(20.0000)}{\frac{1}{4} 0.1} = 3.1112 \text{ Btu/sec } ^\circ\text{F}$$

7. Height

Assume 9" rise (0.75 ft). This accounts for the difference in the cold leg piping so that the net elevation change equals zero.

Cold Leg Nodes 34-371. Volume

These nodes correspond to RELAP nodes 17 thru 21.

R. L. Drexler's Loop Volume Notes

<u>Node</u>	<u>Vol</u>	÷	<u>Flow Area</u>	=	<u>Length</u>
17	1.553076		0.394063		3.9412
18	0.515827		0.394063		1.3090
19	6.463449		0.682704		9.4674
20	1.348992		0.682704		1.9760
21	1.572665		0.682704		2.3036
	<u>11.54009</u>				<u>18.9972</u>

$$\text{vol/node} = 2.8635 \text{ ft}^3$$

2. Heat Capacity

$$C_p = (46.5333) (2.8635) (1.2577) = 167.59 \text{ Btu/}^\circ\text{F}$$

3. Heat Transfer Surface Area

$$\text{eqv. dia} = 2 \sqrt{\frac{V}{\pi L}} = 0.8762$$

$$A = \pi DL = 52.2929 \text{ ft}^2$$

$$= 13.0732 \text{ ft}^2 \text{ per node}$$

4. Wall Heat Capacity

14" sch 160 pipe thickness = 0.1167 ft  
 outside dia =  $0.8762 + 2 (0.1167) = 1.1096 \text{ ft}$

$$V = \frac{\pi}{4} (1.1096^2 - 0.8762^2) (18.9972)$$

$$= 6.9154 \text{ ft}^3$$

$$\text{vol/node} = 1.7289 \text{ ft}^3$$

$$C_p = (495) (1.7289) (0.11) = 94.1386 \text{ Btu/}^\circ\text{F}$$

5. Heat Transfer Across Film


$$h_{DB} = \frac{1.8778}{0.1.8} = 2.3821 \text{ Btu/sec ft}^2 \text{ } ^\circ\text{F}$$

$$H_{DB} = (2.3821) (13.0732) = 31.1417 \text{ Btu/sec } ^\circ\text{F}$$

6. Structure Heat Transfer

$$\frac{kA}{L} = \frac{(.003889) 13.0732}{\frac{1}{4} 0.1167} = 1.7426 \text{ Btu/sec } ^\circ\text{F}$$

Reactor Vessel Flow Distributor Node 38



This node is modeled as two concentric annuluses and corresponds to RELAP nodes 22 and 25.



Annulus between vessel ID and filler

From R. L. Drexlers notes:

$$\begin{aligned}
 \text{flow area} &= 0.31334 \text{ ft}^2 \\
 \text{height} &= 52.70" = 4.3917 \text{ ft} \\
 \text{ave. dia} &= (57.2 + 57.7)/2 \\
 &= 57.45" = 4.7875 \text{ ft} \\
 \text{vol} &= (0.31334)(4.3917) \\
 &= 1.3761 \text{ ft}^3
 \end{aligned}$$

Distributor ring

$$\text{Height} = (277.12 - 247.30) = 29.82" = 2.4850 \text{ ft}$$

$$\text{ID} = 33" = 2.7500 \text{ ft}$$

$$\text{Define OD such that vol} = 9.6515 - 1.3761 = 8.2754 \text{ ft}^3$$

$$V = \frac{\pi}{4} (\text{OD}^2 - \text{ID}^2) h$$

$$\text{OD} = \sqrt{\frac{4V}{\pi h} + \text{ID}^2} = \sqrt{\frac{4(8.2754)}{\pi(2.4850)} + 2.7500^2} = 3.4355 \text{ ft}$$

$$\text{flow area} = \frac{V}{h} = \frac{8.2754}{2.4850} = 3.3301 \text{ ft}^2$$

1. Volume

R. L. Drexler's notes 4-17-79 give the volume as 9.6515 ft<sup>3</sup>

2. Heat Capacity

$$C_p = (46.5333) (9.6515) (1.2577) = 564.85 \text{ Btu/CF}$$

3. Heat Transfer Surface Area

Outer Annulus

$$\begin{aligned} A &= 2 \pi D_h = 2 \pi (4.7875) (4.3917) \\ &= 132.11 \text{ ft}^2 \end{aligned}$$

Distributor Ring

$$A = \pi (OD) h + \pi (ID) h$$

$$A = \pi (3.4355) (2.4850) + \pi (2.7500) (2.4850)$$

$$A = 26.8205 + 21.4689 = 48.2894 \text{ ft}^2$$

4. Wall Heat Capacity

Assume 2" slab except for core barrel which is only 1.5" thick.

$$\left(\frac{2}{12}\right) (132.11 + 26.8205) + \left(\frac{1.5}{12}\right) (21.4689) = 29.1720 \text{ ft}^3$$

$$C_p = (29.1720) (495) (0.11) = 1588.4 \text{ Btu/OF}$$

5. Heat Transfer Across Film

$$v = \frac{\dot{V}_{\text{ref}} \times 3600}{0.31334 + 3.3301} = 30,397 \text{ ft/hr}$$

Outer Annulus

$$D_H = 4 \frac{\text{area}}{\text{perim}} = 4 \frac{0.31334}{2 \pi 4.7875} = 0.04167 \text{ ft}$$

$$h_{DB} = \frac{0.5135}{3600} \frac{v^{0.8}}{D_H^{0.2}} = 1.0388 \text{ Btu/sec ft}^2 \text{ OF}$$

Distributor ring

$$D_H = 4 \frac{3.3301}{\pi (2.7500 + 3.4355)} = 0.6855 \text{ ft}$$

$$h_{DB} = \frac{0.5135}{3600} \frac{v^{0.8}}{D^{0.2}} = 0.5933 \text{ Btu/sec ft}^3 \text{ } ^\circ\text{F}$$

$$H_{DB} = (132.11) (1.0388) + (48.2894) (0.5933) = 165.89 \text{ Btu/sec } ^\circ\text{F}$$

6. Structure Heat Transfer

$$\frac{kA}{L} = \frac{(0.003889)}{\left(\frac{1}{4}\right) \left(\frac{1}{12}\right)} \left( \frac{158.93}{2} + \frac{21.4689}{1.5} \right) = 17.5057 \text{ Btu/sec } ^\circ\text{F}$$

7. Height

$$269.59'' - 247.30'' = 22.29'' = 1.8575 \text{ ft}$$

Downcomer Nodes 39-43

These nodes include the downcomer and outer annulus between station 247.30 and 96.437. These correspond to RELAP4 nodes 23, 24, 26, and 27. See Reference 6, Figure 78 for geometry.

1. Volume

From R. L. Drexler's Reactor Vessel Volume notes.

$$\begin{array}{r} 2 \times 5.8104 \quad (\text{nodes 23 and 26}) \\ + 2 \times 6.8762 \quad (\text{nodes 24 and 27}) \end{array}$$

$$25.3732 \text{ ft}^3$$

$$\text{vol/node} = 5.0746 \text{ ft}^3$$

2. Heat Capacity

$$C_p = (46.5333) (5.0746) (1.2577) = 296.99 \text{ Btu/}^\circ\text{F}$$

3. Heat Transfer Surface Area

These nodes are modeled similar to Node 38.

Outer Annulus	height	=	150.863"	=	12.5719 ft
	vol	=	(0.31334) (12.5719)	=	3.9393 ft <sup>3</sup>
	area	=	2 $\pi$ (4.7875) (12.5719)	=	378.17 ft <sup>2</sup>

Downcomer	Vol	=	25.3732 - 3.9393	=	21.4339 ft
-----------	-----	---	------------------	---	------------

$$\text{OD} = \sqrt{\frac{4V}{\pi h} + \text{ID}^2} = 3.1198 \text{ ft}$$

$$\begin{aligned} A &= \pi (3.1198) (12.5719) + \pi (2.7500) (12.5719) \\ &= 123.22 + 108.61 = 231.83 \text{ ft}^2 \end{aligned}$$

4. Wall Heat Capacity

Assume 2" slab except for core barrel which is only 1.5" thick.

$$\left(\frac{2}{12}\right) (378.17 + 123.22) + \frac{1.5}{12} (108.61) = 97.1413 \text{ ft}^3$$

$$C_p = (495) (97.1413) (0.11)/5 = 1057.87 \text{ Btu/}^\circ\text{F}$$

5. Heat Transfer Across Film

$h_{DB}$  in annulus same as node 38 = 1.0388 Btu/sec ft<sup>2</sup> °F

Downcomer

$$\text{flow area} = \frac{V}{h} = 1.7049 \text{ ft}^2$$

$$v = (30397) \frac{3.3301}{1.7049} = 59373 \text{ ft/hr}$$

$$D_H = 4 \frac{1.7049}{\pi (2.7500 + 3.1198)} = 0.3698$$

$$h_{DB} = \frac{0.5135}{3600} \frac{v^{0.8}}{D^{0.2}} = 1.1469 \text{ Btu/sec ft}^2 \text{ °F}$$

$$H_{DE} = \left[ (378.17) (1.0388) + (231.83) (1.1469) \right] / 5 = 131.75 \text{ Btu/sec °F}$$

6. Structure Heat Transfer

$$\frac{kA}{L} = \frac{0.003889}{\left(\frac{1}{4}\right) \left(\frac{1}{12}\right)} \left[ \frac{501.39}{2} + \frac{108.61}{1.5} \right] = 60.3140 \text{ Btu/sec °F}$$

12.0628 Btu/sec °F per node

7. Height

$$12.5719 / 5 = 2.5144 \text{ ft}$$

Lower Plenum Nodes 44-46

These nodes are modeled as a cylinder of diameter 37". They correspond to RELAP volumes 28 and 29.

1. Volume

From R. L. Drexler's Reactor Vessel Volume notes

$$\begin{array}{r} 28 \quad 18.96 \\ 29 \quad 4.7609 \\ \hline \text{Total Vol.} \quad 23.7209 \text{ ft}^3 \\ \\ = 7.9070 \text{ ft}^3 \text{ per node} \end{array}$$

2. Heat Capacity

$$C_p = (46.5333) (7.9070) (1.2577) = 462.76 \text{ Btu/}^\circ\text{F}$$

3. Heat Transfer Surface Area

$$\text{Cross section area} = \frac{\pi}{4} D^2 = 7.4667 \text{ ft}^2$$

$$\text{Eqv height} = \frac{V}{A} = \frac{23.7209}{7.4667} = 3.1769 \text{ ft}$$

$$\text{Wall area} = \pi Dh = 30.7733 \text{ ft}^2$$

$$\begin{aligned} \text{Total area} &= 38.2400 \text{ ft}^2 \\ &= 12.7467 \text{ ft}^2 \text{ per node} \end{aligned}$$

4. Wall Heat Capacity

Assume 2" slab

$$V = 12.7467 \times \frac{2}{12} = 2.1245 \text{ ft}^3$$

$$C_p = (2.1245) (495) (0.11) = 115.68 \text{ Btu/}^\circ\text{F}$$

5. Heat Transfer Across Film

$$h_{DB} = \frac{1.8778}{0.1.8} = 0.2474 \text{ Btu/sec ft}^2 \text{ } ^\circ\text{F}$$

$$H_{DB} = (0.2474) (12.7467) = 3.1535 \text{ Btu/sec } ^\circ\text{F}$$

6. Structure Heat Transfer

$$\frac{kA}{L} = \frac{(0.003889) (12.7467)}{\frac{1}{4} \left(\frac{2}{12}\right)} = 1.1897 \text{ Btu/sec } ^\circ\text{F}$$

7. Height

$$\frac{116.925}{-96.437} = \frac{20.488''}{1} = 1.7073 \text{ ft lumped into node 46}$$

RABV Nodes 47 and 50

Each of these nodes includes the volume from the reactor vessel nozzle to the 14x14x10 tee.

1. Volume

Volume of reactor vessel nozzle and 45 elbow	1.8294 ft <sup>3</sup>	(R. L. Drexler's notes)
Volume of tee	1.4495 ft <sup>3</sup>	(R. L. Drexler's notes)
Total Volume each node	3.2779 ft <sup>3</sup>	

2. Heat Capacity

$$C_p = (45.1467) (3.2779) (1.3191) = 195.21 \text{ Btu/}^\circ\text{F}$$

3. Heat Transfer Surface Area

for 14" Sch. 160	OD 14.000" = 1.1667 ft
	ID 11.188" = 0.9323 ft

$$\text{area} = 4 \frac{V}{D} = 4 \frac{3.2779}{0.9323} = 14.0637 \text{ ft}^2$$

4. Wall Heat Capacity

$$V = \frac{\pi}{4} (1.1667^2 - 0.9323^2) \frac{14.0637}{\pi 0.9323}$$

$$C_p = (495) (1.8555) (0.11) = 101.03 \text{ Btu/}^\circ\text{F}$$

5. Heat Transfer Across Film

$$h_{DB} = 0.148 \left[ 1 + \frac{T}{10^2} - \frac{T^2}{10^5} \right] \frac{v^{0.8}}{D^{0.2}}$$

$$v = \frac{\dot{V}_{ref}}{\frac{\pi}{4} D^2} \quad ; \quad \frac{v^{0.8}}{D^{0.2}} = \left( \frac{4 \dot{V}_{ref}^{0.8}}{\pi} \right) \frac{1}{D^{1.8}}$$

for:  $T = 575^{\circ}\text{F}$  and  $\dot{V}_{\text{ref}} = 30.7640 \times 3600$

$$h_{\text{DB}} = (0.5097) \left( \frac{4}{\pi} 30.7640 \times 3600 \right)^{0.8} D^{-1.8}$$

$$h_{\text{DB}} = 6709.9 D^{-1.8} \text{ Btu/hr ft}^2 \text{ }^{\circ}\text{F}$$


$$= 1.8639 D^{-1.8} \text{ Btu/sec ft}^2 \text{ }^{\circ}\text{F}$$

$$h_{\text{DB}} = 2.1146 \text{ Btu/sec ft}^2 \text{ }^{\circ}\text{F}$$

$$H_{\text{DB}} = (2.1146) (14.0637) = 29.7391 \text{ Btu/sec }^{\circ}\text{F}$$

6. Structure Heat Transfer

$$\frac{kA}{L} = \frac{(0.003889) (14.0637)}{\frac{1}{4} \frac{1.406}{12}} = 1.8672 \text{ Btu/sec }^{\circ}\text{F}$$

RABV Node 48

For 10" Sch. 140 pipe

OD            10.75" = 0.8958 ft  
 ID            8.75" = 0.7292 ft

1. Volume

From Reference 6 Table XIV

<u>Location</u>	<u>Volume(ft<sup>3</sup>)</u>	<u>Length</u>
40	0.820	23.56
41	0.155	4.45
42	2.340	67.22
43	0.887	17.00
		8.50
44	0.524	15.06
45	0.276	7.94
46	0.820	23.56
46	0.820	23.56
	<u>6.642</u>	<u>190.85 = 15.9042 ft</u>

Add 0.5 ft<sup>3</sup> volume and 1 ft length for each valve.

$$\text{total volume} = 7.6420 \text{ ft}^3$$

2. Heat Capacity

$$C_p = (45.1467) (7.6420) (1.3191) = 455.10 \text{ Btu/}^\circ\text{F}$$

3. Heat Transfer Surface Area

$$A = 4 \frac{V}{D} = 4 \frac{7.6420}{0.7292} = 41.9199 \text{ ft}^2$$

4. Wall Heat Capacity

$$V = \frac{\pi}{4} [0.8958^2 - 0.7292^2] \times 17.9042 = 3.8069 \text{ ft}^3$$

$$C_p = (495) (3.8069) (0.11) = 207.29 \text{ Btu/}^\circ\text{F}$$

5. Heat Transfer Across Film

$$\begin{aligned} h_{DB} &= 1.8638 D^{-1.8} = (1.8638) (0.7292)^{-1.8} \\ &= 3.2906 \text{ Btu/sec ft}^2 \text{ }^\circ\text{F} \end{aligned}$$

$$H_{DB} = (3.2906) (41.9199) = 137.94 \text{ Btu/sec }^\circ\text{F}$$

6. Structure Heat Transfer

$$\frac{kA}{L} = \frac{(0.003889) (41.9199)}{\frac{1}{4} \frac{1}{12}} = 7.8253 \text{ Btu/sec }^\circ\text{F}$$

RABV Node 49

This volume includes the volume from the RABV's to the tee on the blowdown loop hot leg.

For 10" Sch. 140 pipe

$$\begin{array}{rcl} \text{OD} & 10.75" & = 0.8958 \text{ ft} \\ \text{ID} & 8.75" & = 0.7292 \text{ ft} \end{array}$$

1. Volume

From Reference 6 Table XXIV

<u>Location</u>	<u>Volume(ft<sup>3</sup>)</u>	<u>Length</u>
49	0.820	23.56
50	0.820	23.56
51	0.348	10.00
52	0.452	13.00
53	0.887	17.00
54	0.820	8.50
55	1.490	23.56
56	0.056	42.94
	<u>5.693</u>	<u>1.62</u>
		163.74 = 13.6450 ft

Add 0.5 ft<sup>3</sup> volume and 1 ft length for each valve.

$$\text{total volume} = 6.6930$$

2. Heat Capacity

$$C_p = (45.1467) (6.6930) (1.3191) = 398.59 \text{ Btu/}^\circ\text{F}$$

3. Heat Transfer Surface Area

$$A = 4 \frac{V}{D} = 4 \frac{6.6930}{0.7292} = 36.7142 \text{ ft}^2$$

4. Wall Heat Capacity

$$V = \frac{\pi}{4} (0.8958^2 - 0.7292^2) \times 15.6450 = 3.3265 \text{ ft}^3$$

$$C_p = (495) (3.3265) (0.11) = 181.13 \text{ Btu/}^\circ\text{F}$$

5. Heat Transfer Across Film

$$\text{(same as node 48) } h_{DB} = 3.2906 \text{ Btu/sec ft}^2 \text{ }^\circ\text{F}$$

$$H_{DB} = (3.2906) (36.7142) = 120.81 \text{ Btu/sec}^\circ\text{F}$$

6. Structure Heat Transfer

$$\frac{kA}{L} = \frac{(0.003889) (36.7142)}{\frac{1}{4} \quad \frac{1}{12}} = 6.8535 \text{ Btu/sec }^\circ\text{F}$$

Core Bypass Node 511. Volume

Bypass cross section area 6.430 in<sup>2</sup> (R. L. Drexler's notes on pg 749).  
 = 0.04465 ft<sup>2</sup>

Assume length of bypass extends from station 116.925 to 248.58

$$= 131.655" = 10.9713 \text{ ft}$$

$$\text{volume} = 0.4899 \text{ ft}^3$$

2. Heat Capacity

$$C_p = (45.1467) (0.4899) (1.3191) = 29.1750 \text{ Btu/}^\circ\text{F}$$

3. Heat Transfer Surface Area

This node is modeled as several annuluses with a gap width of 0.045" = 0.003750 ft, and diameter of 28". (R. L. Drexler's notes pg. 749)

$$A = 2 \times \frac{V}{w} = 2 \frac{0.4899}{0.003750} = 261.28 \text{ ft}^2$$

4. Wall Heat Capacity

$$\text{Assume 1" slab } \frac{1}{12} (261.28) = 21.7733 \text{ ft}^3$$

$$C_p = (495) (21.7733) (0.11) = 1185.56 \text{ Btu/}^\circ\text{F}$$

5. Heat Transfer Across Film

$$h_{DB} = \frac{0.5097}{3600} \frac{v^{0.8}}{D_H^{0.2}} ; v = \frac{30.7640 \times 3600}{0.04465} = 2.4804 \times 10^6 \text{ ft/hr}$$

$$D_H = 4 \frac{0.04465}{2 \pi \frac{28}{12}} = 0.01218$$

$$h_{DB} = 44.6170 \text{ Btu/sec ft}^2 \text{ }^\circ\text{F}$$

$$H_{DB} = (44.6170) (261.28) = 11657.53 \text{ Btu/sec }^\circ\text{F}$$

6. Structure Heat Transfer

$$\frac{kA}{L} = \frac{(0.003889) (261.28)}{\frac{1}{4} \frac{1}{12}} = 48.7737 \text{ Btu/sec } ^\circ\text{F}$$

7. Height

To account for round off, the height of the bypass node equals the combined height of nodes 1-4, 16 and 17.

$$4 (1.375) + 2 (2.735) = 10.9700 \text{ ft}$$

APPENDIX DTHERMODYNAMIC PROPERTIES USED IN THE PRESSURIZER MODEL

- Figure D-1                      Specific Volume Versus Specific Enthalpy for Various Pressures - Water Region. (The specific volume of subcooled water is approximated by the saturation curve.)
- Figure D-2                      Steam Quality Versus Specific Enthalpy for Various Pressures - Water Region.
- Figure D-3                      Specific Volume Versus Specific Enthalpy for Various Pressures - Steam Region.
- Figure D-4                      Steam Quality Versus Specific Enthalpy for Various Pressures - Steam Region.
- Tables D-5 through D-9              Input values for AD-10 Function Generator.
- Figure D-10                      Linear Approximation of Specific Enthalpy Versus Pressure at Saturation Conditions - Fluid Region.
- Figure D-11                      Linear Approximation of Specific Enthalpy Versus Pressure at Saturation Conditions - Steam Region.
- Table D-12                      Table of Specific Volume of Saturated Steam Versus Pressure.
- Figure D-13                      Linear Approximation of Specific Enthalpy Versus Temperature for Subcooled Water.
- Figure D-14                      Linear Approximation of Specific Volume Versus Specific Enthalpy - Fluid Region.




FIGURE D-1  
SPECIFIC VOLUME VERSUS SPECIFIC ENTHALPY  
FOR VARIOUS PRESSURES-WATER REGION




FIGURE D-2  
STEAM QUALITY VERSUS SPECIFIC ENTHALPY  
FOR VARIOUS PRESSURES-WATER REGION




FIGURE D-3  
SPECIFIC VOLUME VERSUS SPECIFIC ENTHALPY  
FOR VARIOUS PRESSURES-STEAM REGION

LTR-10-2-Rev. C

D-5

Steam Quality (%)

100  
90  
80

960 1000 1040 1080 1120 1160 1200 1240

Enthalpy,  $h$  (BTU/lbm)

3000 PSIA  
2900 PSIA  
2700 PSIA  
2500 PSIA  
2300 PSIA  
2200 PSIA  
2000 PSIA  
1800 PSIA  
1600 PSIA  
1400 PSIA

FIGURE D-4  
STEAM QUALITY VERSUS SPECIFIC ENTHALPY  
FOR VARIOUS PRESSURES - STEAM REGION

LTR-10-2-Rev. C




TABLE D-5

AD-10 VALUES OF SPECIFIC VOLUME (CU FT/LBM) AS A FUNCTION OF ENTHALPY AND PRESSURE - WATER REGION

H (BTU/LBM)	PRESSURE (PSIA)									
	1400	1500	1600	1800	2000	2200	2300	2500	2700	3000
550.00										
560.00										
570.00										
580.00	.0140									
590.00	.0188	.0136								
600.00	.0236	.0181	.0135							
610.00	.0285	.0227	.0178							
620.00	.0333	.0272	.0221	.0138						
630.00	.0381	.0318	.0264	.0176	.0110					
640.00	.0430	.0363	.0306	.0215	.0144					
650.00	.0478	.0409	.0349	.0253	.0179	.0122				
660.00		.0454	.0392	.0291	.0214	.0154	.0129			
670.00		.0500	.0435	.0330	.0249	.0186	.0159	.0112		
680.00			.0478	.0368	.0284	.0218	.0190	.0140	.0101	
690.00				.0407	.0319	.0249	.0220	.0168	.0127	
700.00				.0445	.0354	.0281	.0251	.0196	.0153	.0106
710.00				.0484	.0389	.0313	.0281	.0225	.0179	.0130
720.00					.0424	.0345	.0312	.0253	.0205	.0153
730.00					.0458	.0377	.0342	.0281	.0231	.0176
740.00					.0493	.0409	.0373	.0309	.0258	.0199
750.00						.0441	.0404	.0338	.0284	.0222
760.00						.0473	.0434	.0366	.0310	.0246
770.00							.0465	.0394	.0336	.0269
780.00							.0495	.0422	.0362	.0292
790.00								.0451	.0388	.0315
800.00								.0479	.0414	.0339

Sub-cooled region - values above the saturation line are necessary for accurate interpolation.

Saturation Region  
 Range .01 to .05 cu ft/lbm.  
 Data is plotted on Figure D-1.  
 Scaled values are listed in Table H-8.

Saturation Line

LTR-10-2-Rev. C

D-5

TABLE D-7

## AD-10 VALUES OF SPECIFIC VOLUME (CU FT/LBM) AS A FUNCTION OF ENTHALPY AND PRESSURE - STEAM REGION

H (BTU/LBM)	PRESSURE (PSIA)									
	1400	1600	1800	2000	2200	2300	2500	2700	2900	3000
950.00	.1929	.1635	.1407	.1226	.1078	.1014	.0902	.0806	.0725	.0687
960.00	.1977	.1678	.1446	.1261	.1110	.1045	.0931	.0832	.0749	.0710
970.00	.2025	.1721	.1484	.1296	.1142	.1076	.0959	.0859	.0773	.0733
980.00	.2074	.1764	.1523	.1331	.1174	.1106	.0987	.0885	.0797	.0756
990.00	.2122	.1807	.1561	.1366	.1206	.1137	.1015	.0911	.0822	.0780
1000.00	.2170	.1850	.1600	.1400	.1238	.1167	.1044	.0937	.0846	.0803
1010.00	.2219	.1893	.1638	.1435	.1269	.1198	.1072	.0963	.0870	.0826
1020.00	.2267	.1936	.1677	.1470	.1301	.1228	.1100	.0989	.0894	.0849
1030.00	.2315	.1978	.1715	.1505	.1333	.1259	.1128	.1015	.0918	.0882
1040.00	.2364	.2021	.1754	.1540	.1365	.1289	.1156	.1041	.0943	.0915
1050.00	.2412	.2064	.1792	.1575	.1397	.1320	.1185	.1068	.0978	.0948
1060.00	.2461	.2107	.1831	.1610	.1429	.1350	.1213	.1094	.1013	.0980
1070.00	.2509	.2150	.1869	.1645	.1461	.1381	.1241	.1120	.1049	.1015
1080.00	.2557	.2193	.1908	.1680	.1493	.1412	.1269	.1160	.1084	.1050
1090.00	.2606	.2236	.1946	.1714	.1524	.1442	.1298	.1200	.1119	.1084
1100.00	.2654	.2278	.1985	.1749	.1556	.1473	.1335	.1239	.1156	.1119
1110.00	.2702	.2321	.2023	.1784	.1588	.1503	.1380	.1279	.1194	.1154
1120.00	.2751	.2364	.2062	.1819	.1620	.1546	.1424	.1320	.1231	.1191
1130.00	.2799	.2407	.2100	.1854	.1667	.1594	.1468	.1361	.1269	.1228
1140.00	.2847	.2450	.2139	.1893	.1719	.1644	.1513	.1403	.1307	.1264
1150.00	.2896	.2493	.2177	.1950	.1770	.1694	.1559	.1444	.1346	.1301
1160.00	.2944	.2536	.2235	.2008	.1823	.1744	.1604	.1486	.1385	.1338
1170.00	.2992	.2595	.2300	.2066	.1877	.1795	.1650	.1528	.1424	.1377
1180.00	.3057	.2668	.2365	.2125	.1930	.1846	.1696	.1571	.1463	.1415
1190.00	.3141	.2741	.2431	.2184	.1983	.1897	.1743	.1614	.1503	.1453
1200.00	.3226	.2815	.2497	.2243	.2037	.1948	.1790	.1657	.1543	.1492
1210.00	.3311	.2890	.2563	.2303	.2091	.1999	.1837	.1701	.1583	.1531
1220.00	.3396	.2964	.2629	.2363	.2145	.2051	.1885	.1745	.1624	.1570
1230.00	.3482	.3039	.2696	.2422	.2199	.2103	.1933	.1789	.1665	.1610
1240.00	.3568	.3115	.2762	.2483	.2254	.2155	.1981	.1833	.1707	.1649
1250.00	.3655	.3191	.2830	.2543	.2309	.2207	.2029	.1878	.1749	.1689

Saturation Line

Range  $\pm$  .4000 cu ft/lbm. Data is plotted on Figure D-3. Scaled values are listed in Table H-10.

TABLE D-6

AD-10 VALUES OF STEAM QUALITY AS A FUNCTION OF ENTHALPY AND PRESSURE - WATER REGION

H (BTU/LBM)	PRESSURE (PSIA)										
	1400	1500	1600	1800	2000	2200	2300	2500	2700	3000	
550.00	-.0847	-.1105	-.1373	-.1955							
560.00	-.0674	-.0926	-.1188	-.1756							
570.00	-.0500	-.0747	-.1003	-.1558							
580.00	-.0327	-.0568	-.0818	-.1359	-.1976						
590.00	-.0153	-.0389	-.0633	-.1161	-.1761						
600.00	.0020	-.0210	-.0448	-.0962	-.1547						
610.00	.0194	-.0030	-.0263	-.0764	-.1332						
620.00	.0367	.0149	-.0078	-.0500	-.1118	-.1768					
630.00	.0541	.0328	.0107	-.0367	-.0903	-.1534	-.1901				
640.00	.0714	.0507	.0292	-.0169	-.0689	-.1300	-.1655				
650.00	.0888	.0686	.0478	.0030	-.0474	-.1065	-.1408				
660.00	.1061	.0865	.0663	.0228	-.0260	-.0831	-.1162	-.1983			
670.00	.1235	.1044	.0848	.0427	-.0045	-.0597	-.0916	-.1707			
680.00	.1408	.1223	.1033	.0625	.0169	-.0362	-.0669	-.1430			
690.00	.1582	.1402	.1218	.0824	.0384	-.0128	-.0423	-.1154			
700.00	.1755	.1581	.1403	.1022	.0598	.0106	-.0177	-.0877	-.1836		
710.00	.1928	.1760	.1588	.1221	.0813	.0341	.0069	-.0600	-.1516		
720.00		.1939	.1773	.1419	.1027	.0575	.0316	-.0324	-.1195		
730.00			.1958	.1618	.1242	.0809	.0562	-.0047	-.0875		
740.00				.1816	.1456	.1044	.0808	.0229	-.0555		
750.00					.1671	.1278	.1055	.0506	-.0235		
760.00					.1885	.1512	.1301	.0782	.0085	-.1915	
770.00		Saturation Region					.1747	.1547	.1059	.0405	-.1457
780.00		Range +20%.					.1981	.1794	.1335	.0725	-.1000
790.00		Data is plotted on Figure D-2.							.1612	.1046	-.0542
800.00		Scaled values are listed in Table H-9.							.1889	.1366	-.0084

Sub-cooled region - values above the saturation line are necessary for accurate interpolation.

D-7

LTR-10-2-Rev. C

Saturation Line

TABLE D-8

AD-10 VALUES OF STEAM QUALITY AS A FUNCTION OF ENTHALPY AND PRESSURE - STEAM REGION

H (BTU/LBM)	PRESSURE (PSIA)									
	1400	1600	1800	2000	2200	2300	2500	2700	2900	3000
950.00										
960.00										
970.00										
980.00										.8155
990.00									.8045	.8613
1000.00									.8437	.9071
1010.00								.8089	.8830	.9529
1020.00								.8409	.9223	.9986
1030.00							.8249	.8729	.9615	1.0444
1040.00					.8074	.8197	.8526	.9049	1.0008	1.0902
1050.00				.8106	.8308	.8443	.8803	.9369	1.0401	1.1360
1060.00	.8000	.8066	.8168	.8320	.8542	.8690	.9079	.9689	1.0793	1.1817
1070.00	.8173	.8251	.8366	.8535	.8777	.8936	.9356	1.0010	1.1186	
1080.00	.8347	.8436	.8565	.8749	.9011	.9182	.9632	1.0330	1.1579	
1090.00	.8520	.8621	.8763	.8964	.9245	.9429	.9909	1.0650	1.1971	
1100.00	.8694	.8806	.8962	.9178	.9480	.9675	1.0185	1.0970		
1110.00	.8867	.8991	.9160	.9393	.9714	.9921	1.0462	1.1290		
1120.00	.9041	.9176	.9359	.9607	.9948	1.0167	1.0738	1.1610		
1130.00	.9214	.9361	.9557	.9822	1.0183	1.0414	1.1015	1.1930		
1140.00	.9388	.9547	.9756	1.0036	1.0417	1.0660	1.1292			
1150.00	.9561	.9732	.9954	1.0251	1.0651	1.0906	1.1568			
1160.00	.9735	.9917	1.0153	1.0465	1.0886	1.1153	1.1845			
1170.00	.9908	1.0102	1.0351	1.0680	1.1120	1.1399				
1180.00	1.0082	1.0287	1.0550	1.0894	1.1354	1.1645				
1190.00	1.0255	1.0472	1.0748	1.1109	1.1589	1.1892				
1200.00	1.0428	1.0657	1.0947	1.1323	1.1823					
1210.00	1.0602	1.0842	1.1145	1.1538						
1220.00	1.0775	1.1027	1.1344	1.1753						
1230.00	1.0949	1.1212	1.1542	1.1967						
1240.00	1.1122	1.1397	1.1741							
1250.00	1.1296	1.1582	1.1939							

Saturation Region

Saturation Line

Super heat region - values below the saturation line are necessary for accurate interpolation.

Range 80 - 120%.  
Data is plotted on Figure D-4.  
Scaled values are listed in Table H-11.

D-9

LTR-10-2-Rev. C


TABLE D-9AD-10 VALUES OF SPECIFIC VOLUME AS A  
FUNCTION OF ENTHALPY - SATURATION CONDITIONS

<u>H (BTU/LBM)</u>	<u>V (CU FT/LBM)</u>
550.0	.0218
598.8	.0231
611.7	.0235
624.2	.0239
648.5	.0247
672.1	.0257
695.5	.0267
707.2	.0273
731.7	.0286
757.3	.0303
800.0	.0341

Data is plotted on Figure D-1.

Scaled values are listed in Table H-12.

D-11



ASME  
Steam Tables

linear approximation  
 $h_f = .117 P + 438.1$   
formed from  $\oplus$  points

FIGURE D-10. LINEAR APPROXIMATION OF SPECIFIC ENTHALPY VERSUS PRESSURE AT SATURATION CONDITIONS-FLUID REGION

LTR-10-2-Rev. C




FIGURE D-11. LINEAR APPROXIMATION OF SPECIFIC ENTHALPY VERSUS PRESSURE AT SATURATION CONDITIONS-STEAM REGION

TABLE D-12SPECIFIC VOLUME OF SATURATED STEAM VERSUS PRESSURE

<u>Pressure PSIA</u>	<u>Specific Volume ft<sup>3</sup>/lbm</u>
2000	.1883
2100	.1750
2200	.1625
2300	.1513
2400	.1408





FIGURE D-13. LINEAR APPROXIMATION OF SPECIFIC ENTHALPY VERSUS TEMPERATURE FOR SUB-COOLED WATER



FOR INFORMATION ONLY  
 KEUFFEL & ESSER CO. MADE IN U.S.A.

## APPENDIX E

STEAM GENERATOR VOLUME VS LEVEL CALCULATIONS

1. References: LOFT Drawings 206161 through 206169
2. Dimensions:
- |              |        |          |
|--------------|--------|----------|
| Shell        | ID     | 56"      |
| Shroud       | ID     | 50.75"   |
|              | OD     | 51.75"   |
| Riser        | ID     | 24"      |
|              | OD     | 24.75"   |
| Tubes        | OD     | 0.5"     |
|              | number | 1845     |
| Frustum base | ID     | 49.9375" |

Heights (referenced to top of the tube sheet):

tube bend line	72.5"
bottom of frustum section	88.125"
max tube height	97.5"
bottom of riser/top of frustum	101.21875"
bottom of separator duct	144.625"
top of riser	161.750"

3. Cross sectional areas:

$$\text{Shell inside } \frac{\pi}{4} \left( \frac{56}{12} \right)^2 = 17.1042 \text{ ft}^2$$

$$\text{Shroud outside } \frac{\pi}{4} \left( \frac{51.75}{12} \right)^2 = 14.6066 \text{ ft}^2$$

$$\text{Shroud inside } \frac{\pi}{4} \left( \frac{50.75}{12} \right)^2 = 14.0475 \text{ ft}^2$$

$$\text{Riser outside } \frac{\pi}{4} \left( \frac{24.75}{12} \right)^2 = 3.3410 \text{ ft}^2$$

$$\text{Riser inside } \frac{\pi}{4} \left( \frac{24}{12} \right)^2 = 3.1416 \text{ ft}^2$$

Tube outside - straight section

$$2 \times 1845 \times \frac{\pi}{4} \left( \frac{0.5}{12} \right)^2 = 5.0315 \text{ ft}^2$$

#### 4. Inside Shroud Volume

4.1 From the top of the tube sheet to the tube bend line.

Height = 72.5"

Cross Sectional Area = 14.0475 - 5.0315 = 9.0160 ft<sup>2</sup>

Volume = (9.0160) 72.5/12 = 54.4717 ft<sup>3</sup>

Displacements:

Tie Rods - 10 rods, 1/2" diameter, 5'10-3/4" long.

Volume = 10  $\pi/4$  (0.5)<sup>2</sup> 70.75 = 138.92 in<sup>3</sup>

Support Plates - 4 plates, 1/2" thick, 24-7/8" radius with 2 1/4" overlap strip. Assume volume of each plate is equal. Use type "A" as typical.

Area of semi circle = (1/2)  $\pi$  (24.875)<sup>2</sup> = 971.95 in<sup>2</sup>

Area of overlap strip = (2.25) (2 x 24.875) = 111.94 in<sup>2</sup>

Area of holes

1961 17/32" holes for tubes = 434.68 in<sup>2</sup>

6 17/32" holes for tie rods = 1.33 in<sup>2</sup>

3556 3/16" holes for flow = 98.19 in<sup>2</sup>

$$\begin{aligned} \text{Total Support Plate Area} &= 549.69 \text{ in}^2 \\ \text{Volume (4) (0.5) (549.69)} &= 1099.38 \text{ in}^3 \end{aligned}$$

Bottom Blowdown Pipe - 1-1/2" sch 40 pipe, 3'9" long  
with a 1 1/2" elbow.

$$\text{Volume} = \pi/4 (1.9)^2 (45 + \pi/2 1.5) = 134.27 \text{ in}^3$$

$$\begin{aligned} \text{Net volume} &= 54.4717 - (138.92 + 1099.38 + 134.27)/1728 \\ &= 53.6774 \text{ ft}^3 \end{aligned}$$

4.2 From the tube bend line to the bottom of the frustum section.

$$\text{Height} = 15.625''$$

$$\text{Area inside shroud} = 14.0475 \text{ ft}^2$$

The displacement of the upper tube support structure is neglected because of its small volume and irregular geometry.

From an analysis of the steam generator tube displacement by  
C. D. Clayton, 1-24-80:

<u>Height Above bend line (in.)</u>	<u>Displacement of tubes (in.<sup>3</sup>)</u>	<u>(ft<sup>3</sup>)</u>
5.0	3765.00	2.1788
10.0	7268.00	4.2060
15.5	10377.14	6.0053
16.0	10606.46	6.1380

Interpolate to find volume at 15.625" = 6.0385 ft<sup>3</sup>

<u>Height Above tube sheet (in.)</u>	<u>Volume inside shroud (ft<sup>3</sup>)</u>	<u>Net Volume above tube bend line (ft<sup>3</sup>)</u>	<u>Total Volume (ft<sup>3</sup>)</u>
77.500	5.8531	3.6743	57.3517
82.500	11.7063	7.5003	61.1777
88.125	18.2910	12.2525	65.9299

- 4.3 From the bottom of the frustum section (88.125") to the maximum tube height (97.500").

From an analysis of the steam generator tube displacement by C. D. Clayton, 1-24-80.

Height above bend line (in)	Displacement of tubes		Net Displacement above 88.125" (ft <sup>3</sup> )
	(in <sup>3</sup> )	(ft <sup>3</sup> )	
17.0	11035.98	6.3866	0.3481
19.0	11765.17	6.8085	0.7700
21.0	12304.09	7.1204	1.0819
23.0	12634.77	7.3118	1.2733
25.0	12728.98	7.3663	1.3278

Volume of frustum:

$$V = \frac{\pi}{4} \int_0^h D^2 dh = \frac{\pi}{4} h (1.4431 - 0.05725h + 0.7569 \times 10^{-3} h^2)$$

V in ft<sup>3</sup>, h in inches, D = (49.9375 - 1.9809h)/12.

Height above bend line (in.)	Height above tube sheet (in.)	Height above 88.125" (in.)	Volume inside frust. (ft <sup>3</sup> )	Net Volume above 88.125" (ft <sup>3</sup> )	Total volume (ft <sup>3</sup> )
17.0	89.5	1.375	1.4750	1.1269	67.0568
19.0	91.5	3.375	3.3359	2.5659	68.4958
21.0	93.5	5.375	4.8853	3.8034	69.7333
23.0	95.5	7.375	6.1517	4.8784	70.8083
25.0	97.5	9.375	7.1636	5.358	71.7657

- 4.4 From the top of the tubes (97.500") to the bottom of the riser (101.219").

$$\text{Volume of frustum} = \pi h/3 (r_1^2 + r_1 r_2 + r_2^2)$$

$$h = 101.219 - 88.125 = 13.0940''$$

$$r_1 = 49.9375/2 = 24.9688''$$

$$r_2 = 24/2 = 12.000''$$

$$V = 8.4674 \text{ ft}^3$$

$$\text{Net Volume} = 8.4674 - 7.1636 = 1.3038 \text{ ft}^3$$

$$\text{Total Volume} = 71.7657 + 1.3038 = 73.0695 \text{ ft}^3$$

- 4.5 From the bottom of the riser (101.219") to the bottom of the separator duct (144.625").

$$\text{Height} = 43.406"$$

$$\text{Area} = 3.1416 \text{ ft}^2$$

$$\text{Volume} = 11.3637 \text{ ft}^3$$

$$\text{Total Volume} = 84.4332 \text{ ft}^3$$

- 4.6 From 144.625" to 161.75".

For analytical purposes the volume of the riser is considered to extend vertically to 161.75."

$$\text{Height} = 17.125"$$

$$\text{Area} = 3.1416 \text{ ft}^2$$

$$\text{Volume} = 4.4833 \text{ ft}^3$$

Displacements:

Level Control Cup - 6" diameter, 6-1/4" height.

$$\text{Volume} = 0.1023 \text{ ft}^3$$

Level Control Piping - 2 pieces, 1-1/2" sch 40 pipe, approximately 19" long.

$$\text{volume} = 2 \pi/4 (0.840)^2 (19) / 1728 = 0.0122 \text{ ft}^3$$

$$\text{Net Volume} = 4.3688 \text{ ft}^3$$

$$\text{Total Volume} = 88.8020 \text{ ft}^3$$

5. Downcomer Volume

- 5.1 Lower Section - from the top of the tube sheet to the bottom of the frustum section.

$$\text{Height} = 88.125''$$

$$\text{Cross Sectional Area} = 17.1042 - 14.6066 = 2.4976 \text{ ft}^2$$

$$\text{Volume} = (2.4976) (88.125)/12 = 18.3418 \text{ ft}^3$$

Displacements:

Spacer lugs - 8 lugs 2-7/8" x 4" x 3/8"

$$\text{Volume} = 34.5000 \text{ in}^3 = 0.0200 \text{ ft}^3$$

$$\text{Net Volume} = 18.3218 \text{ ft}^3$$

## 5.2 Frustum Section - 88.125" to 101.395".

$$\text{Height} = 13.270''$$

$$\text{Volume inside the shell} = (17.1042) (13.270)/12 = 18.9144 \text{ ft}^3$$

$$\text{Volume of frustum} = \pi/4 \int_0^h D^2 dh$$

$$\text{Diameter of base} = 49.9375 + \sqrt{2} = 51.3517''$$

$$D = (51.3517 - 2.0046h)/12$$

$$V = \pi/4 h (1.5260 - 0.05957h + 0.7752 \times 10^{-3}h^2)$$

$$V \text{ in ft}^3, h \text{ in inches.}$$

Displacements:

Shroud Upper lip and weld - Ring 51" diameter,  
approximate cross section 3/8" x 1/2", located around  
bottom of frustum

$$\text{Volume} = (0.375) (0.5) \pi (51)/1728 = 0.0174 \text{ ft}^3$$

Level control piping - 2 pieces of 1/2" sch 40 pipe,  
17-1/4" long each.

$$\text{Volume} = 2 \pi/4 (0.840)^2 (17.25)/1728 = 0.0111 \text{ ft}^3$$

Emergency cooldown pipe bosses - 6 each, 2" diameter, 2-5/8"  
long, cut at 45° angle, located at the top of the frustum.

$$\text{Volume} = 6 \pi/4 (2)^2 (0.6250 + 1/2 (2))/1728 = 0.0177 \text{ ft}^3$$

Height Above tube sheet (in.)	Height Above 88.125" (in.)	Volume of Frustrum (ft <sup>3</sup> )	Volume of displacement (ft <sup>3</sup> )	Net Volume above 88.125" (ft <sup>3</sup> )	Total Volume (ft <sup>3</sup> )
90.125	2.000	2.2148	0.0191	0.6168	18.9386
92.125	4.000	4.0845	0.0207	1.5962	19.9180
94.125	6.000	5.6383	0.0224	2.8914	21.2132
96.125	8.000	6.9056	0.0241	4.4731	22.7949
98.125	10.000	7.9154	0.0258	6.3123	24.6341
101.395	13.270	9.0883	0.0462	9.7799	28.1017

### 5.3 Riser Section - 101.395" to 144.625".

$$\text{Cross sectional Area} = 17.1042 - 3.3410 = 13.7632 \text{ ft}^2$$

Displacements:

Level control piping - 2 pieces of 1/2" sch 40 pipe.

$$\text{Area} = 2 \pi/4 (0.840)^2/144 = 0.007697 \text{ ft}^2$$

Mist extractor drain piping - 4 pieces of 1/2" sch 40 pipe.

Assume pipe fills as level increases.

$$\text{Area} = 4 \pi/4 (0.840^2 - 0.622^2)/144 = 0.006953 \text{ ft}^2$$

Emergency cooldown pipe - 6 pieces of 1" sch 40 pipe, 29-1/2" long, approximately 4-1/2" extends into bosses.

$$\text{Volume} = 6 \pi/4 (1.315)^2 (25)/1728 = 0.1179 \text{ ft}^3$$

Feed ring - 24" radius, 3" sch 40 pipe, located at 105.0". Assume this pipe is full regardless of the level.

$$\text{Volume} = \frac{\pi}{4} (3.5)^2 2\pi (24) /1728 = 0.8396 \text{ ft}^3$$

Feed ring supports - 4 - 5 3/4" x 2-1/2" x 1/2"

$$\text{Volume} = 0.01664 \text{ ft}^3$$

Surface blowdown ring - 23" radius, 1-1/2" sch 40 pipe, located at 109.5". The inside of this pipe is assumed to fill up as the level increases.

$$\text{Volume} = \pi/4 [1.9^2 - 1.61^2] 2\pi (23)/1728 = 0.06686 \text{ ft}^3$$

Surface blowdown ring supports - 4 - 6-1/4" x 2-1/2" x 1/2"

$$\text{Volume} = 0.01808 \text{ ft}^3$$

Emergency cooldown ring - radius varies from 23" to 24", 1-1/2" sch 40 pipe, located at 120.5".

$$\text{Volume} = \pi/4 (1.9)^2 2\pi (23.5)/1728 = 0.2423 \text{ ft}^3$$

Cooldown ring supports - 4 - 3-3/8" x 2-1/2" x 1/2"

$$\text{Volume} = 0.009766 \text{ ft}^3$$

Eject pipes - 8 each - 3" sch 40 pipe with 5" sch 40 6-1/2" high cup. Bottom of cup is at approximately 129.5" and extends to the mist extractors. Assume the cups are full.

$$\text{Volume of cups} = 8 \frac{\pi}{4} (5.563)^2 (6.5)/1728 = 0.7314 \text{ ft}^3$$

$$\text{Area of pipes} = 8 \pi/4 (3.5)^2/144 = 0.5345 \text{ ft}^2$$

Gage glass internal piping - 1" sch 40 pipe, starts at 137.5" and extends to top of riser.

$$\text{Area} = \pi/4 (1.315)^2/144 = 0.009431 \text{ ft}^2$$

Net Cross Sectional Area

$$13.7632 - 0.007697 - 0.006953 = 13.7486 \text{ ft}^2$$

Displacements below 122"

$$\begin{array}{r} 0.1179 \\ 0.8396 \\ 0.0166 \\ 0.0669 \\ 0.0181 \\ 0.2423 \\ 0.0098 \\ \hline 1.3112 \text{ ft}^3 \end{array}$$

Volume at 122"

$$\begin{aligned} (13.7486)(122.0 - 101.395)/12 - 1.3112 &= \\ 22.2963 \text{ ft}^3 & \\ \text{Total volume} = 28.1017 + 22.2963 &= 50.3980 \text{ ft}^3 \end{aligned}$$

Volume at 129.5"

$$\begin{aligned} (13.7486)(129.5 - 122.0)/12 &= 8.5929 \text{ ft}^3 \\ \text{Total volume} = 50.3980 + 8.5929 &= 58.9909 \end{aligned}$$

Volume at 144.625

$$\begin{aligned} (13.7486)(144.625 - 129.5)/12 &- 0.7314 \\ - (0.5345)(144.625 - 136.0)/12 & \\ - (0.009431)(144.625 - 137.5)/12 &= \\ 16.2078 \text{ ft}^3 & \end{aligned}$$

$$\text{Total volume} = 58.9909 + 16.2078 = 75.1987 \text{ ft}^3$$

5.4 From 144.625" to 161.75"

For analytical purposes the volume of the downcomer is considered to extend to 161.75". The displacement of the moisture separators is neglected.

$$\text{Height} = 17.125''$$

$$\text{Volume} = (13.7632 - 0.006953 - 0.5345 - 0.009431)(161.75 - 144.625)/12 = 18.8551 \text{ ft}^3$$

$$\text{Total Volume} = 94.0538 \text{ ft}^3$$

## 6. Analytical fits for the level versus volume curves

### 6.1 Inside Shroud - Comprised of two straight line segments.

The first line passes through points (0,0) and (53.6774,72.5).

$$L = \frac{72.5}{53.6774} V = 1.3507 V$$

The second line passes through points (73.0695, 101.219) and (84.4332, 144.625).

$$L - 101.219 = \frac{144.625 - 101.219}{84.4332 - 73.0695} (V - 73.0695)$$

$$L = 3.8197 V - 177.8851$$

The lines intersect at (72.0474, 97.3145).

$$L = 1.3507 V \quad \text{for } V \leq 72.0474$$

$$L = 3.8197 V - 177.8851 \quad \text{for } V > 72.0474$$

$$V = 0.7404 L \quad \text{for } L \leq 97.3145$$

$$V = 0.2618 L + 46.5704 \quad \text{for } L > 97.3145$$

6.2 Downcomer - comprised of two straight line segments.

The first line passes through the points (0,0) and (18.3218, 88.125)

$$L = \frac{88.125}{18.3218} V = 4.8098 V$$

The second line passes through the points (28.1017, 101.395) and (50.3980, 122.0)

$$L - 101.395 = \frac{122.0 - 101.395}{50.3980 - 28.1017} (V - 28.1017)$$

$$L = 0.9241 V + 75.4250$$

The lines intersect at (19.4109, 93.3626)

$$L = 4.8098 V \quad \text{for } V \leq 19.4109$$


$$L = 0.9241 V + 75.4250 \quad \text{for } V > 19.4109$$

$$V = 0.2079 L \quad \text{for } L \leq 93.3626$$

$$V = 1.0821 L - 81.6200 \quad \text{for } L > 93.3626$$



FIGURE E-1  
STEAM GENERATOR LEVEL VS. VOLUME



46 1513

K&E 10 X 10 TO THE CENTIMETER 18 X 25 CM  
KEUFEL & ESSER CO. MADE IN U.S.A.

## APPENDIX F

ANALYSIS OF STEAM GENERATOR SHRINK DATA RECORDED  
DURING POWER RANGE SCRAMS

F.1 Steam Generator Mass Distribution During Normal Operation

By performing a mass balance before and after a reactor scram the normal operating mass distributions inside the steam generator can be determined.

1. Following a scram the water level inside the shroud and the downcomer are equal. See the data sheet for a tabulation of the total steam generator mass. Because the level instrument actually measures differential pressure and is calibrated for saturated water, the mass of the steam in the downcomer and shroud is included with the water masses.
2. During a scram the steam valve closes much slower than the feed valve. This results in a net mass loss which is calculated as follows:

$$2.1 \quad \Delta M = \int_0^{W_i/R} W(t) dt = \int_0^{W_i/R} (W_i - Rt) dt = \frac{1}{2R} W_i^2$$


$$\begin{aligned} W_i &= \text{initial mass flow} \\ R &= \text{flow change ramp rate} \end{aligned}$$

2.2 From 100% plant proof trip (281:23:14:51.429)

2.2.1 Mass added through feedwater valve while the valve was closing. Feed valve shut in 0.7 sec. Feed flow was 206,000 lbm/hr.

$$\begin{aligned} \Delta M_f &= 1/2 \ 1/R \ W_i^2, \ R = W_i/\Delta t \\ \Delta M_f &= 1/2 \ (0.7) \ (206,000)/3600 = 20.0 \ \text{lbm} \end{aligned}$$

## 2.2 Steam flow trace:



Mass loss through steam valve while the valve was closing.

$$\Delta M_s = [1/2 (70K) (3.1) + (130K) (3.1) + 1/2 (130K) (9.6)] / 3600 = 315.4 \text{ lbm}$$

$$2.2.3 \text{ Net } \Delta M = -295.4 \text{ lbm}$$

2.3 Linearized approximation for net mass lost as a function of the initial feed flow.

$$\frac{1}{2R} = \frac{\Delta M}{W_i^2} = \frac{-295.4}{(206K/3600)^2} = -0.09$$

$$\Rightarrow \text{Net } \Delta M = -0.09 W_i^2$$

See data sheet for the calculated mass changes and the initial mass values.

- The steam generator shroud mass can now be found by subtracting the downcomer, dome, and steam line masses from the total mass. See the data sheet for the calculated values.

$$4. \quad \bar{v}_{\text{shrd}} = \frac{V_{\text{shrd}}}{M_{\text{shrd}}}$$

$$\bar{X}_{\text{shrd}} = (\bar{v}_{\text{shrd}} - v_f) / v_{fg}$$

DATA SHEET F.1

Power Level	100%	75%	30%	0%	
<u>Post Scram Data</u>					
Level(1)	87.9(2)	94.7(3)	109.9(4)	116	inches
Dwn Water Vol	18.3	21.7	37.3	43.9	cuft
Shroud Water Vol	65.7	70.4	75.3	76.9	cuft
Pressure	925.0(2)	938.0(3)	907.0(4)	963.0(6)	psia
vf	0.02132	0.02136	0.02126	0.02146	cuft/lbm
vfg	0.46479	0.45738	0.47543	0.44367	cuft/lbm
vg	0.48611	0.47871	0.49669	0.46513	cuft/lbm
Masses					
Dwncmr	858.3	1015.9	1754.5	2045.7	lbm
Shroud	3081.6	3295.9	3541.9	3583.4	lbm
Dome	105.9	107.6	103.7	116.1	lbm
Steam line	84.3	85.6	82.5	88.1	lbm
TOTAL	4130.1	4505.0	5482.6	5833.3	lbm
<u>Pre-Scram Data</u>					
Steam Flow	55.56(2)	41.67(3)	17.5(5)	0	lbm/sec
Feed Flow	57.22(2)	45.00(3)	17.5(5)	0	lbm/sec
Mass Change	295.4	182.3	27.6	0	lbm
Initial S/G Mass	4425.5	4687.3	5510.2	5833.3	lbm
Level(1)	126.1(2)	124.5	121.6	N/A	inches
Dwncmr Water Vol	55.1	53.3	50.0	N/A	cuft
Pressure	740	780	843	N/A	psia
vf	0.02065	0.02080	0.02102	N/A	cuft/lbm
vfg	0.59757	0.56377	0.51678	N/A	cuft/lbm
vg	0.61822	0.58457	0.53780	N/A	cuft/lbm
Masses					
Dwncmr	2668.3	2562.5	2378.7	N/A	lbm
Dome	83.3	88.1	95.8	N/A	lbm
Steam line	66.3	70.1	76.2	N/A	lbm
TOTAL	2817.9	2720.7	2550.7	N/A	lbm
Shroud Mass	1607.6	1966.7	2959.0	N/A	lbm
vshrd	0.05524	0.04515	0.03001	0.02478	cuft/lbm
Xshrd	0.05788	0.04319	0.01740	0.00748	

DATA SHEET F.1 (cont'd)Volumes

Shroud	88.8 cuft
Downcomer	94.7 cuft
Dome	51.5 cuft
Steam line	<u>41.0 cuft</u>
TOTAL	276.0 cuft

- 
- (1) The levels given here are referenced to the top of the tube sheet. Indicated level is referenced to 116 inches above the tube sheet.
  - (2) IP-01.07PR Step 6.11.9, Att 11 Step 6.3, Plant Proof Trip, 100 (281:23:14:51.429).
  - (3) IP-01.07 Step 6.9.14, Att 11 Step 6.3, Plant Proof Trip, 75 (279:10:35:50.024).
  - (4) IP-01.07PR Step 6.7.8, Att 11 Step 6.3, Plant Proof Trip 30 (257:22:30:09.436).
  - (5) Estimated value
  - (6) Assumed 540°F.
-




FIGURE F.1-1  
STEAM GENERATOR MASS AS A FUNCTION OF POWER

## F.2 Steam Generator Natural Circulation Flow Calculation

1. The steam generator gravity head is calculated as follows:

$$\Delta P = \left[ \frac{L_{DWN}}{v_D} - \frac{Z_{riser}}{v_{riser}} - \frac{Z_{drum}}{v_{drum}} \right] \times \frac{ft^3}{1728 \text{ in}^3}$$

- 1.1 The  $L_{DWN}/v_D$  term is calculated by assuming  $v_D = v_f$ .
- 1.2  $Z_{riser} = 161.75 - 97.31 = 64.44$  inches. Assume that the velocity of the steam and recirculation flows are equal. Then,

$$X_{riser} = \frac{W_S}{W_S + W_R} = \frac{1}{R}$$

From LTR-115-51, Performance Evaluation of LOFT Steam Generator and Air Cooled Condenser during the Power Range Test W. C. Townsend, nominal values of the circulation ratio R were chosen. See Figure F.2-1.  $v_{riser}$  is then calculated by:

$$v_{riser} = v_f + X_{riser} v_{fg}$$

- 1.3  $Z_{drum} = 97.31$  inches. This is the height where the inside shroud volume versus level lines (see Figure E-1) for the upper and lower volumes cross. The specific volume of the drum is found by dividing the drum volume by the shroud mass minus the riser mass. The distribution of the mass between the riser and the drum affects the gravity head calculation because the cross sectional areas are not the same.

$$V_{riser} = 17.13 \text{ ft}^3$$

$$V_{\text{drum}} = 71.67 \text{ ft}^3$$

2. Assume that the flow losses are proportional to the square of the downcomer and riser volumetric flow.

$$\begin{aligned} \Delta P &= k_1 \dot{V}_D^2 + k_2 \dot{V}_{\text{riser}}^2 \\ &= k_1 v_D^2 (W_S + W_R)^2 + k_2 (v_g W_S + v_f W_R)^2 \\ &= k_1 v_f^2 R^2 W_S^2 + k_2 (v_g + v_f (R-1))^2 W_S^2 \\ &= \left[ k_1 v_f^2 + k_2 (v_f + X_{\text{riser}} v_{fg})^2 \right] \cdot (RW_S)^2 \\ &= (k_1 v_f^2 + k_2 v_{\text{riser}}^2) (RW_S)^2 \end{aligned}$$

3. Least square fit for  $c_i = a_i k_1 + b_i k_2$

$$\epsilon = \sum (c_i - a_i k_1 - b_i k_2)^2$$

Minimize  $\epsilon$  with respect to  $k_1$  and  $k_2$

$$\frac{\partial \epsilon}{\partial k_1} = 0 = \sum 2 (c_i - a_i k_1 - b_i k_2) (-a_i)$$

$$\sum a_i c_i = (\sum a_i^2) k_1 + (\sum a_i b_i) k_2$$

$$\frac{\partial \epsilon}{\partial k_2} = 0 = \sum 2 (c_i - a_i k_1 - b_i k_2) (-b_i)$$

$$\sum b_i c_i = (\sum a_i b_i) k_1 + (\sum b_i^2) k_2$$

$$\begin{bmatrix} (\sum a_i^2) & (\sum a_i b_i) \\ (\sum a_i b_i) & (\sum b_i^2) \end{bmatrix} \begin{bmatrix} k_1 \\ k_2 \end{bmatrix} = \begin{bmatrix} (\sum a_i c_i) \\ (\sum b_i c_i) \end{bmatrix}$$

$$\begin{bmatrix} k_1 \\ k_2 \end{bmatrix} = \frac{1}{(\sum a_i^2)(\sum b_i^2) - (\sum a_i b_i)^2} \begin{bmatrix} \sum b_i^2 & -\sum a_i b_i \\ -\sum a_i b_i & \sum a_i^2 \end{bmatrix} \begin{bmatrix} \sum a_i c_i \\ \sum b_i c_i \end{bmatrix}$$

$$\begin{bmatrix} k_1 \\ k_2 \end{bmatrix} = \frac{\begin{bmatrix} \sum b_i^2 \sum a_i c_i - \sum a_i b_i \sum b_i c_i \\ \sum a_i^2 \sum b_i c_i - \sum a_i b_i \sum a_i c_i \end{bmatrix}}{(\sum a_i^2)(\sum b_i^2) - (\sum a_i b_i)^2}$$

4. Solve the flow loss equation for R

$$\Delta P = (k_1 v_f^2 + k_2 v_{riser}^2) (R W_S)^2$$

$$\left(\frac{1}{R}\right)^2 \Delta P = W_S^2 \cdot (k_1 v_f^2 + k_2 (v_f + \frac{1}{R} v_{fg})^2)$$

$$\left(\frac{1}{R}\right)^2 \frac{\Delta P}{W_S^2} = v_f^2 k_1 + v_f^2 k_2 + 2\frac{1}{R} v_{fg} v_f k_2 + \left(\frac{1}{R}\right)^2 v_{fg}^2 k_2$$

$$0 = \left(\frac{1}{R}\right)^2 \left(\frac{\Delta P}{W_S^2} - v_{fg}^2 k_2\right) - \left(\frac{1}{R}\right) (2 v_{fg} v_f k_2) - v_f^2 (k_1 + k_2)$$

$$\frac{1}{R} = \frac{2 v_{fg} v_f k_2 + \sqrt{4 v_{fg}^2 v_f^2 k_2^2 + 4 \left(\frac{\Delta P}{W_S^2} - v_{fg}^2 k_2\right) v_f^2 (k_1 + k_2)}}{2 \left(\frac{\Delta P}{W_S^2} - v_{fg}^2 k_2\right)}$$

$$\frac{1}{R} = v_f \left[ \frac{v_{fg} k_2 + \sqrt{v_{fg}^2 k_2^2 + \frac{\Delta P}{W_S} (k_1 + k_2) - v_{fg}^2 k_1 k_2 - v_{fg}^2 k_2^2}}{\frac{\Delta P}{W_S} - v_{fg}^2 k_2} \right]$$

$$R = \frac{1}{v_f} \left\{ \frac{\frac{\Delta P}{W_S} - v_{fg}^2 k_2}{v_{fg} k_2 + \sqrt{k_1 \left( \frac{\Delta P}{W_S} - v_{fg}^2 k_2 \right) + \frac{\Delta P}{W_S} k_2}} \right\}$$

5. The least squares method given in step 3 was used to estimate  $k_1$  and  $k_2$  using R values from Figure F.2-1. Then the equation given in step 4 was used to determine corresponding values of the circulation ratios, R. This process was repeated several times until the R's used for the least squares fit equaled the results of the step 4 equation. The following results were obtained:

	Percent Power		
	<u>100</u>	<u>75</u>	<u>30</u>
Initial R's	5	7	13
Final R's	5.2104	6.6717	13.0688

$$k_1 = 2.2028 \times 10^{-2} \text{ psi}/(\text{cuft}/\text{sec})^2$$

$$k_2 = 7.8888 \times 10^{-4} \text{ psi}/(\text{cuft}/\text{sec})^2$$

Figure F.2-2 shows the gravity head and flow losses as a function of power.

6. Assume that R is a function of power and  $\bar{X}_{shrd}$ :

$$R = \frac{1}{B(P) \cdot \bar{X}_{shrd}}; \quad B(P) = A_0 + A_1 \frac{1}{P}$$

From the values of R computed in Step 5 and the shroud quality values calculated on Data Sheet F.1, the following values of  $\beta$  were obtained:

	Percent Power		
	<u>100</u>	<u>75</u>	<u>30</u>
$\beta(P)$	3.3159	3.4704	4.3976

A least squares fit yields:

$$\beta = 2.8523 + \frac{46.3590}{P}, \text{ Power in percent}$$

$$\beta = 2.8523 + \frac{21974}{\dot{Q}}, \text{ Power in Btu/sec}$$

7. Determine the resulting circulation ratio as a function of power. Assume that the pressure varies linearly with power:  $\text{Press} = 954 - 2.38 \times \text{percent Power}$ .

$$\bar{X}_{\text{shrd}} = \frac{\bar{v}_{\text{shrd}} - v_f}{v_{fg}} = \frac{M_{\text{shrd}} - v_f}{v_{fg}}$$

$$M_{\text{shrd}} = 3583.4 - 19.758 P, \text{ Power in percent (from Mass vs Power curve)}$$

$$R = \frac{1}{\beta(P) \bar{X}_{\text{shrd}}}$$

See plot of data on Figure F.2-1.

DATA SHEET F.2

Power Level	100 %	75 %	30 %	
<u>Downcomer Gravity Head</u>				
Level	126.1	124.5	121.6	inches
v <sub>f</sub>	0.02065	0.02080	0.02102	cuft/lbm
ΔP	3.5339	3.4639	3.3478	psi
<u>Riser Gravity Head</u>				
R	5	7	13	
v <sub>fg</sub>	0.59757	0.56377	0.51678	cuft/lbm
v <sub>riser</sub>	0.1402	0.1013	0.0608	cuft/lbm
ΔP	0.2660	0.3681	0.6133	psi
<u>Drum Gravity Head</u>				
Shroud Mass	1607.6	1966.6	2959.5	lbm
Riser Mass	122.2	169.1	281.7	lbm
Drum Mass	<u>1485.4</u>	<u>1797.5</u>	<u>2677.8</u>	lbm
v <sub>drum</sub>	0.04825	0.03987	0.02676	cuft/lbm
ΔP	1.1671	1.4124	2.1044	psi
<u>TOTAL Head</u>				
ΔP	2.1008	1.6834	0.6301	psi




FIGURE F.2-1

LOFT STEAM GENERATOR PERFORMANCE





FIGURE F.2.2

STEAM GENERATOR FLOW LOSSES AS A FUNCTION OF POWER

F.3 Steam Generator Dry Out Factor

1. Assume that the quality inside the steam drum is linearly distributed with height.



2. Determine  $b$ .

$$x(L_{\text{DRUM}}) = x_{\text{RISER}}$$

$$mL_{\text{DRUM}} + b = x_{\text{RISER}}$$

$$b = x_{\text{RISER}} - mL_{\text{DRUM}}$$

$$\begin{aligned} x(h) &= mh + x_{\text{RISER}} - mL_{\text{DRUM}} \\ &= x_{\text{RISER}} - m(L_{\text{DRUM}} - h) \end{aligned}$$

3. Determine  $m$ .

$$x_{\text{DRUM}} = \frac{1}{L_{\text{DRUM}}} \int_{h_0}^{L_{\text{DRUM}}} x(h) dh$$

$$X_{DRUM} L_{DRUM} = \int_{h_0}^{L_{DRUM}} (X_{RISER} - m(L_{DRUM} - h)) dh$$

$$X_{DRUM} L_{DRUM} = X_{RISER} (L_{DRUM} - h_0) - \frac{m}{2} (L_{DRUM} - h_0)^2$$

$$m = 2 \left\{ \frac{X_{RISER}}{(L_{DRUM} - h_0)} - \frac{X_{DRUM} L_{DRUM}}{(L_{DRUM} - h_0)^2} \right\}$$

4. Determine  $h_0$ .

For case 1,  $h_0$  is the X-axis intercept.

$$X(h_0) = 0$$

$$X_{RISER} - m(L_{DRUM} - h_0) = 0$$

$$h_0 = L_{DRUM} - X_{RISER}/m$$

For case 2,  $h_0 = 0$

5. Solve for m.

Case 1

$$m = 2 \left\{ \frac{X_{RISER}}{X_{RISER}/m} - \frac{X_{DRUM} L_{DRUM}}{(X_{RISER}/m)^2} \right\}$$

$$\pi/2 = m - m^2 X_{DRUM} L_{DRUM} / X_{RISER}^2$$

$$m = \frac{X_{RISER}^2}{2 X_{DRUM} L_{DRUM}}$$

Case 2

$$m = 2 \left\{ \frac{X_{RISER}}{L_{DRUM}} - \frac{X_{DRUM} L_{DRUM}}{L_{DRUM}^2} \right\}$$

$$m = \frac{2 (X_{RISER} - X_{DRUM})}{L_{DRUM}}$$

6. Determine Case 1 and 2 Criteria.

Division between case 1 and 2 occurs when  $m = X_{RISER}/L_{DRUM}$

Case 1 applies for  $m \geq X_{RISER}/L_{DRUM}$ .

$$\frac{X_{RISER}^2}{2 X_{DRUM} L_{DRUM}} \geq \frac{X_{RISER}}{L_{DRUM}}$$

$$X_{RISER} \geq 2 X_{DRUM}$$

Case 2 applies for  $m \leq X_{RISER}/L_{DRUM}$

$$\frac{2 (X_{RISER} - X_{DRUM})}{L_{DRUM}} \leq \frac{X_{RISER}}{L_{DRUM}}$$

$$X_{RISER} \leq 2 X_{DRUM}$$

7. Determine  $L_{DNB}$ .

$$X(L_{DNB}) = X_{DNB}$$

$$X_{RISER} - m (L_{DRUM} - L_{DNB}) = X_{DNB}$$

$$L_{DNB} = L_{DRUM} - (X_{RISER} - X_{DNB})/m$$

8. Solve for the dryout factor.

$$f = L_{DNB}/L_{DRUM}$$

$$f = 1 - (X_{RISER} - X_{DNB})/mL_{DRUM}$$

$$\text{Case 1: } X_{RISER} \geq 2 X_{DRUM}$$

$$f = 1 - 2 (X_{RISER} - X_{DNB}) X_{DRUM}/X_{RISER}^2$$

$$\text{Case 2: } X_{RISER} \leq 2 X_{DRUM}$$

$$f = 1 - (X_{RISER} - X_{DNB})/2 (X_{RISER} - X_{DRUM})$$

9. Values of  $f$  are limited to  $0.01 \leq f \leq 1.0$ .

The upper limit is reached when  $X_{DNB} \geq X_{RISER}$ . In this case no reduction of the heat transfer will occur and  $f$  equals 1. The minimum value of  $f$  is held at 0.01 to simulate the reduction of heat transfer by a factor of 1/100 when DNB is exceeded.

```

1      PROGRAM SGTBL(INPUT,OUTPUT,PUNCH,TAPE5=INPUT,TAPE6=OUTPUT,TAPE15,
2      TAPE7=PUNCH)
3      DIMENSION S(23),P(23,19),CK(23,19)
4      COMMON/LCH/A(8000)
5      LOGICAL ERR
6      LEVEL 2, A
7      N=15
8      NUSE=8000
9      CALL STH2Q1(A,N,NUSE)
10     IF(NUSE.LE.0) STOP 1
11     HK=0.
12     S(9)=1.
13     DO 500 I=1,23
14     VBARI=10.**((I,-1-1.9))
15     PK=20.
16     DP=2.5
17     DO 500 J=1,19
18     HBARJ=300.+J*50.
19     IF(PK.GT.200.) DP=5.
20     IF(PK.GT.400.) DP=10.
21     IF(PK.GT.1300.) DP=20.
22     PK=PK+DP
23     S(2)=PK*6894.8
24     IF(PK.LE.3000.) GO TO 200
25     P(I,J)=3000.
26     GO TO 500
27     200 CALL STH2Q2(A,S,ERR)
28     IF(ERR) GO TO 899
29     VF=S(11)*16.0185
30     VG=S(12)*16.0185
31     HF=S(15)*0.0004299
32     HG=S(16)*0.0004299
33     HK1=HK
34     HK=HF+(VBARI-VF)*(HG-HF)/(VG-VF)
35     IF(HK.LT.HBARJ) GO TO 100
36     P(I,J)=PK-DP+(HBARJ-HK1)*DP/(HK-HK1)
37     CONTINUE
38     500 DO 800 J=1,19
39     WRITE(7,1001)(P(I,J),I=1,23)
40     1001 FGMAT(2,(5X,"1",2X,6(F7.2," ")),5X,"1",2X,7(F7.2," "))
41     899 DO 900 H=1,12,11
42     K=N+11
43     WRITE(6,8)
44     8     FORMAT("1 ENTHALPY",I40,"PRESSURE"//)
45     WRITE(6,10)((1300.-J*50.), (P(I,20-J),I=N,K),J=1,19)
46     10     FORMAT(1X,13F9.2)
47     900 WRITE(6,7)((10.**((I,-1-1.9)),I=N,K)
48     7     FORMAT("0",9X,12F9.5)
49     DO 700 J=1,19
50     S(5)=(300.+J*50.)*2326.
51     DO 700 I=1,23
52     IF(P(I,J).LT.3000.) GO TO 600
53     CK(I,J)=10.
54     GO TO 700
55     600 S(2)=P(I,J)*6894.8
56     CALL STH2Q5(A,S,I,EKR)
57     IF(EKR) STOP 3

```

G-1

APPENDIX G  
 Computer Program Used to Generate the  
 Pressure Versus Volume and Enthalpy Table

LTR-10-2-Rev. C

```

60      700  CK(I,J)=10.0*(10.1-1.9)-S(3)*16.0185
          CONTINUE
          DD 950 N=1,12,11
          K=N+11
          WRITE(6,9)
          9   FORMAT('MIENHALPY',T30,'COMPUTED SP VOL - TABLE SP VOL'//)
          WRITE(6,11)((1300.-J*50.),(CK(I,20-J),I=N,K),J=1,19)
65      11   FORMAT('X',F9.2,12F9.5)
          950 WRITE(6,7)((10.0*(10.1-1.9),I=N,K)
          STOP
          END
    
```

SYMBOLIC REFERENCE MAP (R=3)

ENTRY POINTS DEF LINE REFERENCES

VARIABLES SN TYPE RELOCATION

VARIABLES	SN	TYPE	RELOCATION	4	6	9	27	56		
1544	A	REAL	ARRAY	3	64	DEFINED	53	58		
616	OP	REAL	ARRAY	22	2*36	DEFINED	16	19	20	21
607	ERK	LOGICAL		5	27	28	56	57		
620	HBAKJ	REAL		35	36	DEFINED	18			
623	HF	REAL		2*34	DEFINED	31				
624	HG	REAL		34	DEFINED	32				
612	HK	REAL		33	33	33	DEFINED	11	34	
625	HK1	REAL		2*36	DEFINED	33				
613	I	INTEGER		14	25	36	39	45	47	52
				55	2*58	64	66	DEFINED	13	39
				47	51	64	66			
627	IT	INTEGER		56						
617	J	INTEGER		18	25	36	39	2*45	50	52
				5	58	2*64	DEFINED	17	38	45
626	K	INTEGER		45	47	64	66	DEFINED	42	61
610	N	INTEGER		9	42	45	47	61	64	66
611	NUSE	INTEGER		7	41	60				
657	P	REAL	ARRAY	9	10	DEFINED	8	55		
				3	39	45	52			
615	PK	REAL		25	36					
				19	20	21	22	23	24	36
630	S	REAL	ARRAY	15	22					
				3	27	29	30	31	32	56
614	VBARI	REAL		DEFINED	12	23	50	55		
621	VF	REAL		34	DEFINED	14				
622	VC	REAL		2*34	DEFINED	29				
				34	DEFINED	30				

FILE NAMES MODE

C INPUT  
20 OUTPUT  
40 PUNCH  
60 5

ENTHALPY

PRESSURE

1250.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	2722.92	2238.01
1200.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	2530.26	2088.46
1150.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	2827.13	2350.11	1940.78
1100.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	2601.68	2166.51	1792.23
1050.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	2840.87	2388.35	1646.83
1000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	2578.18	2172.02	1502.64
950.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	2734.50	2324.75	1361.58
900.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	2824.57	2430.85	1223.99
850.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	2473.02	2136.84	1090.33
800.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	1851.96	1591.62	961.27
750.00	3000.00	3000.00	2835.49	2573.16	2315.17	2057.41	1811.43	1579.68	1364.90	1169.00	1355.94	1145.86	837.21
700.00	2659.44	2483.11	2298.75	2097.68	1896.31	1696.41	1506.48	1322.70	1150.58	991.80	991.80	847.73	718.86
650.00	2066.80	1937.97	1804.57	1661.47	1516.77	1370.15	1224.87	1084.49	950.61	825.67	766.97	710.84	606.86
600.00	1547.49	1465.45	1375.80	1279.03	1176.69	1074.69	970.04	866.90	766.97	671.96	671.96	583.33	501.96
550.00	1120.03	1069.78	1013.37	951.56	885.79	816.05	744.65	672.37	601.04	531.95	531.95	466.28	404.96
500.00	778.78	750.03	717.07	680.15	639.75	596.14	550.18	502.67	454.63	407.01	407.01	360.80	316.76
450.00	516.68	501.39	483.62	463.36	440.54	415.32	388.05	359.11	329.04	298.47	298.47	268.01	238.27
400.00	324.00	316.71	308.05	297.94	286.32	273.14	258.50	242.47	225.37	207.43	207.43	189.00	170.53
350.00	189.87	186.78	183.05	178.62	173.41	167.34	160.39	152.57	143.96	134.60	134.60	124.67	114.37
	.01685	.01995	.02512	.03162	.03981	.05012	.06310	.07943	.10000	.12589	.15849	.19953	

G-3

ENTHALPY

PRESSURE

1250.00	2238.01	1832.34	1488.41	1201.62	965.91	773.28	617.13	491.14	389.96	308.98	244.41	193.03
1200.00	2268.48	1710.94	1390.02	1123.53	904.09	744.72	579.08	461.42	366.77	290.93	230.37	182.12
1150.00	1946.78	1589.31	1293.24	1046.39	843.30	716.90	541.57	432.08	343.89	273.10	216.48	171.33
1100.00	1792.23	1469.58	1197.26	970.64	783.30	689.73	504.59	403.17	321.30	255.50	202.78	160.67
1050.00	1646.83	1351.80	1103.18	895.87	724.29	629.32	468.20	374.67	299.04	238.14	189.26	150.14
1000.00	1502.64	1236.09	1010.91	822.68	666.43	537.74	432.40	346.64	277.13	221.04	175.93	139.76
950.00	1361.58	1122.73	920.55	750.84	609.69	493.04	397.29	319.11	255.59	204.21	162.80	129.53
900.00	1223.99	1012.26	832.34	680.77	554.19	449.28	362.86	292.10	234.45	187.68	149.89	119.47
850.00	1090.33	904.87	746.45	612.47	500.08	406.56	329.22	265.67	213.72	171.46	137.21	109.57
800.00	961.27	800.96	663.25	546.16	447.46	364.92	296.39	239.85	193.46	155.58	124.79	99.87
750.00	837.21	700.87	582.95	482.03	396.47	324.52	264.47	214.70	173.68	140.06	112.64	90.36
700.00	718.66	605.09	505.88	420.32	347.26	285.43	233.33	190.27	154.44	124.94	100.78	81.07
650.00	606.86	514.09	432.37	361.26	300.03	247.82	203.67	166.64	135.80	110.26	89.24	72.02
600.00	501.96	428.41	362.65	305.16	255.00	211.82	175.01	143.90	117.80	96.06	78.05	63.22
550.00	404.96	348.65	297.75	252.35	212.40	177.63	147.69	122.14	100.53	82.39	67.26	54.72
500.00	316.76	275.54	237.61	203.25	172.55	145.47	115.47	101.48	84.07	69.32	56.91	46.54
450.00	238.27	209.82	163.05	158.31	135.80	115.61	97.72	82.08	68.54	56.92	47.05	38.72
400.00	170.53	152.31	118.74	118.09	102.57	88.37	75.54	64.12	54.06	45.31	37.77	31.33
350.00	114.37	103.87	93.40	83.18	73.37	64.15	55.60	47.62	40.82	34.60	29.16	24.43
	.19953	.25119	.31623	.39811	.50119	.63096	.79433	1.00000	1.25893	1.58489	1.99526	2.51189

G-4





APPENDIX H  
ANALOG WIRING SCHEMATICS

<u>FIGURE</u>	<u>Title</u>
H-1	Reactor Kinetics Analog Circuitry
H-2	Core Thermal Analog Circuitry
H-3	Primary Coolant Control and Indication Circuitry
H-4	Pressurizer Analog Circuitry
H-5	Secondary Coolant System Analog Circuitry
H-6	Timer and Data Counter
H-7	IHI Program Used to Set Potentiometers
H-8 - H-12	AD10 Tables Used to Set Up the Function Generator

FIGURE H-1  
REACTOR KINETICS ANALOG CIRCUITRY





FIGURE H-2  
CORE THERMAL ANALOG CIRCUITRY







Figure H-3

PRIMARY COOLANT CONTROL AND INDICATION CIRCUITRY

FIGURE H-4  
PRESSURIZER ANALOG CIRCUITRY








Figure H-5

SECONDARY COOLANT SYSTEM ANALOG CIRCUITRY



Data counter

FIGURE H-6

TIMER AND DATA COUNTER

FIGURE H-7

IHI Program Used to Set Potentiometers

FILE: D:\I:\COFSET0.COD DATE: 10-DEC-79 PAGE: 1

```

/CO
01.02 FLOET HYBRID POT SETUP
01.03 #CONSOLE 0
01.04 #0.25/29 C. D. CLAYTON
01.05 #LINE IN,AN CORR-SPRODS TO CORENN, WITH COF000 SET AT LINE 09.99
01.06 #AND COF100 SET AT LINE 10.99.

03.01 CALL INITA(0)
03.02 CALL HOR(0)
03.03 FOR N=1,2
#FIELD 0
10.10 COF010=.2045
10.11 COF011=.4016
10.12 COF012=.3621
10.15 #COF015 THRU 018 SET BY INIT
10.19 COF019=.5000
10.25 #COF025 THRU 027 SET BY INIT
10.29 COF029=-.4000
10.36 COF036=-.0127
10.37 COF037=.0038
10.39 COF039=-.0117
10.40 COF040=.0188
10.45 COF045=.0213
10.46 COF046=-.1150
10.48 COF048=-.3110
10.49 COF049=.0407
10.55 COF055=-.1400
10.56 COF056=.1280
10.57 COF057=-.3870
10.59 COF059=.0260
#FIELD 1
11.10 COF110=.1738
11.24 COF124=0.3
11.37 COF137=.5000
15.05 SET SV=1VFR
15.06 SET ST=.0003
15.10 NEXT N
16.01 WRITE(0,16.02)
16.02 FORMAT('CONSOLE 0 HAND SET POTS')
16.03 PRH COF140
16.04 WRITE(0,16.05)
16.05 FORMAT('4
PRH COF149
16.29 WRITE(0,16.31)
16.30 FORMAT('4
16.31 PRH COF150
16.50 WRITE(0,16.61)
16.61 FORMAT('4
19.99 STOP
RUN
INITIAL POWER TRIM*
PZR PRESSURE TRIM*
FIX PWRT*

```

FIGURE H-8

AD-10 INPUT TABLE

	X	Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	Y9	Y10
1	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
2	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
3	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
4	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
5	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
6	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
7	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
8	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
9	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
10	-0.9200	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
11	-0.7600	-0.8037	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
12	-0.6800	-0.5600	-0.8200	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
13	-0.5000	-0.3382	-0.5928	-0.8252	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
14	-0.5200	-0.0765	-0.3656	-0.6109	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
15	-0.4400	0.1654	-0.1384	-0.3965	-0.8122	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
16	-0.3600	0.4071	0.0888	-0.1822	-0.6198	-0.9521	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
17	-0.2800	0.6488	0.4160	0.0322	-0.4274	-0.7776	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
18	-0.2000	0.8906	0.5432	0.2465	-0.2349	-0.6032	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
19	-0.1200	0.9703	0.4609	0.4609	-0.0425	-0.4288	-0.7306	-0.8571	-1.0000	-1.0000	-1.0000
20	-0.0400	0.9975	0.6752	0.1499	-0.2543	-0.4119	-0.5119	-0.7044	-0.9418	-1.0000	-1.0000
21	0.0400	1.0000	1.0000	0.8896	0.3423	-0.5799	-0.8005	-0.9958	-0.9958	-1.0000	-1.0000
22	0.1200	1.0000	1.0000	1.0000	0.5347	-0.0946	-0.2525	-0.3989	-0.6594	-0.8652	-1.0000
23	0.2000	1.0000	1.0000	1.0000	0.7271	0.2690	-0.0932	-0.2962	-0.5182	-0.7346	-0.9682
24	0.2800	1.0000	1.0000	1.0000	0.9195	0.4435	0.0662	-0.0593	-0.3770	-0.6039	-0.8521
25	0.3600	1.0000	1.0000	1.0000	1.0000	0.6179	0.2256	0.0593	-0.2358	-0.4733	-0.7360
26	0.4400	1.0000	1.0000	1.0000	1.0000	0.7924	0.3849	0.2120	-0.0946	-0.3427	-0.6200
27	0.5200	1.0000	1.0000	1.0000	1.0000	0.9668	0.5443	0.3648	0.0466	-0.2120	-0.5039
28	0.6000	1.0000	1.0000	1.0000	1.0000	1.0000	0.7036	0.5175	0.1877	-0.0814	-0.3878
29	0.7600	1.0000	1.0000	1.0000	1.0000	1.0000	0.8230	0.3289	0.4701	0.0492	-0.2717
30	0.8400	1.0000	1.0000	1.0000	1.0000	1.0000	0.9630	0.5703	0.3289	0.0492	-0.2717
31	0.9400	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.9257	0.6113	0.3165	-0.2395
32	0.9200	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.9257	0.7525	0.4412	0.0766
33	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.8937	0.5718	0.1526

Z1=-0.700 Z2=-0.500 Z3=-0.400 Z4=-0.200 Z5=0.000 Z6=0.200 Z7=0.300 Z8=0.500 Z9=0.700 Z10=1.000

FORMER COPY 1

11/11/77 11:24:55

FIGURE H-9  
AD-10 INPUT TABLE

Z1=0.0000 Z2=0.5000 Z3=0.4000 Z4=-0.2000 Z5=0.0000 Z6=0.2000 Z7=0.3000 Z8=0.5000 Z9=0.7000 Z10=1.0000

X	Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	Y9	Y10
1	-1.0000	-0.5525	-0.6867	-0.9775	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
2	-1.0000	-0.5525	-0.6867	-0.9775	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
3	-1.0000	-0.5525	-0.6867	-0.9775	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
4	-1.0000	-0.5525	-0.6867	-0.9775	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
5	-1.0000	-0.5525	-0.6867	-0.9775	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
6	-1.0000	-0.5525	-0.6867	-0.9775	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
7	-1.0000	-0.5525	-0.6867	-0.9775	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
8	-1.0000	-0.5525	-0.6867	-0.9775	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
9	-0.9200	-0.4629	-0.5941	-0.8782	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
10	-0.8400	-0.3733	-0.5046	-0.7790	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
11	-0.7600	-0.2838	-0.4090	-0.6797	-0.9879	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
12	-0.6800	-0.1943	-0.3165	-0.5805	-0.8806	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
13	-0.6000	-0.1048	-0.2239	-0.4812	-0.7733	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
14	-0.5200	-0.0152	-0.1314	-0.3820	-0.6661	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
15	-0.4400	0.0743	-0.0369	-0.2827	-0.5589	-0.9841	-1.0000	-1.0000	-1.0000	-1.0000
16	-0.3600	0.2704	0.0537	-0.1835	-0.4516	-0.7670	-0.9504	-1.0000	-1.0000	-1.0000
17	-0.2800	0.3571	0.1462	-0.0843	-0.3444	-0.6494	-0.8273	-1.0000	-1.0000	-1.0000
18	-0.2000	0.4438	0.2388	0.0150	-0.2371	-0.5326	-0.7042	-1.0000	-1.0000	-1.0000
19	-0.1200	0.5306	0.3313	0.1142	-0.1299	-0.4155	-0.5810	-0.9816	-1.0000	-1.0000
20	-0.0400	0.6173	0.4238	0.2135	-0.0226	-0.2983	-0.4579	-0.8533	-1.0000	-1.0000
21	0.0400	0.7040	0.5164	0.3127	0.0846	-0.1811	-0.3347	-0.7150	-1.0000	-1.0000
22	0.1200	0.7906	0.6089	0.4120	0.1919	-0.0640	-0.2116	-0.5768	-1.0000	-1.0000
23	0.2000	0.8775	0.7015	0.5112	0.2991	0.0532	-0.0884	-0.4385	-1.0000	-1.0000
24	0.2800	0.9642	0.7940	0.6104	0.4064	0.1704	0.0347	-0.3002	-0.9179	-1.0000
25	0.3600	1.0000	0.8865	0.7097	0.5136	0.2875	0.1579	-0.1619	-0.7578	-1.0000
26	0.4400	1.0000	0.9791	0.8089	0.6209	0.4047	0.2810	-0.0236	-0.4376	-1.0000
27	0.5200	1.0000	1.0000	0.9082	0.7281	0.5219	0.4042	0.1166	-0.2776	-1.0000
28	0.6000	1.0000	1.0000	1.0000	0.8354	0.6300	0.5273	0.2529	-0.1175	-1.0000
29	0.6800	1.0000	1.0000	1.0000	0.9426	0.7562	0.6505	0.3912	0.0426	-0.9576
30	0.7600	1.0000	1.0000	1.0000	1.0000	0.8734	0.7746	0.5295	0.2027	-0.7287
31	0.8400	1.0000	1.0000	1.0000	1.0000	0.9905	0.8968	0.6677	0.3627	-0.4909
32	0.9200	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.8060	0.5228	-0.2710
33	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.9443	0.6829	-0.0421

FIGURE H-10  
AD-10 INPUT TABLE

Y1=0.0000 Y2=-0.4000 Y3=-0.2000 Z4=-0.0000 Z5=0.2000 Z6=0.3000 Z7=0.5000 Z8=0.7000 Z9=0.9000 Z10=1.0000

X	Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	Y9	Y10
1	-1.0000	0.3422	0.4089	0.3519	0.3065	0.2536	0.2256	0.2016	0.1812	0.1717
2	-1.0000	0.3422	0.4089	0.3519	0.3065	0.2536	0.2256	0.2016	0.1812	0.1717
3	-1.0000	0.3422	0.4089	0.3519	0.3065	0.2536	0.2256	0.2016	0.1812	0.1717
4	-0.9333	0.3442	0.4146	0.3615	0.3152	0.2613	0.2326	0.2081	0.1873	0.1775
5	-0.8667	0.3063	0.3303	0.3711	0.3240	0.2855	0.2397	0.2146	0.1933	0.1833
6	-0.8000	0.3184	0.3410	0.3807	0.3327	0.2934	0.2468	0.2212	0.1994	0.1891
7	-0.7333	0.3405	0.3517	0.3904	0.3014	0.2842	0.2538	0.2277	0.2054	0.1949
8	-0.6667	0.3426	0.3624	0.4000	0.3094	0.2918	0.2609	0.2342	0.2114	0.2007
9	-0.6000	0.3447	0.3732	0.4096	0.3173	0.2994	0.2679	0.2408	0.2175	0.2065
10	-0.5333	0.3468	0.3839	0.4192	0.3253	0.3071	0.2752	0.2473	0.2235	0.2123
11	-0.4667	0.3489	0.3946	0.4288	0.3333	0.3147	0.2821	0.2538	0.2296	0.2205
12	-0.4000	0.3510	0.4053	0.4385	0.3413	0.3223	0.2891	0.2604	0.2357	0.2287
13	-0.3333	0.3530	0.4160	0.4481	0.3492	0.3300	0.2962	0.2664	0.2445	0.2369
14	-0.2667	0.3551	0.4268	0.4577	0.3572	0.3376	0.3032	0.2734	0.2533	0.2451
15	-0.2000	0.3572	0.4375	0.4673	0.3652	0.3453	0.3103	0.2801	0.2622	0.2537
16	-0.1333	0.3593	0.4482	0.4769	0.3731	0.3529	0.3174	0.2900	0.2710	0.2624
17	-0.0667	0.3614	0.4589	0.4866	0.3811	0.3605	0.3244	0.2999	0.2798	0.2711
18	0.0000	0.3635	0.4696	0.4962	0.3891	0.3682	0.3339	0.3098	0.2889	0.2797
19	0.0667	0.3656	0.4803	0.5058	0.3970	0.3758	0.3449	0.3197	0.2984	0.2886
20	0.1333	0.3677	0.4911	0.5154	0.4050	0.3864	0.3560	0.3299	0.3078	0.2977
21	0.2000	0.3697	0.5018	0.5250	0.4168	0.3986	0.3670	0.3403	0.3173	0.3069
22	0.2667	0.3718	0.5125	0.5347	0.4297	0.4110	0.3783	0.3507	0.3269	0.3161
23	0.3333	0.3739	0.5232	0.5443	0.4425	0.4234	0.3896	0.3611	0.3364	0.3253
24	0.4000	0.3760	0.5339	0.5539	0.4558	0.4360	0.4010	0.3716	0.3462	0.3346
25	0.4667	0.3781	0.5446	0.5636	0.4692	0.4487	0.4125	0.3821	0.3559	0.3441
26	0.5333	0.3802	0.5553	0.5732	0.4825	0.4614	0.4241	0.3927	0.3658	0.3537
27	0.6000	0.3823	0.5660	0.5828	0.4959	0.4741	0.4358	0.4035	0.3758	0.3634
28	0.6667	0.3844	0.5767	0.5924	0.5093	0.4870	0.4476	0.4143	0.3857	0.3730
29	0.7333	0.3865	0.5874	0.6020	0.5227	0.4998	0.4593	0.4252	0.3957	0.3826
30	0.8000	0.3886	0.5981	0.6116	0.5362	0.5126	0.4712	0.4362	0.4060	0.3925
31	0.8667	0.3907	0.6088	0.6212	0.5498	0.5257	0.4831	0.4473	0.4163	0.4024
32	0.9333	0.3928	0.6195	0.6308	0.5635	0.5387	0.4952	0.4583	0.4267	0.4124
33	1.0000	0.3949	0.6302	0.6404	0.5773	0.5519	0.5073	0.4694	0.4371	0.4223

FIGURE H-11  
AD-10 INPUT TABLE

Z1=0.6000 Z2=0.4000 Z3=0.2000 Z4=0.0000 Z5=0.2000 Z6=0.3000 Z7=0.5000 Z8=0.7000 Z9=0.9000 Z10=1.0000

	X	Y1	Y2	Y3	Y4	Y5	Y6	Y7	Y8	Y9	Y10
1	-1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
2	-1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
3	-1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
4	-0.9333	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
5	-0.8667	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
6	-0.8000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.9224
7	-0.7333	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.9777	0.6935
8	-0.6667	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.7814	0.4646
9	-0.6000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.8556	0.5851	0.2357
10	-0.5333	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.7956	0.3887	0.0069
11	-0.4667	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.8753	0.6355	0.1924	-0.0069
12	-0.4000	1.0000	1.0000	1.0000	1.0000	0.9631	0.9014	0.7370	0.4754	-0.0039	-0.4509
13	-0.3333	1.0000	1.0000	1.0000	0.9470	0.8459	0.7783	0.5987	0.3153	-0.2003	-0.6798
14	-0.2667	1.0000	0.9671	0.9160	0.8398	0.7288	0.6551	0.4605	0.1553	-0.3966	-0.9086
15	-0.2000	0.9333	0.4745	0.4168	0.7325	0.6116	0.5320	0.3222	-0.0048	-0.5929	-1.0000
16	-0.1333	0.2766	0.7820	0.7175	0.6253	0.4944	0.4088	0.1839	-0.1649	-0.2853	-1.0000
17	-0.0667	0.2399	0.6894	0.6183	0.5180	0.3773	0.2857	0.0456	-0.3249	-0.9856	-1.0000
18	0.0000	0.5531	0.5969	0.5190	0.4108	0.2601	0.1626	-0.0926	-0.4950	-1.0000	-1.0000
19	0.0667	0.5861	0.5043	0.4194	0.3035	0.1429	0.0394	-0.2309	-0.6451	-1.0000	-1.0000
20	0.1333	0.3796	0.4138	0.3206	0.1963	0.0258	-0.0837	-0.3692	-0.8052	-1.0000	-1.0000
21	0.2000	0.3929	0.3193	0.2213	0.0890	-0.0914	-0.2069	-0.5075	-0.9652	-1.0000	-1.0000
22	0.2667	0.3062	0.2267	0.1221	-0.0182	-0.2086	-0.3300	-0.6458	-1.0000	-1.0000	-1.0000
23	0.3333	0.2194	0.1342	0.0228	-0.1255	-0.3252	-0.4532	-0.7840	-1.0000	-1.0000	-1.0000
24	0.4000	0.1327	0.0416	-0.0764	-0.2327	-0.4429	-0.5763	-0.9223	-1.0000	-1.0000	-1.0000
25	0.4667	0.0460	-0.0509	-0.1357	-0.3400	-0.5601	-0.6995	-1.0000	-1.0000	-1.0000	-1.0000
26	0.5333	-0.0408	-0.1434	-0.2749	-0.4472	-0.6772	-0.8226	-1.0000	-1.0000	-1.0000	-1.0000
27	0.6000	-0.1275	-0.2460	-0.3741	-0.5545	-0.7944	-0.9458	-1.0000	-1.0000	-1.0000	-1.0000
28	0.6667	-0.2142	-0.3285	-0.4734	-0.6617	-0.9116	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
29	0.7333	-0.3010	-0.4211	-0.5726	-0.7690	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
30	0.8000	-0.3877	-0.5136	-0.6719	-0.8763	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
31	0.8667	-0.4744	-0.6061	-0.7711	-0.9635	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
32	0.9333	-0.5612	-0.6987	-0.8704	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000
33	1.0000	-0.6479	-0.7912	-0.9496	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000	-1.0000

FIGURE H-12

AD-10 INPUT TABLE

LINE NO.	Y	X	FUNCTION GROUP
1	-1.0000	-1.0000	
2	-1.0000	-1.0000	
3	-1.0000	-1.0000	
4	-1.0000	-1.0000	
5	-1.0000	-1.0000	
6	-1.0000	-1.0000	
7	-1.0000	-1.0000	
8	-1.0000	-1.0000	
9	-1.0000	-1.0000	
10	-1.0000	-1.0000	
11	-1.0000	-1.0000	
12	-1.0000	-1.0000	
13	-1.0000	-1.0000	
14	-1.0000	-1.0000	
15	-1.0000	-1.0000	
16	-1.0000	-1.0000	
17	-1.0000	-1.0000	
18	-1.0000	-1.0000	
19	-1.0000	-1.0000	
20	-1.0000	-1.0000	
21	-1.0000	-1.0000	
22	-1.0000	-1.0000	
23	-1.0000	-1.0000	
24	-0.6094	-0.6094	
25	-0.5064	-0.5064	
26	-0.4061	-0.4061	
27	-0.2121	-0.2121	
28	-0.0231	-0.0231	
29	0.1637	0.1637	
30	0.2574	0.2574	
31	0.4537	0.4537	
32	0.6587	0.6587	
33	1.0000	1.0000	

APPENDIX ICONDENSATE VELOCITY IN THE AIR-COOLED CONDENSER TUBESI.1 Flow Method

Assume that at maximum flow the tubes are half full of condensate.

$$W_{\max} = \frac{\dot{Q}_{\max}}{SG \quad CR} (h_g - h_f)$$

$$\dot{Q}_{\max} = 194,626,016 \text{ Btu/hr (Reference 6, page 258, Table XXXIII)}$$

$$h_g = 1200 \text{ Btu/lbm}$$

$$h_f \text{ at } 300 \text{ psi} = 394 \text{ Btu/lbm}$$

$$W_{\max} = 67 \text{ lbm/sec}$$

$$\dot{V}_{\max} = W_{\max} / \rho \quad \rho = \frac{1}{0.01889} \text{ (saturated water at 300 psi)}$$

$$\dot{V}_{\max} = 1.2656 \text{ cu ft/sec}$$

$$\text{Cross sectional area} = \left( \begin{array}{c} \text{fraction of} \\ \text{tubes filled} \\ \text{with condensate} \end{array} \right) \left( \begin{array}{c} \text{cross} \\ \text{section} \\ \text{of tubes} \end{array} \right) \left( \begin{array}{c} \text{number} \\ \text{of} \\ \text{tubes} \end{array} \right)$$

$$A = \left( \frac{1}{2} \right) \left( \frac{\pi}{4} \left( \frac{0.83}{12} \right)^2 \right) (230 \times 3) = 1.2963 \text{ ft}^2$$

$$v = \dot{V}_{\text{max}} \quad A = 0.9763 \text{ ft/sec}$$

## I.2 Friction Loss Method

Assuming that the tubes are half full

$$\text{Equiv. Diameter} = 4 \times \text{hydraulic radius} = 4 \times \frac{\text{area}}{\text{wetted perimeter}}$$

$$= 4 \frac{\frac{1}{2} \frac{\pi}{4} (0.83)^2}{\frac{1}{2} \pi (0.83)} = 0.83 \text{ inches}$$

Absolute roughness from Reference 10, page 3:

$$\epsilon = 0.001$$

Relative Roughness

$$\frac{\epsilon}{D} = \frac{0.001}{0.83} \times 12 = 0.01446$$

Reynolds number (assume 1 ft/sec)

$$R_e = \frac{(0.83/12 \text{ ft}) (1 \text{ ft/sec})}{\left(0.01889 \frac{\text{ft}^3}{\text{lbm}}\right) (0.13 \text{ centipoise}) \left(\frac{0.000672 \text{ lbm/ft sec}}{\text{centipoise}}\right)}$$

$$= 42,000$$

Friction Factor from Crane Technical Paper No. 410, Flow of Fluids, page A-24:

$$f = 0.044$$

Darcy's Formula:

$$v = \sqrt{\frac{h_L D^2 g}{L f}}$$

$$v = \sqrt{\frac{(1 \text{ ft}) (0.83/12 \text{ ft})^2 (32 \text{ ft/sec}^2)}{(44 \text{ ft}) (0.044)}} = 1.512 \text{ ft/sec}$$

APPENDIX JFEEDWATER SYSTEM CALCULATIONSJ.1 Subcooler Heat Transfer Coefficient

Assume 10°F subcooling at feed flow corresponding to 50 MW operation.

$$(1) \quad Q = W C_p (T_{CR} - T_{FW}) \quad T_{FW} = T_{CR} - \frac{Q}{WC_p}$$

$$(2) \quad Q = UA (T_{FW} - T_{AMB})$$

$$Q = UA \left( T_{CR} - \frac{Q}{WC_p} - T_{AMB} \right)$$

$$Q = \frac{UA}{C_p} \left( h_{CR} - \frac{Q}{W} - h_{AMB} \right)$$

$$\frac{UA}{C_p} = \frac{Q}{h_{CR} - h_{AMB} - \frac{Q}{W}} = \frac{W C_p \Delta T}{h_{CR} - h_{AMB} - C_p \Delta T}$$

$$W = 60 \text{ lbm/sec}$$

$$\Delta T = 10^\circ\text{F}$$

$$C_p = 1.093 \text{ Btu/lbm } ^\circ\text{F}$$

$$h_{CR} = 394.0 \text{ Btu/lbm}$$

$$h_{AMB} = 100 \text{ Btu/lbm}$$

$$\frac{UA}{C_p} = \frac{(60)(10.93)}{(294 - 10.93)} = 2.3167 \text{ lbm/sec.}$$

## J.2 Feedwater Pump Internal Resistance

Shut off head        2360 ft (Pacific Pump Data Sheet)

$$(2360 \text{ ft}) (53.36 \text{ lbm/ft}^3) (\text{ft}^2/144 \text{ in}^2) = 874.51 \text{ psi}$$

head at 600 gpm = 2040 ft

$$\Delta h = 2360 - 2040 = 320 \text{ ft} \quad 118.5778 \text{ psi}$$

$$\frac{600 \text{ gal}}{\text{min}} \times \frac{1 \text{ ft}^3}{7.48 \text{ gal}} \times \frac{53.36 \text{ lbm}}{\text{ft}^3} \times \frac{\text{min}}{60 \text{ sec}} = 71.3369 \text{ lbm/sec}$$

$$R_p = \frac{118.5778}{(71.3369)^2} = 0.02330 \text{ psi/(lbm/sec)}^2$$

APPENDIX KANALOG/DIGIT INTERFACE

<u>IDAC</u>	<u>DAC</u>	<u>Variable</u>	<u>Use</u>
1	030	$Q_{CLAD}/MCCL * 2E-4$	Core Thermal
2	031	SGLVL/400	Chart 2-3
3	052	SDL/20	RKS
4	053	$\Delta SDL/2$	RKS/Chart 2-8
5	130	-KFC/100	Core Thermal
6	131	DECAY/100	RKS
7	132	$(TBM(19) - 600)/100$	$T_{AVE}$ /Chart 1-2
8	133	$(TBM(38) - 600)/100$	$T_{AVE}$ /Chart 1-4
9	150	WFW/500	Chart 1-8
10	151	WS/500	Chart 1-7
11	152	WPCS * FLOSC * E-7	Chart 2-6
12	153	PRLEV/100	Chart 1-6

<u>IDAC</u>	<u>DCU's</u>	<u>Variable</u>	<u>Use</u>
13	000	$(CBAR-1500) * 5E-4$	Chart 2-7
14	001	XMSCV	Chart 2-5
15	002	PCR/500	Chart 2-1
16	003	VWCR/400	Chart 2-2
17	004	PSG * 5E-4	Chart 2-4
18	005	$(THLI--600)/100$	Misc. Indication

APPENDIX K (Cont'd)

## ANALOG/DIGIT INTERFACE

---

<u>IARY</u>	<u>ADC</u>	<u>Variable</u>	<u>Use</u>
1	040	$(T_{CLAC}-600)/500$	A055
2	041	$-VWP/200$	D050
3	042	$(PPR-2000) * E-3$	A110
4	043	$XW * 5$	T131
5	044	$(1-XG) * 5$	T133
6	045	$-(TFUEL-1000) * E-3$	A018
7	046	RPA/100	A047

---

<u>JDAC</u>	<u>DAC</u>	<u>Variable</u>	<u>Use</u>
1	032	$(h_w - 675)/125$	Pressurizer
2	033	$(h_g - 1100)/150$	Pressurizer
3	050	$-M_w/2000$	Pressurizer
4	051	Mg/500	Pressurizer

---

```

0001 PROGRAM PLAN14
0002 INCLUDE 'DK1:COMM14.FTN/LIST'
0003 * DIMENSION DAT(128),PA(256),IPA(33),PSGT(23,19)
0004 * COMMON /DAT/
*      1 TIM,      RPA,      VLOOP,      PLA,      PPR,      ! 1-5
*      2 WG,      OCLAD,     SPL,      QSG,      PSG,      ! 6-10
*      3 PCR,      XFEW,     WFW,      XMSCV,     CP,      ! 11-15
*      4 PANG,     TCLAD,     CRAR,     TCL1,     PZRMW,     ! 16-20
*      5 PZRHV,     WRABV,     DLMSP,     WR,      HEW,      ! 21-25
*      6 WENC,     WBNC,     WCNC,     PZRMG,     ! 26-29
*      7 WPCS,     WCORE,     DCVHT,     TTUBF(3),  GATR(3),   ! 30-38
*      8 WAIF(3),   RODPOS,    PZRHG,     DLMOD,     DLF,      ! 39-45
*      9 DLR,      DCR,      XRISE,     PMASS,     HWCR,     ! 46-50
*      0 DMSHT,     TRM(51),  SGLVL,     SGV,      HDWN,     ! 51-105
*      1 DWMASS,    SGMASS,    ND,      SHRD,     HSG,      ! 106-110
*      2 WSGRV,     CRMSTM,    CRHSTM,    CONDMF,    CRHW,     ! 111-115
*      3 HWPR,     HGPR,     PZROMT,    CRMW,     DLMRT,     ! 116-120
*      4 VCRP,     DEXT,     RPI,      THLT,     PLI,      ! 121-125
*      5 VLT,     PRIEV,     TEUFL,     ! 126-128
0005 * COMMON /PA/
*      1 RPSCRM,   HTSCRM,   VSCRM,   HPSCRM,   LPSCRM,   ! 1-5
*      2 TCRP,     TCHLT,   TCLF,   TCLP,   KSURGE,   ! 6-10
*      3 DELT,     SMTSLO,  WPCSI,   ALPHAR,   SCILY,    ! 11-15
*      4 SMTST,     SVTC,   DOPC,   DPP0,   TCCLT,    ! 16-20
*      5 STHKKG,    VSER(60),  SSP,   HTSHP,   ! 21-83
*      6 SPACE9(2),  FLTMD,   ELTHX,   RPSP,   PCSP,     ! 84-89
*      7 HTISP,     H2SP,   BASCRM,  SPAC10(3), ! 90-95
*      8 SURMTH,    CLIC,   CPTC,   VDRAIN,   ! 96-99
*      9 VINJ,     RABFR(60),  SPAC1(3), ! 100-163
*      0 FFRMN,    SPACE2(11),  DLS(23),  AIRSW(.),  HAYSW(3), ! 164-204
*      1 SPACE3,   AIRTSL,  WAIRRN(3),  CRRLSP,   CRRLDB,   ! 205-211
*      2 CRRLF,     TAMB,   FWRMP,   FWDLY,   TIMSCM,   ! 212-216
*      3 SPACE4,   DCON,   REACKY,  TIMEX,   SPACES,   ! 217-221
*      4 SVRMPN,   PMSVHS,  PMSVLS,  PMSVDP,  CINO,     ! 222-226
*      5 CKCORE,   CKSG,   RXPWR,   THOT,   SGLSP,    ! 227-231
*      6 PCRT,     SPACE6(2),  PLOOPT,  HAPZR,   ! 232-236
*      7 SPRCNT,   PZLEVI,  LPHPTS,  SPRNOM,   RCDB,     ! 237-241
*      8 RPDH,     SGXDNB,  SGRS1,   SGRS2,   ! 242-245
0006 * COMMON /IPA/
*      1 ITRNTP,   KSCRAM,   TRUNTM,   ISMTM,   IDLZER,   ! 1-5
*      2 KNOHTR,   IC0NC,   IZDP,   ISCEP,   ISVHMP,   ! 6-10
*      3 KHTR,     ISMP,   ISMTD,   IZDM,   ICPHP,   ! 11-15
*      4 KSCMN,    ID,     KSPRA,   KPOR,   KNSPRP,   ! 16-20
*      5 JINJ,     JDRAIN,  IOPMSV,  ICLNSV,   ! 21-24
*      6 IFELMN,   IHPTS,   ! 25-26
*      7 IC015,    IC016,   IC017,   ! 27-29
*      8 IC018,    IC025,   IC026,   IC027,   ! 30-33
0007 * COMMON
*      0 AIRFLD(15),  AIRDOZ,  C(51),   CDPEW,   CELTRN,   !
*      1 CINJ,     CK(51),  CO(51),  CONDR,   CONMF1,   !
*      2 CPAIP,    CPD,     CRDH,   CRDM,   CRDYZ,   !
*      3 CRHF,     CRHG,   CRHST1,  CRHWI,   CRMWI,   !
*      4 CRRL,     CRRLT,  CRSTMI,  CRVF,   !
*      5 CRXG,     CRXW,   CVFW,   !
*      6 CVFWI,    CVMSCF(14),  CVMSCF,  C2RO,   DECAY(8), !
*      7 DELTAD,   DENCOR,  ! DHBPF,   DHMF,   !

```

L-1

PLAN14 DIGITAL PROGRAM LISTING

APPENDIX L

/ZTR;BLOCKS/HR

```

*      8 DLHSHR,  DLMDRN,  DLMINJ,  DLMR,
*      9 DLMRC,   DLMRH,   DLMPP,   DLMSP,  DLMSH,
*      0 DDMEM,  DTATR(3), DTOTZ,   DVDH,   DWELL,
*      1 DDMASI,  ERR,     EXTARA,  FANFR(3), FLOLP,
*      2 FLOSC,  FLOTRN,  FLOW,   FLTNSC, FPMAS,
*      3 FWTIM,  GHHP,    GHCP,    GHLP,   H(51),
*      4 HAMB,   HC(51),  HCVAL(51), HDIFF,  HDWNI,
*      5 HF,     HFCTR,  HFTAB(19), HC,     HGAS,
*      6 HGCR,   HGTAB(19), HHL,    HPEF(51), HSC,
*      7 HSCI,   HSGC,   HSGI,   HSP,   HSTMI,
*      8 HSUP,  HTQ,    HTIQ,   H?Q,  HTIT,
*      9 HT?T,  HIDA,   HZDB,   IARY(16), IBSPR,
*      0 IDAC(18), IDELTA,
*      1 IDISC,  IOS,    IOSB(2), IPARM(6), IPRINT,
*      2 ISFT(18), IT,    IYINE,  ITMSW,
*      3 ITR(11), ITRNP,  JDAC(4), JSET(4), KSCRMS, !JSP'S INSERTED SO
*      4 KSCSET, JSP?,   LASTI,  LISTPA(69), LPA(33), !VARIABLES ARE ON
*      5 MCLL,   MCTUR,  MRC,   MKP,   !4 BYTE BOUNDARIES.
*      6 NBR,   JSP1,  NDAT(128), PAHFAD(69), PANGI
0008 *      COMMON
*      1 PANGL,  PCORR,   PCRO,   PCRSP,  PMASSO,
*      2 PLIIC,  PMSVHT, PMSVLT,  PRESSE,  PSATI,
*      3 PSGO,   PSGT1(23,10), PSGT2(23,9), PZRDM,  PZROM,
*      4 PZRHG1, PZRHG1, PZRLS,  PZRHGI,  PZRMWI,
*      5 Q(51),  QAIRI,  QCRPI,  QCLPK(4), QCOND(3),
*      6 QCOND1, QCORE,  QDIR,  QDIR1,  QSC,
*      7 RABFRV, RB,     RC,     RCSPT,  REACTN,
*      8 RHO(51), RI,    RMPM,  RMPMSV,  RPIIC,
*      9 RPSPT,  RXRTH,  QCRP,  SCMAS,  SCRAM(R),
*      0 SCRMTM, SOB,    SGBETA,  SGDPZ,  SGHFAD,
*      1 SGHF,   SGHG,   SCK1,   SGK2,   SGLI,
*      2 SGLV11, SGMASI,  SGRH1,  SGRH2,  SGRT1,
*      3 SGRT2,  SGVF,   SGVG,   SGWLC,  SHRDM,
*      4 SHRDV,  SLP(11), SPRAYG,  SPRAYW,  SSPT,
*      5 SUPFLO, SVGT(8), TAIR,  TAUCI,
*      6 TRN(51), TCALC(51), TCLADC,  TCOLD,  THLIC,
*      7 TML,    TIN,    TNOT,  TOUT,
*      8 TSAT,  TSATC,  TSATCR,  TSATSG(19), TSTCRI,
*      9 TTURF1, TWALS(51), UACC,  UAIN(3), UAINI,
*      0 UAOUT(3), UAOUT1, UASC,
*      1 UB(51),  UBCORE,  URF,   URSR,  UFOUL,
*      2 UINE(3), UOUTF(3), V(51),  VAIR,  VAPB,
*      3 VCORE,  VCORR,  VDRUM,  VFTAB(19),
*      4 VGTAB(19), VRRAP,
*      5 VREF,   VRISER,  VSFRD,  VSFRV,  VSTMCR,
*      6 VOTO,   VVTCRI,  VVSS1,  VWCR,  VWCRI,
*      7 VWP,    WATROF(3), WHAY,
*      8 WCAIR(3), WCOND(3), WCOND1,  WCRPV,
*      9 WDRAIN, WDSQ,   WFACC,  WGACC,  WGMIN,
*      0 WINJ,   WS,     WSGI,   WSGRVI,  WSGRV2,
*      1 XDRUM,  XG,     XMSCVL,
*      2 XMSCV0, XSEWT,  XW,     Z(51)
0009 *      COMMON /DATID/ IDAT(512), TNAM, HNAM, NPA
0010 *      EQUIVALENCE (DAT, T10), (PA, RPSCRM), (I?C, ITRNTP), (PSGT, PSGT1)
0011 *      DOUBLE PRECISION PAHEAD, SCRAM, LPA, TNAM, HNAM
0012 *      LOGICAL*1 IDAT, PARE(20), DUMMY(512)

```

L-2

PLANS  
 /TRIBUNES/4P  
 \*\*\*\*\*  
 \*\*\*\*\*

```

0013 * RPAI KFC,MCCL,MRC,MRR,KO,LPSCRM,KSURGE,TPR,
0014 * NDAT,ACTHR,EPHPI5
0015 * INTFGR*4 ITIME,INCR,IPRINT
0016 * LOGICAL*1 IHR,JHR
0017 * DATA TNAM,HRAMZ2*PLAN14**
0018 * CALL DATID(1,2,0)
0019 * IDISC=0
0020 * TYPE101
0021 * FORMAT(1X,'LOFT? ',5)
0022 * ACCEPT 99R,IHR,JHR
0023 * FORMAT(2A1)
0024 * NHR=IHR
0025 * NHR=NHR+NHR-136
0026 * IF(NHR.NE.8) GO TO 103
0027 * PAUSE
0028 * GO TO 100
0029 * IF (NHR.GT.16)NHR=NHR-16
0030 * IF(NHR.NE.8)GO TO 102
0031 * CALL MAIN
0032 * GO TO 100
0033 * IF (NHR.NE.9,A=0,NHR.NE.2)GO TO 104
0034 * CALL DUMP
0035 * GO TO 100
0036 * IF(NHR.NE.16) GO TO 105
0037 * TYPE 999
0038 * GO TO 100
0039 * IF(NHR.EQ.5) GO TO 160
0040 * CALL INIT
0041 * GO TO 100
0042 * IF(IDISC.EQ.0)GO TO 161
0043 * TYPE 997
0044 * FORMAT(' ',10X,'CLOSE FILE')
0045 * GO TO 100
0046 * CALL CONS(0)
0047 * CALL DETACH
0048 * CALL EXIT
0049 * FORMAT('0',1PARMFILE-PR1,T16,'TITLE/OPFD-TO',T32,'CHANGE-CH',
0050 * 1 T43,'TRAN TV',-TR1,T59,'IC-IC',T70,'RUN-RN',T80,
0051 * 2 'DSCRIPT/SAVE-DS'/1X,'LIST-LI',T16,'DUMP-DM',T12,
0052 * 3 'OPEN-OP',T43,'SAVE-SA',T59,'DEFTF-DF',T70,'EXIT-EX',
0053 * 4 T80,'FULL PUMP-FD'/1X,'NCR-MC',T16,'HELP-HP'/)
0050 * END
  
```

PROGRAM SECTIONS

NAME	SIZE	ATTRIBUTES
SCODE1	000500	RM,I,COR,I,CL
SPDATA	000014	RM,D,COR,I,CL
SDATA	000376	RM,D,COR,I,CL
SVAFS	001046	RM,D,COR,I,CL
DAT	001003	RM,D,DVR,GRI
PA	002000	RM,D,DVR,GRI
IPA	000102	RM,D,DVR,GRI

PLAN 14, KTR ZP1B1DCK258R

-SSSS- 017664 405H RM, D, DVB, GHI.  
DATED 001022 265 RM, D, DVB, GHI.

TOTAL SPACE ALLOCATED = 026170 5692

NO FPP INSTRUCTIONS GENERATED

PLA14. 1544319 00-FF0-00

```

0001 FUNCTION TABLE (X,F)
0002 DIMENSION F(1)
0003 RMOD=F(1)
0004 OFFSET=F(2)
0005 N=F(3)
0006 PT=DIM(X,OFFSET)/RMOD+4.
0007 I=INT(PT)
0008 FR=PT-I
0009 I=MIN(N,I)
0010 J=MIN(N,I+1)
0011 TABF=F(I)+(F(J)-F(I))*FR
0012 RETURN
0013 END

```

! SPACING BETWEEN INPUT VALUES  
! INPUT VALUE OF THE FIRST TABLE VALUE  
! DIMENSION OF TABLE

PROGRAM SECTIONS

NAME	SIZE	ATTRIBUTES
SCODF1	000314	102 RW,I,CON,I,CL
SIDATA	000040	16 RW,D,COR,I,CL
SVAPS	000026	11 RW,D,COR,I,CL

TOTAL SPACE ALLOCATED = 000402 129

```

0001            SUBROUTINE ZERO(FUNCT,X)
          C
          C        THIS SUBROUTINE FINDS X SUCH THAT FUNCT(X)=0.
          C        'FUNCT' IS THE NAME OF THE FUNCTION SUBROUTINE WHICH DEFINES FUNCT(X)
          C        THE INPUT VALUE OF X IS USED AS THE INITIAL GUESS.
          C        THE OUTPUT VALUE OF X IS DETERMINED TO WITHIN .01%.
          C
0002            DX=X*.1,F=4
0003            DO 300 N=1,20
0004            Y0=FUNCT(X-DX)
0005            Y2=FUNCT(X+DX)
0006            Y1=FUNCT(X)
0007            DY=(Y2-Y0)/2.
0008            IF(DY.EQ.0.) DY=Y1                    ! INFLECTION POINT, BUMP X BY DX.
0009            X=X-Y1*DX/DY                        ! USE NEWTON'S METHOD TO UPDATE X
0010            IF(Y0*Y2.LT.0.) RETURN              ! IF Y0 AND Y2 HAVE DIFFERENT SIGNS
                                                  ! THEY BRACKET THE ZERO VALUE.
          C
0011        300    CONTINUE
0012            TYPE 1, X,Y0,Y1,Y2
0013            1    FORMAT(' SUBROUTINE ZERO FAILED TO CONVERGE. X= ',E20,10/
                          '    ' Y0,Y1,Y2= ',3E20,10)
0014            RETURN
0015            END

```

PROGRAM SECTIONS

NAME	SIZE	ATTRIBUTES
SCODE1	000414    134	RW,I,CON,LCL
\$PDATA	000004    2	RW,D,CON,LCL
\$TDATA	000104    34	RW,D,CON,LCL
SVARS	000026    11	RW,D,CON,LCL

TOTAL SPACE ALLOCATED = 000552    181

DK1:PLAN14,PLAN14=DK1:PLAN14.FTN;10/CO;60/LI:1

9-1

```

0001 SUBROUTINE INIT
0002 INCLUDE 'DK1:COMM14.FTN/NOLIST'
0015 EXTERNAL SGDP,AIRDQ
0016 DATA PAHEAD/'RPSCRM','HTSCRM','VSCRM','HPSCRM','LPSCRM','ICPP',
1 'TCHLT','TCLF','TCLP','KSHRGE','DEL','SMTSLO','FLOW','ALPHAB',
1 'SCOLY','SMTFST','SVTC','DOPC','DPP0','TCCLT','STMLKG',
1 'SSP','HTSUP','FLTMD','FLTMX',
1 'RSP','RCSP','HTISP','HT2SP',
1 'RASCRM','SURMIN','CLIC','CPIC',
1 'VDRAIN','VINJ','FFRNN','AIRTSU',
1 'CRRLSP','CRRLDB','CRRLF','TAMB','FWRMPT','FWDLY','TIMSCN',
1 'DCOR','REACEX','TIMEX','SVRMPN',
1 'PMSVHS','PMSVLS','PMSVDR','CTDD','CKCORE','CKSG',
1 'RXPWR','THOT','SGLSP','PCRT','PLOGPT',
1 'DAPZR','SPRCNT','PZLEVI','LHPIS','SPRNM','RCDB','RPDB',
1 'SGXDR','SGRS1','SGRS2'/

0017 DATA LISTPA/1,2,3,4,5,6,7,8,9,10,
1 11,12,13,14,15,16,17,18,19,20,21,
1 82,83,86,87,88,89,90,
1 91,92,96,97,98,99,100,
1 164,206,210,211,212,213,
1 214,215,216,218,219,220,222,223,
1 224,225,226,227,228,229,230,231,242,
1 235,236,237,238,239,240,241,242,243,
1 244,245/

0018 DATA IPA/
1 'ITRNTP','KSCRAM','IRUNTM','ISMTM','IDIZER',
2 'KNOPTR','ICONC','IZDP','ISCRP','ISVRMP',
3 'KHTR','ISMPI','ISMTD','IZDM','ICRHP',
4 'KSCMN','ID','KSPRA','KPOB','KNSFRR',
5 'JINJ','JDRAIN','IQPMSV','ICLHSV',
6 'IFLNM','IHPIS','IC015','IC016','IC017',
7 'IC018','IC025','IC026','IC027'/

0019 DATA SCRAM/'MANUAL ','HI POWER','HI TEMP','HI PRESS',
1 'LO PRESS','LOW FLOW','RARB ','TIMED '/

0020 DATA HASC/2,3/
0021 DATA HACC,HFOHL,CPATH/0.0151,.2778,.242/
0022 DATA EXTARA/56128./
0023 DATA CONDAR/2210./
0024 DATA DWELL/22.87/
0025 DATA MCTHR/1009.6R/
0026 DATA HAMB,SCMAS/100.,430./
0027 DATA FPMAS/1665./
0028 DATA AIRFLO/2.,0.,15.,0.,65.,84.,100.,114.,126.,137.,148.,156.,
1 164.,170.,174./

C
0029 DATA ISET/0,1,6,7,8,9,10,11,12,13,14,15,64,65,66,67,68,69/
0030 DATA JSET/2,3,4,5/
0031 DATA SLP/300.,450.,11.,7.525E-3,5.607E-3,4.100E-3,2.879E-3,
1 1.782E-3,0.732E-3,-0.429E-3,-1.889E-3/
0032 DATA ITP/300.,450.,11.,50.510,52.171,53.097,53.707,
1 54.339,55.286,56.869,59.474/
0033 DATA V/
1 4*2.54,10*2.43,2*6.87,7.40,12.30,5*2.76,11.84,2*1.56,11.84,
1 4*3.00,2*3.50,4*2.86,9.65,5*5.07,3*7.91,3.28,7.64,6.69,3.28,
1 0.49/

```

0034 C DATA HC/  
1 4\*151.,10\*144.59,2\*536.25,526.41,1333.94,5\*168.93,  
1 725.62,95.57,91.30,693.21,4\*175.65,2\*204.81,4\*167.59,564.85,  
1 5\*296.99,3\*462.76,195.21,455.1,398.59,195.21,29.18/  
0035 C DATA HCWAL/  
1 14\*0.0,2\*61.65,62.49,237.75,5\*83.28,143.66,2\*242.92,1 .66,  
1 4\*90.,2\*124.46,4\*94.14,1588.4,5\*1657.87,3\*115.68,  
1 101.03,207.29,181.13,101.03,1185.56/  
0036 C DATA HREF/  
1 4\*342.55,10\*588.64,2\*10.80,11.29,63.15,5\*21.84,20.64,378.15,  
1 384.81,21.00,4\*25.9,2\*40.99,4\*31.14,165.89,5\*131.75,3\*3.15,  
1 29.74,137.94,120.81,29.74,11657.53/  
0037 C DATA CK/  
1 4\*508.00,10\*170.49,2\*4.37,4.57,2.45,5\*1.56,1.14,2\*49.31,1.14,  
1 4\*1.68,2\*3.11,4\*1.74,17.51,5\*12.06,3\*1.19,1.88,7.83,6.85,1.88,  
1 48.77/  
0038 C DATA Z/  
1 4\*1.375,5\*-1.408,5\*1.408,2\*2.735,-1.751,6\*0.0,-2.583,  
1 -0.958,0.958,2.583,2.433,2\*0.0,-2.083,-.75,5\*0.0,1.858,  
1 5\*2.514,2\*0.0,-1.707,4\*0.0,10.97/  
0039 C DATA SGK1,SGK2/2,2028E-2.7,8888E-4/  
0040 DATA WSGRV1,WSGRV2/25.,25./  
0041 DATA SGRB1,SGRB2/55.,56./  
0042 DATA H1DB,H2DB/30.,15./  
0043 DATA HT10,HT20/2\*22.752/ 1 24KW EACH  
0044 DATA MRC,MRP/45232.,7200./  
0045 DATA SDB/25./  
0046 C DATA MCCL/48.8950/  
0047 DATA VFFF/30.764/  
0048 DATA RC,RR,RL/2.0835,39.5869,3.5408/  
0049 C DATA TSATSG/100.,100.,19.,327.8,381.8,417.4,444.6,467.0,  
1 486.2,503.1,518.2,532.0,544.6,556.3,567.2,577.4,  
1 587.1,596.2,604.87/  
0050 DATA HFTAB/100.,100.,19., 298.5,355.5,394.0,424.2,449.5,471.7,  
1 491.6,509.8,526.7,542.6,557.5,571.9,585.6,598.8,611.7,624.2/  
0051 DATA HGTAB/100.,100.,19., 1187.2,1198.3,1202.9,1204.6,1204.7,  
1 1203.7,1201.8,1199.4,1196.4,1192.9,1189.1,1184.8,1180.2,  
1 1175.3,1170.1,1164.5/  
0052 DATA VFTAB/100.,100.,19., .01774,.01839,.01889,.01934,.01975,  
1 .02013,.02050,.02087,.02123,.02159,.02195,.02232,.02269,  
1 .02307,.02346,.02387/  
0053 DATA VGTAB/100.,100.,19., 4.4310,2.2873,1.54274,1.16095,  
1 .92762,.76975,.65556,.56896,.50091,.44596,.40058,.36245,  
1 .32991,.30178,.27719,.25545/  
0054 DATA CVMSCF/.1,0.,14.,0.,.0223,.0289,.0388,.0520,  
1 .0685,.0907,.1196,.1592,.217,.2805/  
0055 DATA DECFAY/1.,-1.,8.,.96725,.06281,.04844,.03163,.01937/  
0056 DATA SVGT/100.,2000.,8.,.1883,.1750,.1627,.1513,.1408/

0057

DATA PSGT1/

1	189.87	186.78	183.05	178.62	173.41	167.34	160.39	152.57
1	143.96	134.60	124.67	114.37	103.87	93.40	83.18	73.37
1	64.15	55.60	47.82	40.82	34.60	29.16	24.43	
1	324.00	316.71	308.05	297.94	286.32	273.14	258.50	242.47
1	225.37	207.43	189.00	170.53	152.31	134.74	118.09	102.57
1	88.37	75.54	64.12	54.06	45.31	37.77	31.33	
1	516.68	501.39	483.62	463.36	440.54	415.32	388.05	359.11
1	329.04	298.47	268.01	238.27	209.82	183.05	158.31	135.80
1	115.61	97.72	82.08	68.54	56.92	47.05	38.72	
1	778.78	750.03	717.07	680.15	639.75	596.14	550.18	502.67
1	454.63	407.01	360.80	316.76	275.54	237.61	203.25	172.55
1	145.17	121.86	101.48	84.07	69.32	56.91	46.54	
1	1120.03	1069.78	1013.17	951.56	885.79	816.05	744.65	672.37
1	601.04	531.95	466.28	404.96	348.65	297.75	252.35	212.40
1	177.63	147.69	122.14	100.53	82.39	67.26	54.72	
1	1547.19	1465.45	1375.80	1279.03	1176.69	1074.89	970.04	866.90
1	766.97	671.96	583.33	501.96	428.41	362.85	305.16	255.00
1	211.82	175.01	143.90	117.80	96.06	78.05	63.22	
1	2066.80	1937.97	1804.57	1661.47	1516.77	1370.15	1224.87	1084.49
1	950.61	825.67	710.84	606.86	514.09	432.37	361.26	300.03
1	247.82	203.67	166.64	135.80	110.26	89.24	72.02	
1	2659.44	2483.11	2298.75	2097.68	1896.31	1698.41	1506.48	1322.70
1	1150.58	991.80	847.73	718.86	605.09	505.88	420.32	347.26
1	285.43	233.53	190.27	154.44	124.94	100.78	81.07	
1	3000.00	3000.00	2835.49	2573.16	2315.17	2057.41	1811.43	1579.68
1	1364.90	1169.00	993.06	837.21	700.87	582.95	482.03	396.47
1	324.52	264.47	214.70	173.68	140.06	112.64	90.36	
1	3000.00	3000.00	3000.00	3000.00	2751.85	2437.02	2135.62	1851.96
1	1591.62	1355.94	1145.86	961.27	800.96	663.25	546.16	447.46
1	364.92	296.39	239.85	193.46	155.58	124.79	99.87	

0058

DATA PSGT2/

1	3000.00	3000.00	3000.00	3000.00	3000.00	2837.38	2473.02	2136.84
1	1828.57	1551.28	1305.34	1090.33	904.87	746.45	612.47	500.08
1	406.56	329.22	265.67	213.72	171.46	137.21	109.57	
1	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	2824.57	2430.35
1	2073.40	1753.59	1470.42	1223.99	1012.26	832.34	680.77	554.10
1	449.28	362.86	292.10	234.45	187.68	149.89	119.47	
1	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	2734.50
1	2324.75	1961.33	1640.62	1361.58	1122.73	920.55	750.84	609.69
1	493.04	397.29	319.11	255.59	204.21	162.80	129.53	
1	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00
1	2578.18	2172.02	1813.90	1502.64	1236.09	1010.91	822.68	666.43
1	537.74	432.40	346.64	277.13	221.04	175.93	139.76	
1	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00
1	2840.87	2388.35	1990.82	1646.83	1351.80	1103.18	895.87	724.29
1	583.32	468.20	374.67	299.04	238.14	189.26	150.14	
1	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00
1	3000.00	2601.68	2168.51	1792.23	1469.58	1197.26	970.64	783.30
1	629.73	504.19	403.17	321.30	255.50	202.78	160.67	
1	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00
1	3000.00	2827.13	2350.11	1940.78	1589.31	1293.24	1046.39	843.30
1	676.90	541.57	432.08	343.89	273.10	216.48	171.33	
1	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00	3000.00
1	3000.00	3000.00	2530.28	2088.48	1710.94	1390.02	1123.53	904.09
1	724.72	579.08	461.42	366.77	290.93	230.37	182.12	

6-7

```

1 3000.00,3000.00,3000.00,3000.00,3000.00,3000.00,3000.00,3000.00,
1 3000.00,3000.00,2722.92,2238.01,1832.34,1488.41,1201.62, 965.91,
1 773.28, 617.13, 491.14, 389.96, 308.98, 244.41, 193.03/

C
C      DE FD CH IC EX MC OP RN DM PR TO SA LI TR DS
0059  C      GO TO(550,800,250,260,800,800,130,800,400,400,140,500,210,122,500)
1  NBR
0060  80      TYPE*, 'INVALID COMMAND'
0061      GO TO 800

C
C      PARAMETERS FROM DISC ROUTINE
C
0062  400     CONTINUE
0063      IF(IDISC.FQ.0) GO TO 403
0064      TYPE 131
0065      GO TO 800
0066  403     TYPE 405
0067  405     FORMAT('+',10X,'ENTER PARM FILE NAME: ',S)
0068      ACCEPT 401, PARF
0069  401     FORMAT (20A1)
0070      PARF(20)=0
0071      OPEN(UNIT=2,NAME=PARF,TYPE='OLD',ACCESS='DIRECT',
1         FORM='UNFORMATTED',ERR=800)
0072      READ(2,1,ERR=800)(IDAT(I),I=1,512)
0073      DECODE(4,402,IDAT(452))NPAR
0074  402     FORMAT(14)
0075      READ(2,NPAR+6,ERR=409)(PA(I),I=1,128)
0076      READ(2,NPAR+7,ERR=409)(PA(I),I=129,256)
0077      READ(2,NPAR+8,ERR=409)IPA
0078  409     CLOSE(UNIT=2,DISPOSE='SAVE',ERR=800)
0079      TIM=(IRUNTM+32768)*DELT
0080      SCRMTM=(ISMTM+32768)*DELT
0081      GO TO 800

C
0082  500     IRUNTM=TIM/DELT-32768.
0083      ISMTM=SCRMTM/DELT-32768.
0084      WRITE(2,1PARM(5),ERR=800)(PA(I),I=1,128)
0085      WRITE(2,1PARM(5)+1,ERR=800) (PA(I),I=129,256)
0086      WRITE(2,1PARM(5)+2,ERR=800) IPA
0087      CALL DATID(72/NBR,2,1PARM(5)-6)
0088      IDISC=0
0089      GOTO 800
0090  550     CLOSE(UNIT=2,DISPOSE='DELETE')
0091      TYPE 551
0092  551     FORMAT('+',10X,'FILE DELETED')
0093      IDISC=0
0094      GOTO 800

C
0095  122     TYPE 920
0096  920     FORMAT(1X,'ENTER TRANSIENT TYPE',2X,S)
0097      ACCEPT*, ITRNTP
0098      GO TO 123

C
C      DISC SETUP
C
0099  130     IF(IDISC.FQ.0)GO TO 132

```

L-10

```
0100 TYPE 131
0101 131 FORMAT('+',10X,'CLOSE OLD FILE')
0102 GO TO 800
0103 132 CALL DATID(3*(NBR-7)/4,2,0)
0104 IPARM(2)=512
0105 IPARM(4)=0
0106 IPARM(5)=6
0107 CALL SFTFF(3)
0108 IOSB(1)=1
0109 IDISC=1
0110 GO TO 800

C
C LIST ROUTINE
C
0111 210 OPEN(UNIT=6,TYPE='NEW',NAME='INIT.LST',RECORDSIZE=132)
0112 WRITE(6,908) (IDAT(I),I=1,72),(IDAT(I),I=456,495)
0113 WRITE(6,910) (IDAT(I),I=73,144)
0114 IF(KSCRAM.F0.0)GO TO 211
0115 I=NINT(LOG(FLOAT(KSCHAM))/LOG(2.)))+1
0116 PRINT 940, TIM, SCRMN, SCRAM(I)
0117 940 FORMAT(1X,'RUN TIME=',F8.2,'SEC SCRAM TIME=',F8.2,
1 'SEC SCRAM TYPE=',A8)
0118 211 PRINT 930
0119 DO 220 I=0,5
0120 WRITE(6,907) (PAHEAD(10*I+J),LISTPA(10*I+J)),J=1,10)
0121 WRITE(6,906) (PA(LISTPA(10*I+J))),J=1,10)
0122 220 CONTINUE
0123 WRITE(6,907) (PAHEAD(J),LISTPA(J)),J=61,69)
0124 WRITE(6,906) (PA(LISTPA(J))),J=61,69)
0125 PRINT 914,'AIRSW (199-201)', 'HAYSW (202-204)', 'WAIRMN (207-209)'
0126 PRINT 912,AIRSW,HAYSW,WAIRMN
0127 PRINT 914,'VSEF (22-81)'
0128 WRITE(6,912) VSEF
0129 PRINT 914,'RABER (101-160)'
0130 WRITE(6,912) RABER
0131 PRINT 914,'DLS (176-198)'
0132 WRITE(6,912) DLS
0133 PRINT 930,(LPA(I),I=1,4),(LPA(I),I=21,27)
0134 PRINT 931,(LPA(I),I=1,4),(LPA(I),I=21,27)
0135 PRINT 930,(LPA(I),I=28,5,-1)
0136 PRINT 931,(LPA(I),I=28,5,-1)
0137 PRINT 930,(LPA(I),I=28,33)
0138 PRINT 932,(LPA(I),I=28,33)
0139 930 FORMAT(3X,16A8)
0140 931 FORMAT(1X,15,15I8)
0141 932 FORMAT(1X,17,15I8)
0142 PRINT 930
0143 WRITE(6,910) (IDAT(I),I=1,52)
0144 941 CLOSE(UNIT=6,DISP='PRINT')
0145 GO TO 800

C
C CHANGE ROUTINE
C
0146 250 TYPE 917
0147 917 FORMAT('+',10X,'ENTER:INDEX,VALUE OR INDEX1-INDEX2 (<CR>=RTN)')
0148 251 TYPE 918
```



```

0197      H1=HREF(1)*(FLOW*.95/VREF)**.R
0198      HACORE=(1./ZCKCORE+1./H1)**-1
0199      FSCORE=(1.+1./(.95*(WC/HACORE-DELT*FLOW/V(1))))**-.1
0200      TCLADC=TCOLD+OCORE/(.95*WC*(1.-FCORE**4))-QDIRI/UACORE
0201      H5=HREF(5)*(FLOW/VREF)**.R
0202      HASG=(1./ZCKSG+1./H5)**-1
0203      FSG=(1.+1./(.95*(WC/HASG-DELT*FLOW/V(5))))**-.1
0204      TSATC=THOT*(TCOLD-THOT)/(1.-FSG**10)
0205      TSAT=TSATC

```

C  
C DETERMINE THE TEMP OF EACH NODE (TCALC'S) AND INITIALIZE TBM AND TWALL

```

C CORE
0206      XX=(TCLADC+QDIRI/UACORE)*(1.-FCORE)
0207      TCALC(1)=XX*(1.-.95*FLOW*DELT/V(1))+(FCORE+.95*FLOW*
1      DELT/V(1))*(1.-FCORE)**TCOLD
0208      TBM(1)=TCALC(1)
0209      TWALL(1)=TCLADC
0210      DO 281 K=2,4
0211      TCALC(K)=XX+TCALC(K-1)*FCORE
0212      TBM(K)=TCALC(K)
0213      TWALL(K)=TCLADC

```

```

C STEAM GENERATOR
0214      YY=TSATC*(1.-FSG)
0215      TCALC(5)=YY*(1.-FLOW*DELT/V(5))+(FSG+FLOW*DELT/V(5)*
1      (1.-FSG))*THOT
0216      TBM(5)=TCALC(5)
0217      TWALL(5)=TSATC
0218      DO 282 K=6,14
0219      TCALC(K)=YY+TCALC(K-1)*FSG
0220      TBM(K)=TCALC(K)
0221      TWALL(K)=TSATC

```

```

C CORE UPPER PLENUM
0222      DO 2825 K=15,16
0223      TCALC(K)=TCOLD+OCORE/(.95*WC)
0224      TBM(K)=TCALC(K)
0225      TWALL(K)=TCALC(K)

```

```

C HOT LEG
0226      DO 283 K=17,25
0227      TCALC(K)=THOT
0228      TBM(K)=THOT
0229      TWALL(K)=THOT

```

```

C COLD LEG AND RABV
0230      DO 284 K=26,50
0231      TCALC(K)=TCOLD
0232      TBM(K)=TCOLD
0233      TWALL(K)=TCOLD
0234      TCCLT=TCOLD
0235      TAUCB=DELT/TCCLT

```

```

C CORE BYPASS
0236      TCALC(51)=TCOLD+(20./WC-DELT/H(51))*QCBPI
0237      TBM(51)=TCALC(51)
0238      TWALL(51)=TCALC(51)

```

C  
C DETERMINE THE INITIAL CONDITIONS OF THE STEAM GENERATOR

C

L-13

```

C STEAM PRESSURE
0239 DO 286 I=5,18
0240 IF(TSATC,LT,TSATSG(I)) GOTO 287
0241 TYPE*, 'PSATI ERROR'
0242 GOTO 800
0243 287 PSATI=100.+100.*((I-5)+(YSATC-TSATSG(I-1))/  
1 (TSATSG(I)-TSATSG(I-1)))
0244 PSG=PSATI
0245 PSGO=PSATI
0246 TSAT=TSATC

C STEAM FLOW
0247 HSTMI=TABLE(PSATI,HGTAB)
0248 HFCRI=TABLE(PCRI,HFTAB)
0249 B=(PASC*(HSTMI-HAMB)-RXBTU)/(HSTMI-HFCRI)
0250 C1=-RXBTU*HASC/(HSTMI-HFCRI)
0251 WSGI=(-B+SQRT(B**2-4.*C1))/2.
0252 WGMIN=WSGI*STMLKG/(RXPWR*.02)
0253 WG=WSGI

C MSCV POSITION
0254 CVMSCI=WSGI/SQRT((PSATI**2-PCRI**2)/2.)
0255 DO 288 I=5,14
0256 288 IF(CVMSCI,LT,CVMSCF(I)) GOTO 289
0257 TYPE*, 'XMSCV0 ERROR'
0258 GOTO 800
0259 289 XMSCV0=0.1*((I-5)+(CVMSCI-CVMSCF(I-1))/  
1 (CVMSCF(I)-CVMSCF(I-1)))
0260 XMSCV=XMSCV0
0261 XMSCVI=XMSCV0

C FEED VALVE POSITION
0262 CDENOM=53.36*(PCRI+DPP0-PSATI-0.0233*WSGI*WSGI)
0263 IF(CDENOM,GT,0.0) GOTO 291
0264 TYPE*, 'CVFW ERROR',CDENOM
0265 GOTO 800
0266 291 CVFWI=WSGI/SQRT(CDENOM)
0267 XSFWI=CVFWI/1.0725
0268 XSFW=XSFWI

C STEAM GEN LEVEL
0269 SGLVLI=SGLSP+.27*WSGI-12.5*XSFWI
0270 SGLI=SGLVLI
0271 SGLVL=SGLI

C SG MASS
0272 SGVG=TABLE(PSATI,VGTAB)
0273 SGVF=TABLE(PSATI,VFTAB)
0274 DWMASS=1.0821*(SGLV'-75.43)/SGVF
0275 DDMFN=(187.2-DWMASS*SGVF)/SGVG
0276 SGBETA=2.8523+21974./RXBTU
0277 SGMASS=2000.
0278 CALL ZFRO(SGDP,SGMASS)
0279 SHRDV=RR.R/SHRDM
0280 294 WD=WR+WSGI

C SG ENERGY
0281 SGHF=TABLE(PSATI,HFTAB)
0282 HDWN=(WSGI*HSTMI+WR*SGHF-RXBTU)/WD
0283 SGV=(276.-DWMASS*SGVF)/SGMASS
0284 VLOGSC=ALOG10(SGV)*10.+19.
0285 IV=VLOGSG
    
```

0286 FRV=VLOGSG-IV  
0287 DO 292 IH=1,10  
0288 P2=PSGT(IV,IH)+(PSGT(IV+1,IH)-PSGT(IV,IH))\*FRV  
0289 IF(PSATI.LE.P2) GO TO 290  
0290 292 P1=P2  
0291 293 TYPE\*, 'PSGT ERROR'  
0292 GO TO 800  
0293 290 IF(IH.EQ.1) GO TO 293  
0294 HSGT=50.+(IH-(P2-PSATI)/(P2-P1))+300.  
0295 HSGC=(HSTMI\*DOMEM+(SGMASS-DOMEM)\*(SGHF+SHRDX\*(HSTMI-SGHF)))/  
1 SGMASS  
0296 SGMASI=SGMASS  
0297 DWMASI=DWMASS  
0298 HDWNI=HDWN  
0299 HSG=HSGI  
C FEED WATER  
0300 HSCI=HSTMI-RXBTH/WSCI  
0301 HSC=HSCI  
0302 HFW=HSCI  
C CLAD TEMP IC POT SET  
0303 IC018=(ICLADC-600.)\*20.  
C PRESSURIZER INITIALIZATION  
0304 HF=438.1+0.117\*PLOOP1  
0305 HG=1320.2-0.09\*PLOOP1  
0306 SVF=0.4957E-4\*HF-0.00778  
0307 PZRMWI=(PZLEVI/2.02)/SVF  
0308 SVG=TABLE(PLOOP1,SVGT)  
0309 PZRMGI=(34.75-PZLEVI/2.02)/SVG  
0310 PZRHWI=PZRMWI\*HF  
0311 PZRHGI=PZRMGI\*HG  
0312 JDAC(1)=(HF-675.)\*80.  
0313 JDAC(2)=(HG-1100.)\*66.67  
0314 JDAC(3)=-PZRMWI\*5.  
0315 JDAC(4)=PZRMGI\*20.  
0316 CALL STRLK(JSET,JDAC,1,4)  
0317 IRSPT=0  
0318 SSPT=SSP  
0319 RPSPT=RPSP  
0320 RCSPT=RCSP  
0321 HT1T=HT1SP  
0322 HT2T=HT2SP  
0323 PZRMW=PZRMWI  
0324 PZRHW=PZRHWI  
0325 PZRMG=PZRMGI  
0326 PZRHG=PZRHGI  
0327 HWPR=HF  
0328 HGPR=HG  
0329 DLMSP=0.  
0330 DLMRT=0.  
0331 DMSURT=0.  
0332 PZRMRT=0.  
0333 PPR=PLOOP1  
0334 PPR0=PLOOP1  
0335 PLA=PLOOP1  
0336 PMASS=0.0  
0337 PCORR=(PLA-2200.)\*(0.00025+3.89E-7\*EXP(.01287\*

```

1 (TBM(25)+TBM(26))/2.)
0338 DO 570 K=1,51
0339 RHO(K)=(.0890337-1.4174E-4*TBM(K))*TBM(K)+PCORR
0340 PMASS=PMASS+V(K)*RHO(K)
0341 570 RHO(K)=RHO(K)+41.58 !ADD OFFSET
0342 PMASS0=PMASS
C RKS IC
0343 PNFUT=RXPPW*(1.-0.06725)*100.
0344 IC015=PNFUT*0.29921
0345 IC016=PNFUT*0.67192
0346 IC017=PNFUT*0.16348
0347 IC025=PNFUT*0.13087
0348 IC026=PNFUT*0.09143
0349 IC027=PNFUT*0.006718
C
0350 TYPE 950
0351 950 FORMAT(' ',10X,'SET POTS (Y/N)',S)
0352 ACCEPT 902,ICREST
0353 IF(ICREST.NE.'Y') GOTO 295
0354 CALL SETPOT(1018,IC018)
0355 CALL SETPOT(1015,IC015)
0356 CALL SETPOT(1016,IC016)
0357 CALL SETPOT(1017,IC017)
0358 CALL SETPOT(1025,IC025)
0359 CALL SETPOT(1026,IC026)
0360 CALL SETPOT(1027,IC027)
0361 TYPE 915,'RXPPW','TCOLD','THOT','FLOW','TSATC','PSATI','WSGI',
'XMSCVD'
0362 915 FORMAT(8(3X,A6))
0363 TYPE 916,RXPPW,TCOLD,THOT,FLOW,TSATC,PSATI,WSGI,XMSCVD
0364 916 FORMAT(7F9.2,F9.4)
0365 295 CONTINUE
0366 CALL STREF(1)
0367 CALL HOFF(0)
0368 RPI=RXPPW
0369 PLI=PL00PI
0370 VLI=WPCSI
0371 TH1=THOT
0372 WFW=WSGI
0373 WINJ=VINJ*.1390 !CONVERTS CPM INTO
0374 WDRAIN=VDRAIN*.1390 !LBM/SEC AT 60 F
C
0375 DO 300 I=1,51
0376 300 CO(I) = CLIC
0377 CPO = CPIC
0378 VTOT0 = 0.
0379 VPI = 0.
0380 DELTA0=0.0
0381 FLOSC=1.
0382 PMSVHT=PMSVHS
0383 PMSVLT=PMSVLS
0384 RMPMSV=0.0
0385 FWTIM=0.0
0386 WSCRV=0.0
0387 SGRT1=SGRS1
0388 SGPT2=SGPS2
  
```

INITIALS  
/TR:BLOCKS/WP

0389 CRRT=CRRLSP  
0390 SMPT=SMT  
0391 DHAPF=0.0303\*9.48  
0392 DHMF=0.004675\*9.48  
0393 DLMRC=MRC/3600.\*DELT  
0394 DLMRP=MRP/3600.\*DELT

C  
C CONDENSER

0395 TSATCR=TABLE(PCRI,TS@TSG)  
0396 CRHF=TABLE(PCRI,HFTAB)  
0397 CRHG=TABLE(PCRI,HGTAB)  
0398 CRVF=TABLE(PCRI,VFTAB)  
0399 CRVG=TABLE(PCRI,VGTAB)  
0400 BAYN=BAYSW(1)+BAYSW(2)+BAYSW(3)  
0401 IF(BAYN.GT.0.) GO TO 620  
0402 TYPE\*, 'ACC SECURED - SET BAYSW TO 1'  
0403 GO TO 800  
0404 620 IF(BAYSW(1).EQ.1.) GO TO 625  
0405 BAYSW(1)=BAYSW(2)  
0406 BAYSW(2)=BAYSW(3)  
0407 BAYSW(3)=0.  
0408 GO TO 620  
0409 625 WCOND(1)=WSCI/BAYN  
0410 QCOND(1)=WCOND(1)\*(HSTMI-CRHF)  
0411 HINE(1)=1.77\*WCOND(1)\*\*-.3333  
0412 UAIN(1)=HINE(1)\*UEOHL/(HINE(1)+UEOHL)\*CONDAR  
0413 TTREF(1)=TSATCR-QCOND(1)/UAIN(1)  
0414 WAIR(1)=200.  
0415 CALL ZERO(AIRDO,WAIR)  
0416 650 TAIR=TAMB+459.67+.5\*QAIR(1)/WCAIR(1)  
0417 VAIR=WAIR(1)\*TAIR\*.8898E-3  
0418 DO 651 I=5,15  
0419 651 IF(VAIR.LC.AIRFLO(I)) GO TO 652  
0420 TYPE\*, 'ACC AIRFLO GT 174000 CUBFT/MIN'  
0421 GO TO 860  
0422 652 PANG=2.\*((I-5)+(VAIR-AIRFLO(I-1))/(AIRFLO(I)-AIRFLO(I-1)))  
0423 PANGI=PANG  
0424 PCRSP=PCRI-(PANG-30.\*XMSCV0)/.8475  
0425 PCR=PCRI  
0426 PCR0=PCRI  
0427 DO 655 I=2,3  
0428 TTREF(I)=TTREF(1)\*BAYSW(I)+TSATCR\*(1.-BAYSW(I))  
0429 QCOND(I)=QCOND(1)\*BAYSW(I)  
0430 655 UAIN(I)=UAIN(1)  
0431 CRPLT=CRRLSP  
0432 CONDMEF=WCOND(1)\*BAYN+DWELL  
0433 CRMST=(745.86-(CRMW+CONDMEF)\*CRVF)/CRVG  
0434 CRHF=CRHF\*CRVF  
0435 CRHG=CRMST\*CRHG  
0436 HCCR=CRHF  
0437 HCGR=CRHG  
0438 CRXW=0.  
0439 CRXG=1.  
0440 VVCR=CRVF\*CRMW  
0441

```

0442      VSTMCR=CRVG*CRMSTM
0443      TSTCR1=TSATCK
0444      PANGI=PANG
0445      CONMEI=CONDMF
0446      CRMWI=CRMW
0447      CRSTMI=CRMSTM
0448      CRHWI=CRHW
0449      CRHSTI=CRHSTM
0450      VRCRI=VWCP
0451      VSTCRI=VSTMCR
0452      TTURFI=TTURF(1)
0453      QCONDI=QCOND(1)
0454      QAIRI=QAIR(1)
0455      HAINI=HAIN(1)
0456      HAOUTI=HAOUT(1)

0457      VLOGP=FLOW
0458      ITIME=0
0459      IDELTA=DELT*1000.
0460      IPRINT=0
0461      TMOT = 0.
0462      TIM=0.0
0463      PRINTM=0.0
0464      DEXT=0.0
0465      ITMSW=0
0466      IDS=0
0467      JHPIS=0
0468      KSCRAMS=0
0469      KSCRAM=0
0470      KSCSET=0
0471      LASTI=1
0472      FLOTRN=0.0
0473      IF(ITRNTP,EQ,1)FLOTRN=1.0
0474      CFLTRN=1.-FLOTRN
0475      TIME=0.0
0476      FLTNSC=1.+19.*FLOTRN
0477      REACTN=0.0
0478      IF(ITRNTP,EQ,3)REACTN=1.0
0479      IF(IDISC,EQ,1)GOTO 296
0480      TYPE*, 'OPEN FILE'
0481      GOTO 800
0482      296      IF(IPARM(5),EQ,6) GO TO 310
0483      TYPE*, ' CLOSE OLD FILE AND OPEN NEW FILE'
0484      310      CONTINUE
0485      902      FORMAT(3A1)
0486      906      FORMAT(10F13.4/)
0487      907      FORMAT(10(3X,A6,14))
0488      908      FORMAT('1',72A1,10X,'TASK ',40A1)
0489      910      FORMAT(' ',72A1)
0490      912      FORMAT(10F13.4)
0491      914      FORMAT('0',2X,3(A*6,23X))
0492      800      RETURN
0493      END

```

PROGRAM SECTIONS

FORM 14-100 0-10000-00

FORM 14-100 0-10000-00

NAME	SIZE	ATTRIBUTES
SCODE1	015722	4561
SPDATA	001166	315
\$IDATA	001360	376
\$VARS	001254	342
\$TEMPS	000014	6
DAT	001000	256
PA	002000	512
TPA	000102	33
\$.5555.	017664	4058
DATID	001022	265

TOTAL SPACE ALLOCATED = 045770 9724

```
0001      FUNCTION AIRDQ(FLO)
0002      INCLUDE 'DK1;COMM14.FTN/NOI,IST'
0005      HOUTF(1)=3.784E-5*FLO** .72
0016      HAOUT(1)=HOUTF(1)*UACC/(HOUTF(1)+UACC)*EXTARA
0017      WCAIR(1)=FLO*CPAIR
0018      QAIR(1)=(TTURF(1)-TAMB)*(1.-EXP(-HAOUT(1)/WCAIR(1)))*WCAIR(1)
0019      AIRDQZ=QAIR(1)-QCOND(1)
0020      AIRDQ=AIRDQZ
0021      RETURN
0022      END
```

PROGRAM SECTIONS

NAME	SIZE	ATTRIBUTES
SCODE1	000214 70	RW,I,CON,LCL
SPDATA	000010 4	RW,D,CON,LCL
SI0ATA	000004 2	RW,D,CON,LCL
SVARS	001040 272	RW,D,CON,LCL
DAT	001000 256	RW,D,OVR,GBL
PA	002000 512	RW,D,OVR,GBL
IPA	000102 33	RW,D,OVR,GBL
.SSSS.	017664 4058	RW,D,OVR,GBL
DATID	001022 265	RW,D,OVR,GBL

TOTAL SPACE ALLOCATED = 025300 5472

L-20

PROGRAM 00251 /TRILUCKS/MR 1546740 00-1-10-80

```

0001 FUNCTION SGDP(SGI)
0002 INCLUDE 'FK1:COMM14.FTH/WOLIST'
0015 SHRDM=SGM-DOMFM
0016 SHPDX=(RR.R/SHRDM-SGVF)/(SGVG-SGVF)
0017 XRTSFR=SGFETA*SHRDX
0018 VRTSFR=SGVF+XRTSFR*(SGVG-SGVF)
0019 VDRUM=71.67/(SHRDM-17.13/VRTSFR)
0020 WR=MSG1*(1./XRTSFR-1.)
0021 1 - (SGVL1/SGVF-64.44/VRTSFR-97.31/VDRUM)/172#
SGDP=SGDPZ
0022 RETURN
0023 END
0024

```

PROGRAM SECTIONS

NAME	SIZE	ATTRIBUTES
SCODE1	000302	RW,I,CON,I,CL
SPDATA	000024	RW,D,CON,I,CL
SIDATA	000004	RW,D,CON,I,CL
SVARS	001040	RW,D,CON,I,CL
DAT	001000	RW,D,OVR,GRL
PA	002000	RW,D,OVR,CHL
TPA	000102	RW,D,OVR,GRL
SSSS	017664	RW,D,OVR,GRL
DATIO	001022	RW,D,OVR,GRL

TOTAL SPACE ALLOCATED = 025402 5505

FOR THE EXECUTION OF THE  
INITI4.FTN  
ZTRBLOCKS/MR

```

0001 SUBROUTINE SFTPOT(IADR,N)
0002 CALL STIND(IADR,N)
0003 CALL READ(IADR,NVAL)
0004 IF(IADR.LT.1100) NVAL=-NVAL
0005 IF(ABS(NVAL->).LT.4) GOTO 2
0006 TYPE 100,IADR,NVAL,N,N=NVAL
0007 FORMAT(IX,'POT',I5,',',I5,',',I5,',',I5,',',I5,',',I5)
0008 RETURN
0009 END
    
```

PROGRAM SECTIONS

NAME	SIZE	ATTRIBUTES
\$CODE1	000222	RW,I,CON,I,CL
\$IDATA	000072	RW,D,CON,I,CL
\$VARS	000002	RW,D,CON,I,CL

TOTAL SPACE ALLOCATED = 000316 103

NO FFP INSTRUCTIONS GENERATED

DE1:INITI4,INITI4=K1:INITI4.FTN;10/C0:50/11:1

PROGRAM V02-01 / TRBUICES/WR 00-00-00

```

0001 SUBROUTINE MAIN
0002 INCLUDE 'DK1:COMM14.FTN/NOLIST'
0015 EXTERNAL CRDV
0016 CALL DSINH
0017 IF(ITSTS(0),EQ,1) GOTO 100
0018 GO TO 120
0019 CALL DSINH
0020 IF(ITSTS(0),EQ,0) GO TO 120
0021 TYPE *, 'FRAME TIME EXCEEDED'
0022 RETURN
0023 IF(ITSTS(0),EQ,0) GO TO 120
C
0024 KNHTR=ITSTD(1)
0025 ICONC=ITSTD(2)
0026 IZDP=ITSTD(3)
0027 ISCHP=ITSTD(4)
0028 ISVMP=ITSTD(5)
0029 KHTR=ITSTD(6)
0030 ISMP=ITSTD(7)
0031 ISYD=ITSTD(8)
0032 IZDM=ITSTD(9)
0033 ICPHP=ITSTD(10)
0034 KSCMN=ITSTD(11)
0035 I0=ITSTD(12)
0036 KSPRA=ITSTD(13)
0037 KNUR=ITSTD(14)
0038 KNSPPR=ITSTD(15)
C
0039 IOLZER=ITSTS(1)
0040 JINJ = ITSTS(3)
0041 JDBAFL = ITSTS(4)
0042 IOPMSV=ITSTS(5)
0043 ICLMSV=ITSTS(6)
0044 IFLMN=ITSTS(7)
C
0045 CALL SCARH(0,1ARY,16)
0046 CALL STRK(ISET,IDAC,1,18)
0047 CALL FNIB
C
0048 IF(ITMSW,EQ,1)GOTO 170
0049 IF(ITSMF,NE,0)ITMSW=1
0050 DO 160 I=1,12R
0051 NDATE(1)=DATE(1)
0052 COM' INDE
C
C PRESSURIZER CALCULATIONS
C
0053 PPRU=PPR
0054 PPR=1ARY(3)*0.1+2000.
0055 XW=1ARY(4)*2.E-5
0056 XW=MAX(XW,0.0)
0057 XG=1-1ARY(5)*2.E-5
0058 XG=MIN(XG,1.0)
0059 VMP=-1ARY(2)*.02
0060 HSP=1.25*TRM(34)-140.
0061 HHL=1.25*TRM(21)-140.

```

```

0062 HF=438.1+0.117*PPR
0063 HG=1320.2-0.09*PPR
C
C INJECTION AND DRAIN FLOW
C
0064 IF (PL.I.F.,I,PHPTS)IHPIS=1
0065 JINJ=IHPIS+JINJ-IHPIS+JINI
0066 DELMI=MIN(I,DELTA*JIRJ
0067 DIMDRN = WDRAIN*DELTA*IDRAIN
C
C PCS DENSITY & MASS
C
0068 PMASS=0.0
0069 PCOPR=(PLA-200.0)*(0.00025+3.89E-7*EXP(.01287*
    (TRM(25)+THM(26))/2.))
0070 DO 570 K=1,51
0071 RHO(K)=(0.090337-1.4474E-4*TRM(K))+THM(K)+PCOPR
0072 PMASS=PMASS+RHO(K)*RHO(K)
0073 RHO(K)=RHO(K)+41.58
    IADD OFFSET
C
C PZR SPRAY
C
0074 IHSPPR=KSPRA*(1-KNSPPR)
0075 IF (PPR.GE.SSPT) IHSPPR=1-KNSPPR
0076 SSPT=SSP-SDR*IHSPPR
0077 SPRFLO=SPRNM+IHSPPR+SPRCMT*(1-IHSPPR-KNSPPR)
0078 DELMSP=0.00223*SPRFLO*(VLOOP/22.)*RHO(34)*DELT
0079 SPRAYG = DELMSP*(HF-HSP)
0080 SPRAYW = DELMSP*HF
C
C PZR SURGE
C
0081 DELMSUR=DELMSP+DEMDRN-DEMINJ
0082 IFAHS=(PMASS-PMASS0).LT.SURMIN) GO TO 580
0083 DELMSUR=DELMSUR*(PMASS-PMASS0)
0084 PMASS0=PMASS
0085 IF (DELMSUR.GT.0.0) GO TO 640
0086 HSHR=HHL
0087 SPV=1./RHO(21)
0088 GOTO 700
0089 HSUR=HMPR
0090 SPV=VMP/PZRMW
0091 DELMSUR=DELMSUR*HSUR
0092 SURFLO=DELMSUR*SPV/DELT
C
C PZR RELIEFS
C
0093 RPQD=RPQR*(1-KNSPPR)
0094 RQD=0.
0095 IF (PPR.GF.RPSPT) RPQD=1.-KNSPPR
0096 IF (PPR.GF.RCSPT) RQD=1.
0097 RPSPT=RPSP-RPDA*RPQD
0098 RCSPT=RCS*RP-RCDA*RCQD
0099 DELMR=(DEMRP*RPQD+DEMR0*RCQD)
0100 DELMR = DELMR*HGPR
    
```

FORMAN 00000000 00000000 00000000

MAIN11

PZR HEATERS

0101 HI0D=0.  
 0102 H20D=0.  
 0103 IF(PPR,IF,HT1T) HI0D=1.-KN0HTP  
 0104 IF(PPR,IF,HT2T) H20D=1.-KN0HTP  
 0105 HT1T=HT1SP+H10R+H10D  
 0106 HT2T=HT2SP+H20R+H20D  
 0107 HTQ=(HT10\*H10D+HT20\*H20D+HTSUP\*KHTR)\*DFLT

C PZR AMBIENT LOSSES  
 C PZRL0S=0.5\*UAPZR\*(HF-100.)\*DFLT IHEAT LOSS PER PHASE

C PZR CONDENSATION AND SOIL OFF

0109 PZRDH=PZRMW\*XW-PZRMG\*(1.-XG)  
 0110 PZRDH=PZFMW\*XW+HG-PZRMG\*(1.-XG)\*HF

C PZR MASS AND ENERGY UPDATE

0111 PZRMW=PZRMW-PZRDH-DLMSUR+DI MSP  
 0112 PZRHW=PZRHW-PZRDH+HT0+SPRAYW-DLMSUR-PZRL0S+VWP\*(PPR-PPRO)\*.1851  
 0113 PZPMG=PZPMG+PZRDH-DLMSUR  
 0114 PZRMG=PZRMG+PZRDH-DLMSUR  
 0115 HWPR=PZRDH/PZRMW  
 0116 HGPR=PZRMG/PZPMG  
 0117 JDAC(1)=(HWPR-675.)\*80.  
 0118 JDAC(2)=(HGPR-1100.)\*66.67  
 0119 JDAC(3)=-PZRMW\*5.  
 0120 JDAC(4)=PZRMG\*20.

0121 CALL STRUK(1,SET,JDAC,1,4)  
 0122 DLMSPT=DLMSPT+DI MSP  
 0123 DLMSUR=DLMSUR+DI MSP  
 0124 DMSURT=DMSURT+DI MSP  
 0125 PZRDMT=PZRDH+PZRDH

C PZR LEVFL  
 0126 PRLEV=VWP\*2.02  
 0127 JDAC(12)=PRLEV\*100.

C LOOP PRESSURE  
 0128 PLA=PPR-KSURGE\*SURFLO\*ABS(SURFLO)

C FORM NAT CIRC PRESS

0129 GHC=0.0  
 0130 GHL=RH0(17)\*Z(17)  
 0131 DO 180 I=1,4  
 0132 GHC=GHC+PH0(I)\*Z(I)  
 0133 CONTINUE  
 0134 DO 190 I=5,14  
 0135 GHL=GHL+PH0(I)\*Z(I)  
 0136 CONTINUE  
 0137 DO 200 I=15,16  
 0138 GHL=GHL+PH0(I)\*Z(I)  
 0139 CONTINUE  
 0140 DO 210 I=24,46

FOURTH 10-PLUS 007-51 15:46:57 00-440-00  
MAIN14.FTN ZTRIBLOCKS/MR

```

0141 GHL=GHL+PHO(I)*Z(I)
0142 CONTINUE
0143 GHRP=RRH(51)*7(51)*.00694444
0144 GPCP=GHC*.00694444
0145 GHP=GHI*.00694444
C
C
C
C
FORM FLOWS
0146 TIME=TIME+FLOTR+TIME*CFLTR+DELTA*IFLNN+ISMP
0147 IF(VIME.GT.FLTMX)TIME=FLTMX
0148 FT=(TIME/FLTMD)+1.0
0149 IFT=FT
0150 VSRV=VSRP(IFT)+(VSRF(IFT+1)-VSRF(IFT))*(FT-IFT)
0151 RARPV=RARFP(IFT)*(RARFH(IFT+1)-RARFH(IFT))*(FT-IFT)
0152 FLOLP=FLOW
0153 VSPG=VSPRY
0154 IF(VSRV.IE.FERRN)VSRF0=FFRRN
0155 RCL=VSRF0*PC
0156 RRL=VSRF0*RR
0157 RLI=VSRF0*RL
0158 P1=RCL+RRL+RCL*RLI+RRL*RLI
0159 WINC=((RCL+RRL)*GHP-RRL*GHP-RCL*GHP)/R1
0160 UPNC=((RCL*GHP+RLI*GHP)-(RCL+RLI)*GHP)/R1
0161 WNC=WINC-WNC
0162 IF(IEMP.FO.1)GO TO 220
0163 VCORB=0.95*FLOLP-WCNC
0164 VARP=0.05*FLOLP-WNC
0165 CONTINUE
0166 VPARP=FLOLP+RARPV
0167 VCPRE=VCORB+VSRV+MCN
0168 VCP=VARP+VSRV+MNC
0169 VVSSI=VCORB+VCHP
0170 VLOOP=VARP+VCP
0171 VUP=VLOOP*0.8
0172 VUPHP=VLOOP-VUP
DEFINE WALL TEMPERATURES
C
C
IF(DLZER.FO.1) GO TO 241
0173 DO 230 K=1,4
0174 TWALL(K)=TART(I)*.05+600.
0175 DO 240 K=5,14
0176 TWALL(K)=TSAT
0177 TCLAD = TWALL(1)
0178 MCORE = VCORE*3600.*RRH(23)
0179 WPARV = VPARV*3600.*RRH(23)
0180
C
C
FORM WLOOP
C
0181 WLA6 = VLOOP*3600.*44.11
0182 WPCS = VLOOP*3600.*RRH(23)
0183 IF(TIME.GT.60.)FLOSC=FLTNSC
0184 IDAC(1)=WPCS+FLOSC*.001
C
C
FORM HEAT TRANSFER COEFF BETWEEN WALL, AND FLUID FOR 51 NODES

```

FORM 51 BULK TEMPERATURES

```

0185 AVV=(ARS(VCORE)/VREF)*0.0
0186 H(CORE)=HREF(1)*AVV
0187 H(CORE) = CKCORE*H(CORE)/(CKCORE+H(CORE))
0188 H(15)=HREF(15)*AVV
0189 UR(15) = CK(15)*H(15)/(CK(15)+H(15))
0190 XDRUM=(VDRUM-SGVF)/(SGVG-SGVF)
0191 IF(XDRUM.GT.0.98) GOTO 1400
0192 HRF=1.-(XRISEF-SGXDRM)*2.+(XDRUM/XRISEF)*2
0193 IF(2.*XDRUM.GT.XRISEF) HRF=1.-(XRISEF-SGXDRM)/2.+(XRISEF-XDRUM)
0194 IF(HRF.LT..01) HRF=.01
0195 IF(HRF.GT.1.) HRF=1.
0196 AVLV=(ARS(VLOOP)/VREF)*0.0
0197 H(RSG) = HRF*CKSC*HREF(5)*AVLV/(CKSG+HREF(5)*AVLV)
0198 DO 290 K=19,38
0199 H(K)=HREF(K)*AVLV
0200 UR(K) = CK(K)*H(K)/(CK(K)+H(K))
0201 H(51) = HREF(51)*(ARS(VCRP)/VREF)*0.0
0202 UR(51) = CK(51)*H(51)/(CK(51)+H(51))
0203 H(18) = HREF(18)*(ARS(VWRAP)/VREF)*0.0
0204 UR(18) = CK(18)*H(18)/(CK(18)+H(18))
0205 H(17)=HREF(17)*AVLV
0206 UR(17) = CK(17)*H(17)/(CK(17)+H(17))
0207 AVVV=(ARS(VFESSL)/VREF)*0.0
0208 DO 300 K=39,46
0209 H(K)=HREF(K)*AVVV
0210 UR(K) = CK(K)*H(K)/(CK(K)+H(K))
0211 AVRV=(ARS(VRABP)/VREF)*0.0
0212 DO 310 K=47,50
0213 H(K)=HREF(K)*AVRV
0214 UR(K) = CK(K)*H(K)/(CK(K)+H(K))
0215 H(16)=HREF(16)*AVVV
0216 UR(16) = CK(16)*H(16)/(CK(16)+H(16))
C
C FORM CLAD, STEAM GENERATOR AND PIPE HEAT
C
0217 RPA=TARY(7)*.01
0218 IF (DOLFER.FO.1) RPA =RXPWR
0219 OCHP = RPA*DRBPF*100.
0220 QDIR=DPA*DIRF*100.
0221 DO 330 K=1,4
0222 Q(K) = HRCORE*(TWALL(K)-TBM(K))
0223 QCLPK(K) = Q(K)+QDIR
0224 QCLAD = Q(1)+Q(2)+Q(3)+Q(4)
0225 IDAC(1)=QCLAD*2./MCCL
0226 QSG = 0
0227 DO 350 P=5,14
0228 Q(K)=H(RSG)*(TWALL(K)-TBM(K))
0229 QSG =OSG*Q(K)
C
C SEND CLAD AND STEAM GENERATOR TOTAL HEAT TO ANALOG VIA DAC'S
C
0230 DO 360 K=15,51
0231 Q(K) = UR(K)*(TWALL(K)-TBM(K))
C
C FORM 51 BULK TEMPERATURES
C

```

```

0232 DO 370 K=1,4
0233   TRN(K) = TRN(K)+CLBK(K)*DELT/HC(K)
0234   DO 380 K=5,50
0235     TRN(K) = TRN(K)+Q(K)*DELT/HC(K)
0236     TRN(51)=TRN(51)+DELT*(Q(51)+QCRP)/HC(51)
C
C   FORM 51 BULK MOVE TEMPERATURES
C   PERFORM BOROON TRANSPORT CALCULATION
C
VCD=VCDP*DELT
TRN(1) = TRN(1)+(VCD/V(1))*(TRN(56)-TRN(1))
C(1)=C(1)+VCD/V(1)*(CO(46)-C(1))
DO 390 K=2,4
TRN(K) = TRN(K)+(VCD/V(K))*(TRN(K-1)-TRN(K))
C(K) = C(K)+VCD/V(K)*(CO(K-1)-C(K))
VLD=VLDP*DELT
TRN(5) = TRN(5)+(VLD/V(5))*(TRN(25)-TRN(5))
C(5) = C(5)+VLD/V(5)*(CO(25)-C(5))
DO 400 K=6,14
TRN(K) = TRN(K)+(VLD/V(K))*(TRN(K-1)-TRN(K))
C(K) = C(K)+VLD/V(K)*(CO(K-1)-C(K))
TRN(15) = TRN(15)+(VCD/V(15))*(TRN(4)-TRN(15))
C(15) = C(15)+VCD/V(15)*(CO(4)-C(15))
TRN(16) = TRN(16)+(VCD/V(16))*(TRN(15)-TRN(16))
C(16) = C(16)+VCD/V(16)*(CO(15)-C(16))
VCRD=VCRP*DELT
VVD=VVDSP*DELT
VRD=VRARP*DELT
BPRFV=0.0
IF(VCH,LT,0.) BPREV=1.0
TRN(17) = TRN(17)+VCD*(TRN(16)-TRN(17))
1 VVD*(TRN(50)-TRN(17))+VCRD*(TRN(51)-TRN(17))*(1.-BPREV))/V(17)
C(17) = C(17)+(VCD*(CO(16)-C(17))+
1 VVD*(CO(50)-C(17))+VCRD*(CO(51)-C(17)))/V(17)
VUP=VUPP*DELT
TRN(18) = TRN(18)+(VVD/V(18))*(TRN(17)-TRN(18))
C(18) = C(18)+VVD/V(18)*(CO(17)-C(18))
TRN(19) = TRN(19)+(VVD/V(19))*(TRN(18)-TRN(19))+(VUP*DELT/V
1(19))*(TRN(17)-TRN(19))
C(19) = C(19)+VVD/V(19)*(CO(18)-C(19))
1 +(VUP)*DELT/V(19)*(CO(17)-C(19))
C(20) = C(20)+VLD/V(20)*(CO(19)-C(20))
C(21) = C(21)+VLD/V(21)*(CO(20)-C(21))
1 +MAX(SURFLO,0.0)*DELT/V(21)*(CPD-CO(21))
DO 430 K=22,25
C(K) = C(K)+VLD/V(K)*(CO(K-1)-C(K))
DO 440 K=29,25
TRN(K) = TRN(K)+(VLD/V(K))*(TRN(K-1)-TRN(K))
TRN(26) = TRN(26)+(VLD/V(26))*(TRN(14)-TRN(26))
C(26) = C(26)+VLD/V(26)*(CO(14)-C(26))
TRN(27)=TRN(27)+(VLD/V(27))*(TRN(26)-TRN(27))
1 -JINJ*.227H*VINJ*DELT/V(27)
C(27) = C(27)+VLD/V(27)*(CO(26)-C(27))
1 +JINJ*(CINJ-CO(27))*0.00227H*VINJ*DELT/V(27)
DO 460 K=28,38

```

! ASSUMES TEMP DIFF OF 100 F AND  
! CONVERTS VINJ TO CUFT/SEC.

```

0277 C(K) = CO(K)+VLD/V(K)*(CO(K-1)-CO(K))
0278 460 TRM(K) = TRN(K)+(VLD/V(K))*(TRN(K-1)-TRN(K))
0279 DO 476 K=39,45
0280 TRM(K) = TRN(K)+(VVD/V(K))*(TRN(K-1)-TRN(K))
0281 470 C(K) = CO(K)+VVD/V(K)*(CO(K-1)-CO(K))
0282 TRM(46)=TRN(46)+(VVD*(TRN(45)-TRM(46))+
1 VCD*(TRN(46)-TRN(51))*BPREV)/V(46)
0283 C(46)=CO(46)+(VVD*(CO(45)-CO(46))+
1 VCD*(CO(46)-CO(51))*BPREV)/V(46)
0284 TRM(47) = TRN(47)+(VRD/V(47))*(TRN(38)-TRN(47))
0285 C(47) = CO(47)+VRD/V(47)*(CO(38)-CO(47))
0286 DO 480 K=48,50
0287 TRM(K) = TRN(K)+(VRD/V(K))*(TRN(K-1)-TRN(K))
0288 480 C(K) = CO(K)+VRD/V(K)*(CO(K-1)-CO(K))
0289 TRM(51)=TRN(51)+(VCD*(TRN(46)-TRN(51))*(1.-BPREV)+
1 VCRD*(TRN(51)-TRN(17))*BPREV)/V(51)
0290 C(51) = CO(51)+(VCD*(CO(46)-CO(51))*(1.-BPREV)+
1 VCRD*(CO(51)-CO(17))*BPREV)/V(51)
0291 CP=CPD+MIP(SURF10,0,0)*DELTA*(CPD-CO(21))/VWP+
1 DIMSP/PZRMW*(CO(34)-CPD)
0292 IF(ICRHP,EQ,1)CP = C(21)
0293 DO 510 I=1,51
0294 510 CO(I) = C(I)
0295 CPD = CP
0296 CBAR=(C(1)+C(2)+C(3)+C(4))*0.25
0297 IDAC(13)=(CBAR-1500)*5.
0298 540 DO 550 I=15,51
0299 550 TWALL(I)=TWALL(I)-Q(I)*DELTA/HCWAL(I)
C
0300 TCLI=TCLI+TAUCL*(TRM(37)-TCLI)
C
C TEST FOR REACTOR SCRAM
C
0301 KSCR=0
0302 KSCHT=0
0303 KSCHP=0
0304 KSCLP=0
0305 KSCLF=0
0306 KSCRA=0
0307 KSCRT=0
C REACTOR POWER SCRAM
0308 RPI=RPI+DELTA*(RPA-RPI)/TCRP
0309 IF(RPI,GE,RPSCRM) KSCR=2
C HIGH TEMPERATURE SCRAM
0310 THLI=THLI+DELTA*(TRM(20)-THLI)/TCHLT
0311 IDAC(18)=(THLI-600.)*100.
0312 IF(THLI,GE,HTSCRM) KSCHT=4
C HIGH PRESSURE SCRAM
0313 PLI=PLI+DELTA*(PIA-PLI)/TCLP
0314 IF(PLI,GE,HPSCRM) KSCHP=8
C LOW PRESSURE SCRAM
0315 IF(PLI,LE,LPSCRM) KSCLP=16
C LOW FLOW SCRAM
0316 VLI=VLI+DELTA*(WPCS-VLI)/TCLF
0317 IF(VLI,LE,VSCRM) KSCLF=32
C REFLOOD ASSIST BYPASS SCRAM
    
```

```

0318  IF(RANPRV.GF,RASCNM) KSCRA=64
C     SCRAM
0319  IF(TIM.GF,TIMSCM) KSCRA=128
C     TEST SCRAM
0320  IF(KSCSET.FO,1) GOTO 1030
0321  KSCRAM=KSCNM+KSCHP+KSCHT+KSCHP+KSCIF+KSCRA+KSCRT
0322  IF(KSCRAM.GT,0).AND.(TIM.GT,0) KSCSET=1-ISCAP
0323  SCRAM=TIM
0324  1030 CONTINUE
0325  SCRAM=TIM-SCRAM
0326  IF(SCRAMD.LT,SCDLY) GOTO 1040
0327  KSCRM=1
0328  TMOT=SCRAMD-SCDLY
0329  CALL SCRAMT(TMOT,DLS,RODPOS,DCR,LASTI)
C     COMPUTE MODERATOR REACTIVITY
0330  DENCOR=(RHO(1)+RHO(2)+RHO(3)+RHO(4))*0.25
0331  DELMOD=DEFCOR+DCOR
C     FUEL REACTIVITY
0332  TFUEL=1.000,-1.847(6)*.1
0333  DLF = TFUEL*DDPC
C     BORN REACTIVITY
0334  DLB = -ALPHAD*CHAR
C     SET EXTERNAL REACTIVITY
0335  IF (KSCRM.FO,1) GO TO 1060
0336  DEXT=(REACTX/TIMX)*TIM*REACTN
0337  F (AMSCDEXT).GE.ABS(REACTX) DEXT=REACTX
0338  1060 CONTINUE
0339  DELTAD=DELTAD+0.0005*(IZDP-IZDM)
C     TOTAL REACTIVITY
0340  DTOT=DEMOD+DLF+DLB+DLR+DEXT+DELTAD
0341  IF(DTOT.FO,1) DTOTZ=DTOT ; 1=ZERO REACTIVITY
0342  SOL=DTOT-DTOTZ
0343  ISDL=SOL/2.
0344  IDAC(1)=ISDL*1000.
0345  IDAC(4)=(SOL/2.-ISDL)*10000.
0346  SL=TABLE(TFUEL,SLP)
0347  KU=TABLE(TFUEL,TR)
0348  KFC=(KU*SL+TWALL(1))
0349  IDAC(5) = -KFC*100.
C
C     CALL DECAY HEAT SUBROUTINE
C
C     W=.06725
0350  IF(TMOT.GT.,1) R=TABLE(LOG(10(TMOT)),DECAY)
0351  DCYHT = R*RXPPWR
C
C
0352  IDAC(6) = DCYHT*100.
0353  IDAC(7) = (TRM(19)-600.)*100.
0354  IDAC(8) = (TRM(28)-600.)*100.
C
C     PFFD FLO
C
0355  IF(ITERAT+15MP.FO,4)GO TO 1091
0356  IF(SCRAMT.GT.FWB.Y) GOTO 1091
0357  SGLI=SGLI+(SGLVI-SGLI)*DELT
0358

```

FORTRAN  
 MAIN14  
 /TR:BLOCKS/WR  
 1:4:5:7  
 08-11-60

```

0359 SGWIC=.0216*WG-.08*(SGLI-SGLSP)
0360 IF(SGWIC.LT.0.0) SGWIC=0.0
0361 IF(SGWIC.GT.1.0) SGWIC=1.0
0362 XSEW=XSEW+(SGWIC-XSEW)*DELT
0363 GOTO 1100
0364 1091 XSEW=XSEW+FWRMP*DELT
0365 1100 CONTINUE
0366 IF(XSEW.LE.0.0) XSEW=0.0
0367 IF(XSEW.GE.1.0) XSEW=1.0
0368 DCVFW=0
0369 DXSEW=XSEW-0.75
0370 IF(DXSEW.GT.0.0) DCVFW=1.
0371 CVFW=1.0725*(XSEW+DCVFW)*DXSEW
0372 C2R0=CVFW*CVFW*53.36
0373 CDPFW=C2R0*(PCR-PSG+DPP0)/(1.+C2R0*0.0233)
0374 IF(CDPFW.LT.0.0) CDPFW=0.
0375 WFW=CDPFW*0.5
0376 IDAC(9) = WFW*20.

C
C STEAM VALVE POSITION
C
0377 MSVC=0
0378 MSVD=0
0379 IF(PSG.LT.PMSVLT) MSVC=KSCSFT*(1-IDLZER)
0380 IF(PSG.GT.PMSVHT) MSVD=1-IDLZER
0381 RMPMSV=(MSVD-MSVC)*SVRMPN
0382 RSVMAN=(IOPMSV-ICLMSV)*SVRMPN*(1.-9*ISVRMP)*(1-MSVC-MSVD)
0383 PMSVLT=PMSVLS+PMSVDB*MSVC
0384 PMSVHT=PMSVHS-PMSVDB*MSVD
C
0385 XMSCVL=XMSCVL+(PMPMSV+RSVMAN)*DELT
0386 IF(XMSCVL.LT.0.) XMSCVL=0.
0387 IF(XMSCVL.GT.1.) XMSCVL=1.
0388 XMSCV=XMSCV+(XMSCVL-XMSCV)*DELT/SVTC
0389 IDAC(14)=XMSCV*10000.

C
C STEAM FLOW
C
0390 CVMSC=TABLE(XMSCV,CVMSCF)
0391 WGSRT=PSG*PSG-PCR*PCR
0392 IF(WGSRT.LE.0.) WGSRT = 0.
0393 WG=CVMSC*((WGSRT*0.5)**0.5)
0394 IF(WG.LT.WGMIN) WG=WGMIN
C
0395 STM GEN RELIEF FLOW
0396 SGRF1=0.0
0397 SGRF2=0.0
0398 IF(PSG.GE.SGRT1)SGRF1=1.0
0399 IF(PSG.GE.SGRT2)SGRF2=1.0
0400 SGRF1=SGRF1+SGRF1*SGRF1
0401 SGRF2=SGRF2+SGRF2*SGRF2
0402 WSGRV=WSGRV+((NSGRV1+SGRF1+W/C*0.5)*SGRF2)-((NSGRV2+SGRF2)*SGRF2)
0403 MS=WG+WSGRV
0404 IDAC(10) =MS*20.
C
C STM GEN RECTOR AND DWMGR FLOWS
0405 SGVG=TABLE(PSG,VGTAB)
0406 SGVF=TABLE(PSG,VFTAB)
  
```

```

0406 SCHF=TABLE(PSC,HFTAB)
0407 SCHK=TABLE(PSC,HGTAB)
0408 VDNW=DMASS*SGVF
0409 SHDDV=SGHASS-(1.17,2-VDRH)/SGVG
0410 SHRDV=RR, R/SHDDM
0411 SHRDV=(SHRDV-SGVF)/(SGVG-SGVF)
0412 IF(SHRDX.GT.1.) SHRDV=1.
0413 SGRETA=2.8523+21974./-QSG
0414 XRTSPR=SGHFTA*SHRDV
0415 IF(XRTSPR.GT.1.) XRTSPR=1.
0416 WP=WS*(1./XRTSPR-1.)

C
0417 VRTSPR=SGVF+XRTSPR*(SGVG-SGVF)
0418 VDRUM=71.67/(SHDDM-17.13/VRTSPR)
0419 SGRFAD=(SGLVL/SGVF-64.44/VRTSPR-97.31/VDRUM)/1728.
0420 WDSQ=(SGHFTA-SCK2*(WR+SGVF+WS*SGVG)**2)/(SCK1+SGVF**2)
0421 AMDSQ=ABS(WDSQ)
0422 WD=AMDSQ**5
0423 IF(WD.LT.10.) WD=0.1*AMDSQ
0424 IF(WDSQ.LT.0.0) WD=-WD

C
C SG MASS AND ENERGY BALANCES
C
0425 DMASS=DMASS+(WFI+WR-WD)*DELTA
0426 SGMASS=SGMASS+(WD-WR-WS)*DELTA
0427 SGV=(276.-VDWN)/SGMASS
0428 HWDPOS=1.0
0429 IF(WD.LT.0.) HWDPOS=0.0
0430 HDWN=HDWN+(WFI*(HFM-HDWN)+WR*(SGHF-HDWN)+WD*(HDKN-HSC))*
1 (1.-HWDPOS)*DELTA/DMASS+(PSC-PSGO)*SGVF*.1851
0431 HSG=HSG+(VD+(HDWN-HSC)*HWDPOS-WS*(SGHF-HSG)-WR*(SGHF-HSG)-QSG)*
1 DELTA/SGMASS+(PSC-PSGO)*SGV*.1851

C
C STM GEN TRVFL
C
0432 SGLVL=4.00R*VDWN
0433 IF(VDNW.GT.19.31) SGLVL=75.41+0.9241*VDWN
0434 IDAC(2)=SGLVL*25.

C
C SG PRESSURE
C
0435 PSGO=PSC
0436 VLOGSG=ALOG10(SGV)+10.*19.
0437 HRARG=(HSG-300.)*.02
0438 IV=VLOGSG
0439 IH=HRARG
0440 IF((IH.GT.18).OR.(IH.LT.1).OR.(IV.GT.22)) GOTO 1450
0441 FRV=VLOGSG-IV
0442 FRH=HRARG-IH
0443 PSC=PSGT(IV,IH)*(1.-FRH)*(1.-FRV)+PSGT(IV+1,IH)+FRV*(1.-FRH)+
1 PSCT(IV,IH+1)*FRH*(1.-FRV)+PSCT(IV+1,IH+1)+FRV*FRH
0444 TSAT=TABLE(PSC,TSATSG)
0445 IDAC(17)=PSC*5.

C
C AIR-COOLFD CONDENSER
C

```

```

0446 PANG1=30.*XMSCV*(PCR-PCRSP)*.8475
0447 IF(PANG1.LT.0.) PANG1=0.
0448 IF(PANG1.GT.25.) PANG1=25.
0449 PANG=PANG+(PANG1-PANG)*DELTA/.2122
0450 VAIR=TABLE(PANG,AIRFLD) ! 1000 CUFT/MIN PER FAN
0451 ROAIR=33.72/VAIR
0452 WWAY=VAIR*ROAIR*33.333
0453 TSATCH=TABLE(PCR,TSATSG)
0454 DO 1210 I=1,3
0455 FANFR(I)=MAX(1,-TIM*AIRTSL+AIRSW(I),WAIRMN(I))*HAYSW(I)
0456 WAIR(I)=WWAY*FANFR(I)
0457 HOUTF(I)=3.784E-5*WAIR(I)**.72
0458 HAOUT(I)=HOUTF(I)*HACC/(HOUTF(I)+HACC)*EXTARA
0459 WCAIR(I)=WAIR(I)*CPAIR
0460 EDT=0.
0461 IF(WAIR(I).GT.1.) EDT=EXP(-HAOUT(I)/WCAIR(I))
0462 DTAIR(I)=(TTURF(I)-TAMB)*(1.-EDT)
0463 QAIR(I)=DTAIR(I)*WCAIR(I)
0464 WCOND(I)=QCOND(I)/(SGHG-CRHF)
0465 IF(WCOND(I).LE.0.) GO TO 1200
0466 UINF(I)=1.77*WCOND(I)**-.3333
0467 HAIN(I)=UINF(I)*HFOHL/(UINF(I)+HFOHL)*CONDAR
0468 QCOND(I)=HAIN(I)*(TSATCH-TTURF(I))
0469 1210 TTURF(I)=TTURF(I)+(QCOND(I)-QAIR(I))*DELTA/HCOTUR
0470 TAIR=TAMB+459.67+DTAIR(I)*.5 ! ABSOLUTE TEMP
    
```

C  
 C CONDENSATE RECEIVER  
 C

```

0471 CRFL=0.0
0472 IF(PCR.GE.CRRLT) CRRL=1.
0473 CRRLT=CRRLSP-CRRLDB*CRRL
0474 WCRRV=CRFL*CRRL ! RELIEF VALVE FLOW
0475 WCONDT=WCOND(1)+WCOND(2)+WCOND(3) ! CONDENSATE FLOW INTO ACC
0476 WFACC=CONDME/DWELL ! CONDENSATE FLOW FROM ACC
0477 WGACC=WG-WCONDT ! STEAM FLOW THRU ACC
0478 CRDM=CRMW*CRXW-CRMSTM*(1.-CRXG)
0479 CRDH=CRMW*CRXW*CRHG-CRMSTM*(1.-CRXG)*CRHF
0480 CONDMF=CONDME+(WCONDT-WFACC)*DELTA
0481 CRMW=CRMW+(WFACC-WFW)*DELTA-CRDM
0482 CRHW=CRHW-CRDH+(WFACC*CRHF-WFW*HWCR)*DELTA+VWCR*(PCR-PCR0)*.1851
0483 CRMSTM=CRMSTM+(WGACC-WCRRV)*DELTA+CRDM
0484 CRHSTM=CRHSTM+CRDH+(WGACC*SGHG-WCRRV*HGCR)*DELTA
    1 +VST*PCR*(PCR-PCR0)*.1851
0485 HWCR=CRHW/CRMW
0486 HGCR=CRHSTM/CRMSTM
    
```

C  
 C CONDENSATE RECEIVER PRESSURE  
 C

```

0487 PCR0=PCR
0488 CALL ZERO(CRDV,PCR)
0489 1220 CRHG=TABLE(PCR,HGTAB)
0490 CRXW=MAX(HDIFF/(CRHG-CRHF),0.)
0491 CRXG=MIN((HGAS-CRHF)/(CRHG-CRHF),1.)
0492 IDAC(15)=PCR*20.
0493 IDAC(16)=VWCR*25.
    
```

C

```

C SUBCOOLER
C
0494 QSC=HASC*(HSC-HAMB)
0495 HSC=HSC*(WEW+(HWCR-HSC)-QSC)*DELTA/SCMAS
0496 HEW=HEW*(WEW*(HSC-HEW))*DELTA/EPMAS
0497 1230 CONTINUE
C
0498 IF(ISMP.EQ.0) GO TO 1320
0499 IF(TIM.NE.0)GO TO 1235
0500 CALL GETADR(IPARM(1),NDAT(1))
0501 GO TO 1270
0502 1235 IF(IPARM(5).GT.NPA+5) GO TO 1310
0503 INCRP=1000.+(SMTSL0*(1-ISMTD)+SMTFST*ISMTD)+.5
0504 IF (IPRINT+INCRP-1*TIME) 1236,1236,1310
0505 1236 IPRINT=1*TIME
0506 1260 CALL WAITFR(3,IDS)
0507 IF(IDS.NE.1) GO TO 1260
0508 DO 1240 I=1,128
0509 1240 NDAT(I)=DAT(I)
0510 IF(IOSB(1).EQ.1) GO TO 1270
0511 TYPE 9000,IOSB
0512 GO TO 1330
0513 1270 CALL SETCL(1,1) ! DATA COUNTER
0514 1280 CALL QIO(4608,2,3,50,IOSB,IPARM,IDS)
0515 IF(IDS.NE.1)GO TO 1280
0516 IPARM(5)=IPARM(5)+1
0517 DLMPT=0.
0518 DMSPT=0.
0519 DMSHRT=0.
0520 PZPDMT=0.
0521 CALL SETCL(1,0) ! DATA COUNTER
0522 1300 CONTINUE
0523 1310 ITIME=ITIME+IDELTA
0524 TIM=ITIME*.001
0525 1320 IF(ID.EQ.0)GO TO 110
0526 1330 CONTINUE
0527 RETURN
0528 1400 TYPE*, 'STEAM GENERATOR DRY'
0529 RETURN
0530 1450 TYPE*, 'SG PRESSURE TABLE EXCEEDED'
0531 RETURN
0532 9000 FORMAT(' ***DISC ERROR***',207)
0533 FND
  
```

PROGRAM SECTIONS

NAME	SIZE	ATTRIBUTES
SCDDP1	022042 4625	RW,I,CON,I,CL
SPDATA	000624 202	RW,D,CON,I,CL
SIDATA	000444 146	RW,D,CON,I,CL
\$VARS	001414 390	RW,D,CON,I,CL
STEMPS	000020 8	RW,D,CON,I,CL
DAT	001000 256	RW,D,OVR,GBL

PROGRAM	000000	000000	000000
MAIN14			
PA	002000	512	RW,D,OVR,GAL
IPA	000102	33	RW,D,OVR,GAL
-5635	017664	4058	RW,D,OVR,GAL
DATID	001022	265	RW,D,OVR,GAL

TOTAL SPACE ALLOCATED = 050776 10495

MAIN14.FTN /TR:HLCKS/WR

```

0001 SUBROUTINE SCHAMT(T,ROD,X,D,I)
0002 DIMENSION TABLE(2,22),ROD(23)
C
C
0003
      TIME          POSITION
      DATA TABLE/ 0.000, 54.0,
2          0.075, 53.9,
3          0.160, 52.8,
4          0.245, 51.4,
5          0.331, 49.5,
6          0.417, 47.2,
7          0.503, 43.6,
8          0.589, 39.3,
9          0.672, 34.6,
0          0.753, 29.2,
1          0.830, 23.7,
2          0.905, 19.7,
3          0.977, 16.2,
4          1.050, 13.5,
5          1.127, 11.1,
6          1.211, 9.0,
7          1.265, 8.0,
8          1.336, 7.0,
9          1.403, 5.9,
0          1.514, 4.1,
1          1.590, 3.0,
2          1.710, 0.0/
      IF (T.GT.TABLE(1,22)) GO TO 200
0004 DO 100 J=1,22
0005 IF (T.GT.TABLE(1,J)) GO TO 100
0006 K=J-1
0007 FRAC=(T-TABLE(1,K))/(TABLE(1,J)-TABLE(1,K))
0008 X=(TABLE(2,J)-TABLE(2,K))*FRAC+TABLE(2,K)
0009 D=(ROD(K)-ROD(J))*FRAC-ROD(K)
0010 I=K
0011 RETURN
0012 CONTINUE
0013 X=TABLE(2,22)
0014 D=-ROD(22)
0015 RETURN
0016 END
0017

```

PROGRAM SECTIONS

NAME	SIZE	ATTRIBUTES
SCORFI	000314	114 RW,I,CON,LCI
STDATA	060012	5 RW,D,CON,LCI
SVARS	000270	92 RW,D,CON,LCI

TOTAL SPACE ALLOCATED = 006646 211

DK1:MAIN14,MAIN14=DK1:MAIN14.FTN;10/CO;60/LL11

```

0001 FUNCTION CRDV(PST)
0002 INCLUDE 'DK1:COMM14.FTN/NOLIST'
0015 HWTR=HWCR+VWCR/CRMW*(PST-PCRO)*.1851
0016 HGAS=HGCR+VSTMCR/CRMSTM*(PST-PCRO)*.1851
0017 CRHF=TABLE(PST,HFTAB)
0018 HDIFF=HWTR-CRHF
0019 DVDH=.0002284+.496124/PST
0020 CRVF=TABLE(PST,VFTAB)
0021 VWCR=(CRVF+13.838E-6*HDIFF)*CRMW ! SUBCOOLED CASE
0022 IF(HDIFF.GT.0.) VWCR=(CRVF+HDIFF*DVDH)*CRMW ! QUALITY REGION
0023 VSTMCR=(CRVF+(HGAS-CRHF)*DVDH)*CRMSTM
0024 CRDVZ=VWCR+CRVF*CONDME+VSTMCR-745.86
0025 CRDV=CRDVZ
0026 RETURN
0027 END
  
```

PROGRAM SECTIONS

NAME	SIZE	ATTRIBUTES
\$CODE	000402 129	RW,I,CON,I,CL
\$PDATA	000024 10	RW,D,CON,I,CL
\$IDATA	000020 8	RW,D,CON,I,CL
\$VARS	001044 274	RW,D,CON,I,CL
DAT	001000 256	RW,D,OVR,GBL
PA	002000 512	RW,D,OVR,GBL
IPA	000102 33	RW,D,OVR,GBL
SSSS	017664 4058	RW,D,OVR,GBL
DATID	001022 265	RW,D,OVR,GBL

TOTAL SPACE ALLOCATED = 22 5545

```

0001      SUBROUTINE DUMP
0002      INCLUDE 'DK1:COMM14.FTN/NOLIST'
0003      DIMENSION DMP1(2000)
0004      EQUIVALENCE (AIRFLD,DMP1)
0005      OPEN (UNIT=6,TYPE='NEW',NAME='DUMP.LST',RECORDSIZE=132)
0006      WRITE(6,900) (IDAT(I),I=1,72)
0007      WRITE(6,902) (IDAT(1),I=73,144)
0008      WRITE(6,903)
0009      WRITE(6,904) (K,Q(K),TRM(K),TBN(K),RHO(K),TWALL(K),TCALC(K),
0010      1 C(K),UH(K),H(K),K=1,51)
0011      PRINT 900
0012      PRINT*, 'NO. OF DATA RECORDS=', (IPARM(5)-6)
0013      WRITE(6,800)
0014      800      FORMAT('0',10X,'HEAT BALANCES',T65,'ERRGR')
0015      WRITE(6,801) RXPWR,RXRTU
0016      801      FORMAT(' INITIAL POWER',T20,F10.2,' MW',T40,F10.2,' BTU/SEC')
0017      WRITE(6,802) 94R,*RPA,94R,*RPA-RXRTU
0018      802      FORMAT(' CORE POWER (RPA)',T40,F10.2,' BTU/SEC',T60,F10.2)
0019      QT=QCLAD+QCRP+4.*QDIR
0020      WRITE(6,803) QCLAD,QCRP,4.*QDIR,QT,QT-RXRTU
0021      803      FORMAT(' QCLAD',T20,F10.2,' BTU/SEC'/' QCRP',T20,F10.2,
0022      1 ' BTU/SEC'/' QDIR*4',T20,F10.2,' BTU/SEC'/' TOTAL CORE HEAT'
0023      1 ' BTU/SEC',T40,F10.2,' BTU/SEC',T60,F10.2)
0024      QPCS=VLOOP*HC(1)/V(1)*(TRM(25)-TRM(26))
0025      WRITE(6,804) QPCS,QPCS-RXRTU
0026      804      FORMAT(' PCS POWER',T40,F10.2,' BTU/SEC',T60,F10.2)
0027      WRITE(6,805) -QSG,-QSG-RXRTU
0028      805      FORMAT(' SG HEAT (-QSG)',T40,F10.2,' BTU/SEC',T60,F10.2)
0029      SGPOW=WS*SGHG-WFW*HFW
0030      WRITE(6,806) SGPOW,SGPOW-RXRTU
0031      806      FORMAT(' STM GEN POWER',T40,F10.2,' BTU/SEC',T60,F10.2)
0032      ACCPOW=WG*SGHG-CONDNT*CKHF
0033      SCLPOW=WFW*(HWC-RHFW)
0034      WRITE(6,807) ACCPOW,SCLPOW,ACCPOW+SCLPOW,ACCPOW+SCLPOW-RXRTU
0035      807      FORMAT(' ACC POWER',T20,F10.2,' BTU/SEC'/' SUB-COOLER POWER',
0036      1 T20,F10.2,' BTU/SEC'/' TOTAL SECONDARY POWER',T40,F10.2,
0037      1 ' BTU/SEC',T60,F10.2)
0038      WRITE(6,808) QSC,(QCOND(K),QAIR(K),K=1,3)
0039      808      FORMAT(' QSC',T20,F10.2/' QCOND/QAIR',3(T20,2F10.2/))
0040      CLCOND=QCOND(1)+QCOND(2)+QCOND(3)
0041      QAIRT=QAIR(1)+QAIR(2)+QAIR(3)
0042      WRITE(6,809) QCONDT,QAIRT
0043      809      FORMAT(' TOTAL ACC HEAT',T20,2F10.2)
0044      WRITE(6,810) QCONDNT+QSC,QAIRT+QSC,QCONDNT+QSC-RXRTU,QAIRT+
0045      1 QSC-RXRTU
0046      810      FORMAT(' TOTAL SECONDARY HEAT REJECTION',T40,2F10.2,T60,2F10.2)
0047      PRINT 811
0048      811      FORMAT(' *** STEAM GENERATOR ***')
0049      PRINT 910,'TSATC','PSATI','SGLVL1','WSGI','SGMASI'
0050      PRINT 912,TSATC,PSATI,SGLVLI,WSGI,SGMASI
0051      PRINT 910,'TSAT','PSG','SGLVL','WS','SGMASS'
0052      PRINT 912,TSAT,PSG,SGLVLI,WS,SGMASS
0053      PRINT 910,'DWMASI','HDWNI','HSGI','XMSCV0','XSEWI'
0054      PRINT 912,DWMASI,HDWNI,HSGI,XMSCV0,XSEWI
0055      PRINT 910,'DWMASS','HDWN','HSC','XMSCV','XSEW'
0056      PRINT 912,DWMASS,HDWN,HSC,XMSCV,XSEW
    
```

L-38

PURCHASE BY  
DUMPIA,FTM

002-51  
/TH:BLACKS/MR

16:11:55

08-FFH-80

PAGE

```

0063 PRINT 910,'HFW','SGVF','SGVG','SGVI','SGVF','SGHF','SGHG'
0064 PRINT 912,'HFW','SGVF','SGVG','SGV','SGHF','SGHG'
0065 PRINT 910,'SHRDM','SHRDV','SHRDX','XRISEI','VRISEI','VDRUM'
1 'XDRUM'
0066 PRINT 912,'SHRDM','SHRDV','SHRDX','XRISEI','VRISEI','VDRUM','XDRUM'
0067 PRINT 910,'SCRETA','SCHEAD','MDSQ','WR','WD','SGDPZ'
0068 PRINT 912,'SCRETA','SCHEAD','MDSQ','WR','WD','SGDPZ'
0069 PRINT 910,'HSCI','HSC','HFW','HWF','RECIRC','HSGC'
WSG=WS
0070 IF WS.EQ.0,WSG=1.
0071 PRINT 912,HSCI,HSC,HFW,HWF,(WR+WSG)/WSG,HSGC
0072 PRINT 812
0073 FORMAT('1',
0074 '1',
0075 '1',
0076 '1',
0077 '1',
0078 '1',
0079 '1',
0080 '1',
0081 '1',
0082 '1',
0083 '1',
0084 '1',
0085 '1',
0086 '1',
0087 '1',
0088 '1',
0089 '1',
0090 '1',
0091 '1',
0092 '1',
0093 '1',
0094 '1',
0095 '1',
0096 '1',
0097 '1',
0098 '1',
0099 '1',
0100 '1',
0101 '1',
0102 '1',
0103 '1',
0104 '1',
0105 '1',
0106 '1',
0107 '1',
0108 '1',
0109 '1',
0110 '1',
0111 '1',
0112 '1',
0113 '1',
0114 '1'

```

```

0115 PRINT 912,HTQ,DLMSUR,PZRLQS,DLMRH,DLHSUR,SPRAYG,SPRAYW
0116 PRINT 910,'PZRHW','PZRHW','PZRMG','PZRHG','PZRMWI','PZRHWI',
1 'PZRMGI','PZRHGI'
0117 PRINT 912,PZRMW,PZRHW,PZRMG,PZRHG,PZRMWI,PZRHWI,PZRMGI,PZRHGI
0118 PRINT 910,'RXPWR','TCOLD','THOT','TCLADC','PZPDM','PZPDM'
0119 PRINT 912,RXPWR,TCOLD,THOT,TCLADC,PZPDM,PZPDM
0120 PRINT 913,DAT
0121 PRINT*,IDAC'
0122 PRINT*,IDAC'
0123 PRINT*,JDAC'
0124 PRINT*,JDAC'
0125 PRINT*,IARY'
0126 PRINT*,IARY'
0127 IF(NBR.EQ.2) PRINT 913,DMP1
0128 CLOSE (UNIT=6,DISP='PRINT')
0129 913 FORMAT('1'/5(10(10E13.5/)/))
0130 900 FORMAT('1',72A1)
0131 902 FORMAT(' ',72A1)
0132 903 FORMAT('0',T10,'NODE',T21,'0',T34,'TBM',T47,'TBN',T60,'RHO',T72,
1 'TWALL',TP5,'TCLC',T97,'BOMON',T112,'UR',T125,'H')
0133 904 FORMAT(' ',T10,12,9F13.4)
0134 909 FORMAT('1',4X,8(A6,9X))
0135 910 FORMAT('0',4X,8(A6,9X))
0136 912 FORMAT(1X,8(1PG15.7))
0137 914 FORMAT('0',4X,8(A8,7X))
0138 500 RETURN
0139 END

```

PROGRAM SECTIONS

NAME	SIZE	ATTRIBUTES
SCODE1	011034 2318	RW,1,CON,LCL
SPDATA	002042 529	RW,D,CON,LCL
SIDATA	001530 428	RW,D,CON,LCL
SVARS	001114 294	RW,D,CON,LCL
DAT	001000 256	RW,D,OVR,GBL
PA	002000 512	RW,D,CVR,GBL
IPA	000102 33	RW,D,OVR,GBL
.SSSS.	017664 4058	RW,D,OVR,GBL
DATID	001022 265	RW,D,OVR,GBL

TOTAL SPACE ALLOCATED = 041752 8693

DK1:DUMP14,DUMP14=DK1:DUMP14.FTN:10/CO:60/LI:1

APPENDIX MINPUT ARRAY

<u>Index</u>	<u>Name</u>	<u>Variable</u>	<u>Nominal Value</u>
1	RPSCRM	Reactor power scram setpoint	54 MW
2	HTSCRM	High hot leg temperature scram setpoint	6050F
3	VSCRM	Low PCS flow scram setpoint	$3.23 \times 10^6$ lbm/hr
4	HPSCRM	High pressure scram setpoint	2281 psia
5	LPSCRM	Low pressure scram setpoint	2058 psia
6	TCRP	Reactor power instrument time constant	0.25 sec
7	TCHLT	Hot leg temperature instrument time constant	18 sec
8	TCLF	PCS flow instrument time constant	1 sec
9	TCLP	PCS pressure instrument time constant	1 sec
10	KSURGE	Surge line resistance	0.1 psi/(ft <sup>3</sup> /sec) <sup>2</sup>
11	DELT	Program step time interval	50 msec
12	SMTSLO	Slow sampling interval	1 sec
13	FLOW	PCS initial flow rate	$3.8 \times 10^6$ lbm/hr
14	ALPHAB	Boron worth	0.0103 \$/ppm
15	SCDLY	Scram delay time	0.05 sec
16	SMTFST	Fast sampling interval	0.2 sec
17	SVTC	Steam valve time constant	1.25 sec
18	DOPC	Doppler reactivity coefficient	-0.00125 \$/0F

## APPENDIX M (Cont'd)

## INPUT ARRAY

Index	Name	Variable	Nominal Value
19	DPPO	Feed pump zero flow discharge pressure	874 psia
20	TCCLT	Cold leg temperature instrument time constant	18 sec
21	STMLKG	Steam leakage fraction	0.00
22-81	VSFR	Variable flow fraction table	See Tables M-2 and M-3
82	SSP	Pressurizer spray setpoint	2275 psia
83	HTSUP	Start up heaters	455 BTU/sec
84-85		Not Assigned	
86	FLTMD	Flow table spacing	See Tables M-2 and M-3
87	FLTMX	Flow table end point	See Tables M-2 and M-3
88	RPSP	Power operated relief setpoint	2422 psia
89	RCSP	Safety relief valves setpoint	2525 psia
90	HTISP	Pressurizer cycling heaters setpoint	2153 psia
91	HT2S	Pressurizer backup heaters setpoint	2148 psia
92	RASCRM	RABV flow fraction scram setpoint	0.2354
93-95		Not Assigned	
96	SURMIN	Surge line mass flow threshold	0.2 lbm
97	CLIC	PCS loop initial boron concentration	1500 ppm

## APPENDIX M (Cont'd)

## INPUT ARRAY

Index	Name	Variable	Nominal Value
98	CPIC	Pressurizer initial boron concentration	1500 ppm
99	VDRAIN	PCS loop drain rate	6 gpm
100	VINJ	HPIS Injection rate	6 gpm
101-160	RABFR	RABV variable flow fraction table	See Table M-3
161-163		Not Assigned	
164	FFRMN	Natural circulation transition flow fraction	0.08
165-175		Not Assigned	
176-198	DIS	Scram curve	See Table M-1
199-201	AIRSW	ACC transient switches	0
202-204	BAYSW	ACC operating bay select switches	1
205		Not Assigned	
206	AIRTSL	ACC air flow reduction rate	0.2/sec
207-209	WAIRMN	ACC minimum air flow fractions	0
210	CRRLSP	Condensate receiver relief setpoint	400 psia
211	CRRLDB	Condensate receiver relief valve reset dead band	10 psia
212	CRRLF	Condensate receiver relief valve flow	81 lbm/sec

## APPENDIX M (Cont'd)

## INPUT ARRAY

Index	Name	Variable	Nominal Value
213	TAMB	ACC air temperature	800F
214	WRMPT	Feed water valve ramp rate	-0.3/sec
215	FWDLY	Feed water valve delay time	1.25 sec
216	TIMSCM	Timed scram setpoint	$\infty$
217		Not Assigned	
218	DCOR	Moderator reactivity coefficient	0.765 $\$/(\text{lbm}/\text{ft}^3)$
219	REACEX	Reactivity insertion Accident - total reactivity	8.35 $\$$
220	TIMEX	Reactivity insertion accident time interval	None
221		Not Assigned	
222	SURMPN	Steam valve ramp rate	0.05/sec
223	PMSVHS	Steam valve high pressure setpoint	1020 psia
224	PMSVLS	Steam valve low pressure setpoint	920 psia
225	PMSVDB	Steam valve reset dead band	10 psia
226	CINO	HPIS boron concentration	3000 ppm
227	CKCORE	Core clad heat transfer coefficient	496.6 Btu/sec $^{\circ}$ F
228	CKSG	Steam generator heat transfer coefficient	188.0 Btu/sec $^{\circ}$ F

## APPENDIX M (Cont'd)

## INPUT ARRAY

Index	Name	Variable	Nominal Value
229	RXPWR	Initial reactor power	50 MW
230	TMOT	Initial hot leg temperature	588.30F
231	SGLSP	Steam generator level setpoint	116 inches
232	PCRI	Initial condensate receiver pressure	300 psia
233-234		Not Assigned	
235	PLOOPI	Initial PCS loop pressure	2262 psia
236	UAPZR	Pressurizer ambient loss heat transfer coefficient	0
237	SPRCNT	Pressurizer continuous spray flow	0 gpm
238	PZLEVI	Initial pressurizer level	44.5 inches
239	LPHPIS	HPIS low pressure setpoint	1800 psia
240	SPRNGM	Pressurizer nominal spray flow	20 gpm
241	RCDB	Safety relief valve reset dead band	50 psia
242	RPDB	Power operated relief valve reset dead band	20 psia
243	SGXDNB	Steam generator shroud steam quality at which DNB begins	85%
244	SGRS1	Steam generator relief valve R136 setpoint	1100 psia
245	SGRS2	Steam generator relief valve R137 setpoint	1200 psia
246-256		Not Assigned	

TABLE M-1  
SCRAM REACTIVITY TABLES

TIME (sec)	INPUT ARRAY INDEX	3 BANK WORST CASE REACTIVITY <sup>1</sup> \$	4 BANK BEST ESTIMATE REACTIVITY <sup>2</sup> \$
0.000	176	0	0.5642
0.075	177	0.00171	0.5711
0.160	178	0.00806	0.6482
0.245	179	0.02028	0.7460
0.331	180	0.04026	0.8791
0.417	181	0.07052	1.040
0.503	182	0.11372	1.482
0.589	183	0.17231	2.084
0.672	184	0.25592	2.876
0.753	185	0.37906	4.425
0.830	186	0.54421	6.464
0.905	187	0.76336	8.667
0.977	188	1.0548	11.46
1.050	189	1.4890	12.50
1.127	190	2.2810	17.49
1.211	191	3.3843	19.94
1.265	192	4.1556	21.10
1.336	193	5.1377	22.18
1.403	194	6.0083	22.61
1.514	195	7.4449	23.11
1.590	196	8.3554	23.42
1.710	197	9.4449	23.55
	198	(not used)	

1 Supplied by S. A. Atkinson, 2-13-79.

2 Computed from rod drop time test data supplied by M. A. Bray on 5-31-79 and the rod worth curve in LTR-111-82, Figure A1.

TABLE M-2

PCS FLOW TRANSIENT TABLES

INPUT ARRAY INDEX	ONE PUMP RAPID COASTDOWN <sup>1</sup>	TWO PUMP RAPID COASTDOWN <sup>2</sup>	TWO PUMP FLYWHEEL ASSISTED COASTDOWN <sup>3</sup>
22	1.0000	1.0000	1.0000
23	0.9340	0.9800	0.9361
24	0.8395	0.9750	0.8530
25	0.7595	0.9100	0.7821
26	0.6975	0.7450	0.7224
27	0.6501	0.6150	0.6710
28	0.6141	0.5120	0.6266
29	0.5874	0.4420	0.5877
30	0.5632	0.3850	0.5534
31	0.5461	0.3450	0.5227
32	0.5348	0.3150	0.4952
33	0.5267	0.2900	0.4702
34	0.5206	0.2620	0.4475
35	0.5160	0.2400	0.4277
36	0.5128	0.2220	0.4076
37	0.5108	0.2100	0.3900
38	0.5099	0.1980	0.3735
39	0.5102	0.1860	0.3582
40	0.5113	0.1740	0.3438
41	0.5133	0.1620	0.3304
42	0.5162	0.1500	0.3176
43	0.5202	0.1380	0.3056
44	0.5233	0.1260	0.2941
45	0.5247	0.1140	0.2832
46	0.5256	0.1020	0.2728
47	0.5262	0.0900	0.2628

TABLE M-2 (cont'd)

INPUT ARRAY INDEX	ONE PUMP RAPID COASTDOWN	TWO PUMP RAPID COASTDOWN	TWO PUMP FLYWHEEL ASSISTED COASTDOWN
48	0.5267	0.0780	0.2532
49	0.5271	0.0660	0.2439
50	0.5274	0.0540	0.2350
51	0.5276	0.0420	0.2263
52	0.5279	0.0300	0.2178
53	0.5280	0.0180	0.2095
54	0.5282	0.0060	0.2014
55	0.5283	0.0000	0.1935
56	0.5284	0.0000	0.1856
57	0.5285	NA	0.1779
58	0.5285	NA	0.1701
59	0.5286	NA	0.1624
60	0.5286	NA	0.1547
61	0.5287	NA	0.1469
62	0.5287	NA	0.1390
63	0.5287	NA	0.1310
64	0.5287	NA	0.1228
65	0.5287	NA	0.1143
66	0.5288	NA	0.1055
67	0.5288	NA	0.0961
68	NA	NA	0.0830
69	NA	NA	0.0730
70	NA	NA	0.0620
71	NA	NA	0.0520
72	NA	NA	0.0420
73	NA	NA	0.0320
74	NA	NA	0.0220
75	NA	NA	0.0140

TABLE M-2 (cont'd)

INPUT ARRAY INDEX	ONE PUMP RAPID COASTDOWN	TWO PUMP RAPID COASTDOWN	TWO PUMP FLYWHEEL ASSISTED COASTDOWN
76	NA	NA	0.0080
77	NA	NA	0.0040
78	NA	NA	0.0020
79	NA	NA	0.0010
80	NA	NA	0.0000
81	NA	NA	0.0000
FLTMD	0.2 sec	0.2 sec	1 sec
FLTMX	8.8 sec	6.6 sec	58 sec

- 
- (1) SICLOPS Analysis, Loss of One Pump Flow, 3.295 MLBM/HR initial flow.
  - (2) LTR 111-104, page 163.
  - (3) SICLOPS Analysis, Loss of Prime Mover Motor, 3.295 MLBM/HR initial flow.
-

TABLE M-3

RABV FLOW TRANSIENT TABLES

RABV OPENING AT 5%/sec

INPUT ARRAY INDEX	VESSEL FRACTION	INPUT ARRAY INDEX	RABV FRACTION
22	1.000	101	0.000
23	0.924	102	0.113
24	0.854	103	0.215
25	0.781	104	0.297
26	0.724	105	0.356
27	0.684	106	0.400
28	0.655	107	0.428
29	0.635	108	0.449
30	0.620	109	0.465
31	0.605	110	0.478
32	0.596	111	0.485
33	0.591	112	0.491
34	0.582	113	0.495
35	0.577	114	0.499
36	0.575	115	0.500
37	0.573	116	0.503
38	0.571	117	0.506
39	0.570	118	0.510
40	0.569	119	0.511
41	0.568	120	0.513
42-43	0.567	121-122	0.514
44-81	(not used)	123-160	(not used)

FLTMD = 1 sec

FLTMX = 20 sec

TABLE M-3 (con't)

RABV OPENING AT 10%/sec

INPUT ARRAY INDEX	VESSEL FRACTION	INPUT ARRAY INDEX	RABV FRACTION
22	1.000	101	0.000
23	0.854	102	0.215
24	0.724	103	0.356
25	0.655	104	0.428
26	0.620	105	0.465
27	0.596	106	0.485
28	0.582	107	0.495
29	0.575	108	0.500
30	0.571	109	0.506
31	0.569	110	0.511
32-33	0.567	111-112	0.514
34-81	(not used)	113-160	(not used)

FLTMD = 1 sec

FLT<sub>ix</sub> = 10 sec

Reference: LTR 112-58, Figures 2 and 5

APPENDIX NRecursive Solution For PCS Steady State Temperatures

1. From Section 3, equations 3-16, 3-12, and 3-17 are:

$$T_{NEW} = T_{OLD} + \dot{Q} \Delta t / mc_p$$

$$\dot{Q} = UA (T_{WALL} - T_{NODE}) + \dot{Q}_{DIR}$$

$$T_{NODE} = T_{NEW} + \frac{\dot{V} \Delta t}{V} (T_{IN} - T_{NEW})$$

2. Solve for  $T_{NODE}$  in terms of  $T_{WALL}$  and  $T_{IN}$ .

$$T_{NODE} = (T_{OLD} + \frac{\dot{Q} \Delta t}{mc_p}) + \frac{\dot{V} \Delta t}{V} (T_{IN} - (T_{OLD} + \frac{\dot{Q} \Delta t}{mc_p}))$$

For steady state conditions  $T_{OLD} = T_{NODE}$ .

$$\text{let } k = \frac{\dot{V} \Delta t}{V}$$

$$0 = \frac{\dot{Q} \Delta t}{mc_p} + k T_{IN} - k T_{NODE} - k \left( \frac{\dot{Q} \Delta t}{mc_p} \right)$$

$$0 = \left( \frac{\dot{Q} \Delta t}{mc_p} \right) (1 - k) + k (T_{IN} - T_{NODE})$$

$$0 = \frac{\Delta t}{mc_p} (UA (T_{WALL} - T_{NODE}) + \dot{Q}_{DIR}) (1 - k) + k (T_{IN} - T_{NODE})$$

$$T_{NODE} \left( \frac{UA \Delta t}{mc_p} (1 - k) + k \right) = \frac{\Delta t}{mc_p} (UA T_{WALL} + \dot{Q}_{DIR}) (1 - k) + k T_{IN}$$

$$T_{NODE} = \frac{(UA T_{WALL} + \dot{Q}_{DIR}) (1 - k) + \frac{mc_p}{\Delta t} k T_{IN}}{UA (1 - k) + \frac{mc_p}{\Delta t} k}$$

$$\text{for } \frac{mc_p}{\Delta t} k = \frac{mc_p}{\Delta t} \frac{V \Delta t}{V} = \frac{m}{V} \dot{V} c_p = wc_p$$

$$T_{NODE} = \frac{(UA T_{WALL} + \dot{Q}_{DIR}) (1 - k) + wc_p T_{IN}}{UA (1 - k) + wc_p}$$

$$3. \text{ Define } F = \frac{wc_p - kUA}{wc_p + (1-k)UA} = \frac{1}{1 + \frac{1}{\frac{wc_p}{UA} - k}}$$

$$(1-F) = \frac{UA}{wc_p + (1-k)UA}$$

$$T_{NODE} = (1-F) \left[ (1-k) \left( T_{WALL} + \frac{\dot{Q}_{DIR}}{UA} \right) + \frac{wc_p}{UA} T_{IN} \right]$$

4. Solve for  $T_{NODE}$  in terms of the upstream node temperature. Let  $T_j = T_{NODE}$  and define  $T_{j-1}$  as the upstream temperature. It is assumed the  $\dot{T}_{WALL}$ ,  $\dot{Q}_{DIR}$ ,  $k$ ,  $UA$ , and  $wc_p$  are the same for each node.

$$\begin{aligned}
 T_{IN} &= T_{NEW} = T_{j-1} + \frac{\dot{Q} \Delta t}{mc_p} \\
 &= T_{j-1} + \frac{\Delta t}{mc_p} (UA (T_{WALL} - T_{j-1}) + \dot{Q}_{DIR}) \\
 &= T_{j-1} \left(1 - k \frac{UA}{WC_p}\right) + k \frac{UA}{WC_p} \left(T_{WALL} + \frac{\dot{Q}_{DIR}}{UA}\right)
 \end{aligned}$$

$$\begin{aligned}
 \frac{WC_p}{UA} T_{IN} &= T_{j-1} \left(\frac{WC_p}{UA} - k\right) + k \left(T_{WALL} + \frac{\dot{Q}_{DIR}}{UA}\right) \\
 &= \frac{1}{\frac{WC_p}{UA} - k} T_{j-1} + k \left(T_{WALL} + \frac{\dot{Q}_{DIR}}{UA}\right)
 \end{aligned}$$

$$T_j = (1-F) \left[ (1-k) \left(T_{WALL} + \frac{\dot{Q}_{DIR}}{UA}\right) + \frac{T_{j-1}}{\frac{WC_p}{UA} - k} + k \left(T_{WALL} + \frac{\dot{Q}_{DIR}}{UA}\right) \right]$$

$$T_j = (1-F) \left[ \left(T_{WALL} + \frac{\dot{Q}_{DIR}}{UA}\right) + \frac{T_{j-1}}{\frac{WC_p}{UA} - k} \right]$$

$$T_j = (1-F) \left(T_{WALL} + \frac{\dot{Q}_{DIR}}{UA}\right) + F T_{j-1}$$

5. Solve for  $T_j$  in terms of  $T_{j-n}$ . Use induction to show that if

$$T_j = A + F T_{j-1}$$

then,

$$T_j = A \sum_{m=1}^n F^{m-1} + F^n T_{j-n}$$

Proof: for  $n = 1$

$$T_j = A \sum_{m=1}^1 F^{m-1} + F T_{j-1} = A + FT_{j-1}$$

Show that if the formula is valid for  $n=i-1$  it is valid for  $n=i$ .

$$T_j = A \sum_{m=1}^{i-1} F^{m-1} + F^{i-1} T_{j-i+1}$$

$$= A \sum_{m=1}^{i-1} F^{m-1} + F^{i-1} (A + FT_{j-i})$$

$$= A \sum_{m=1}^{i-1} F^{m-1} + AF^{i-1} + F^i T_{j-i}$$

$$= A \sum_{m=1}^{i-1} F^{m-1} + F^{i-1} T_{j-i+1} = A \sum_{m=1}^i F^{m-1} + F^i T_{j-i}$$

$$T_j = (1-F) \left( T_{WALL} + \frac{\dot{Q}_{DIR}}{UA} \right) + \sum_{m=1}^n F^{m-1} + F^n T_{j-n}$$

$$\text{for } \sum_{m=1}^n F^{m-1} = \frac{1-F^n}{1-F}$$


$$T_j = (1-F^n) \left( T_{WALL} + \frac{\dot{Q}_{DIR}}{UA} \right) + F^n T_{j-n}$$

6. Find the node outlet temperature.  $T_{out, j} = T_{in, j+1}$  see step 4 above.

$$T_{out_j} = \frac{UA}{Wc_p} \left[ \left( \frac{Wc_p}{UA} - k \right) T_j + k \left( T_{WALL} + \frac{\dot{Q}_{DIR}}{UA} \right) \right]$$

7. Find the core  $T_{clad}$  in terms of  $T_{cold}$ ,  $\dot{Q}_{core}$ ,  $\dot{Q}_{DIR}$ , and  $W$ .

From the core model



$$T_{out} = \frac{UA}{Wc_p} \left[ \frac{F}{1-F} T_4 + k \left( T_{clad} + \frac{\dot{Q}_{DIR}}{UA} \right) \right]$$

$$T_4 = (1-F^3) \left( T_{clad} + \frac{\dot{Q}_{DIR}}{UA} \right) + F^3 T_1$$

$$T_1 = (1-F) \left[ (1-k) \left( T_{clad} + \frac{\dot{Q}_{DIR}}{UA} \right) + \frac{Wc_p}{UA} T_{cold} \right]$$

$$\text{let } T' = T_{clad} + \frac{\dot{Q}_{DIR}}{UA}$$

$$\begin{aligned} T_4 &= (1-F^3) T' + F^3 (1-F) \left[ (1-k) T' + \frac{Wc_p}{UA} T_{cold} \right] \\ &= \left[ 1-F^3 + F^3 (1-F) (1-k) \right] T' + F^3 (1-F) \frac{Wc_p}{UA} T_{cold} \\ &= \left[ (1-F^4) - k(F^3) (1-F) \right] T' + F^3 (1-F) \frac{Wc_p}{UA} T_{cold} \end{aligned}$$

$$\frac{F}{1-F} T_4 = \left( \frac{F(1-F^4)}{1-F} - kF^4 \right) T' + F^4 \frac{Wc_p}{UA} T_{cold}$$

$$T_{out} = \frac{UA}{Wc_p} \left[ \left( \frac{F(1-F^4)}{1-F} - kF^4 \right) T' + F^4 \frac{Wc_p}{UA} T_{cold} + kT' \right]$$

$$= \frac{UA}{Wc_p} T' \left[ \frac{F(1-F^4)}{1-F} + k(1-F^4) \right] + F^4 T_{cold}$$

$$= \frac{UA}{Wc_p} T' (1-F^4) \left( \frac{F}{1-F} + k \right) + F^4 T_{cold}$$

from definition of F

$$\frac{F}{1-F} = \frac{Wc_p}{UA} - k$$

$$T_{out} = (1-F^4) \left( T_{clad} + \frac{\dot{Q}_{DIR}}{UA} \right) + F^4 T_{cold}$$

$$T_{clad} = \frac{T_{out} - F^4 T_{cold}}{(1-F^4)} - \frac{\dot{Q}_{DIR}}{UA}$$

$$= \frac{(T_{out} - T_{cold}) + (1-F^4) T_{cold}}{(1-F^4)} - \frac{\dot{Q}_{DIR}}{UA}$$

$$= T_{cold} + \frac{\dot{Q}_{core}}{Wc_p (1-F^4)} - \frac{\dot{Q}_{DIR}}{UA}, \text{ where } \dot{Q}_{core} = Wc_p (T_{out} - T_{cold})$$

8. Find  $T_{\text{sat}}$  in the steam generator. The method is the same as for the core, except  $\dot{Q}_{\text{DIR}} = 0$ , the number of nodes is 10, and  $F$  is computed using steam generator properties including heat conductivity of the secondary film.

$$T_{\text{sat}} = T_{\text{hot}} + \frac{\dot{Q}_{\text{SG}}}{w c_p (1-F^{10})}$$

APPENDIX B

OUTPUT PARAMETERS

	PLAN14.HDR;003		
1 - TIME	33 - T TUBE 1	65 - T SG 14	97 - T LP 46
2 - POWER	34 - T TUBE 2	66 - T UP 15	98 - T RABU47
3 - LOOP FLO	35 - T TUBE 3	67 - T UP 16	99 - T RAB'48
4 - PCS PRES	36 - QAIR 1	68 - T NZL 17	100 - T RABU49
5 - PZR PRES	37 - QAIR 2	69 - T THD 18	101 - T RABU50
6 - STM FLOW	38 - QAIR 3	70 - T HL 19	102 - T CBP 51
7 - QCLAD	39 - AIRFLOW1	71 - T HOT 20	103 - SG LVL
8 - REACT	40 - AIRFLOW2	72 - T HL 21	104 - U SG
9 - Q SG	41 - AIRFLOW3	73 - T HL 22	105 - H DWNC
10 - PRES SG	42 - CNTR ROD	74 - T HL 23	106 - M DWNC
11 - PRES CR	43 - HG PZR	75 - T SGP 24	107 - M SG
12 - XFWU	44 - MOD REAC	76 - T HOT 25	108 - W DWNC
13 - FW FLOW	45 - FUELREAC	77 - T COLD26	109 - X SHRD
14 - XMSCU	46 - BOR REAC	78 - T SGP 27	110 - H SG
15 - PZR CONC	47 - ROD REAC	79 - T CL 28	111 - SG RU
16 - BLD ANG	48 - RISER	80 - T CL 29	112 - MG CR
17 - TCLAD 1	49 - PCS MASS	81 - T CL 30	113 - CR-GAS
18 - CORE BOR	50 - HW CR	82 - T CL 31	114 - MG ACC
19 - T COLD	51 - PZR SRGE	83 - T P1 32	115 - CR-WTR
20 - MW PZR	52 - T CORE 1	84 - T P2 33	116 - HW PZR
21 - HW PZR	53 - T CORE 2	85 - T CL 34	117 - HG PZR
22 - RABU FLO	54 - T CORE 3	86 - T CL 35	118 - PZR BOIL
23 - PZR SPRY	55 - T CORE 4	87 - T CL 36	119 - MW CR
24 - RECIRFLO	56 - T SG 5	88 - T COLD37	120 - RU FLOW
25 - H FW	57 - T SG 6	89 - T DC 38	121 - CBP FLOW
26 - NAT CIRC	58 - T SG 7	90 - T DC 39	122 - EXT REAC
27 - NAT CIRC	59 - T SG 8	91 - T DC 40	123 - PWR IND
28 - NAT CIRC	60 - T SG 9	92 - T DC 41	124 - T HOT
29 - MG PZR	61 - T SG 10	93 - T DC 42	125 - PCS PRES
30 - PCS FLOW	62 - T SG 11	94 - T DC 43	126 - PCS FLOW
31 - CORE FLO	63 - T SG 12	95 - T LP 44	127 - PZR LVL
32 - DECAY HT	64 - T SG 13	96 - T LP 45	128 - T FUEL