NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

EXHIBIT A

# LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

| 0 1 | O R T N P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5) |
|---|---|---|---|---|
| | LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT |

CON'T

| 0 1 | REPORT SOURCE L (6) | 0 5 0 - 0 3 4 4 (7) | 0 8 0 5 8 1 (8) | 0 8 3 1 8 1 (9) |
|---|---|---|---|---|
| | | DOCKET NUMBER | EVENT DATE | REPORT DATE |

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 DURING A PERIODIC TEST TURBINE FIRST STAGE PRESSURE CHANNEL 506 WAS FOUND

0 3 TO HAVE EXCEEDED ITS LIMITING SETTING. THEREFORE, THE PLANT WAS OPERATING

0 4 LESS THAN THE MINIMUM NUMBER OF OPERABLE CHANNELS AS REQUIRED BY

0 5 THE TECHNICAL SPECIFICATIONS (4.3.1.1.1 and 4.3.2.1.1).

0 6

0 7

0 8

| | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE |
|---|---|---|---|---|---|---|
| 0 9 | I A (11) | E (12) | E (13) | I N S T R U (14) | 0 (15) | Z (16) |

| (17) LER/RO REPORT NUMBER | EVENT YEAR | | SEQUENTIAL REPORT NO. | | OCCURRENCE CODE | REPORT TYPE | | REVISION NO. |
|---|---|---|---|---|---|---|---|---|
| | 8 1 | — | 0 1 8 | / | 0 3 | L | — | 0 |

| ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS (22) | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER |
|---|---|---|---|---|---|---|---|---|
| E (18) | Z (19) | Z (20) | Z (21) | 0 0 0 0 | Y (23) | N (24) | N (25) | H 0 1 5 (26) |

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE CAUSE OF THIS OCCURRENCE IS ATTRIBUTED TO INSTRUMENT DRIFT. THE

1 1 INSTRUMENT WAS RECALIBRATED AND THE TEST WAS RERUN WITH SATISFACTORY

1 2 RESULTS.

1 3

1 4

| | FACILITY STATUS | % POWER | OTHER STATUS (30) | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION (32) |
|---|---|---|---|---|---|
| 1 5 | E (28) | 1 0 0 (29) | NA | B (31) | PERIODIC TEST |

| | ACTIVITY RELEASED | CONTENT OF RELEASE | AMOUNT OF ACTIVITY (35) | LOCATION OF RELEASE (36) |
|---|---|---|---|---|
| 1 6 | Z (33) | Z (34) | NA | NA |

PERSONNEL EXPOSURES

| | NUMBER | TYPE | DESCRIPTION (39) |
|---|---|---|---|
| 1 7 | 0 0 0 (37) | Z (38) | NA |

PERSONNEL INJURIES

| | NUMBER | DESCRIPTION (41) |
|---|---|---|
| 1 8 | 0 0 0 (40) | NA |

LOSS OF OR DAMAGE TO FACILITY (43)

| | TYPE | DESCRIPTION |
|---|---|---|
| 1 9 | Z (42) | NA |

PUBLICITY

| | ISSUED | DESCRIPTION (45) | NRC USE ONLY |
|---|---|---|---|
| 2 0 | N (44) | NA | |

NAME OF PREPARER M. L. Dawson (KLN) PHONE: 503/556-3713,xt.315

8109160115 810831
PDR ADOCK 05000344
S PDR