

OCT 30 1981

Docket Nos.: STN 50-454, STN 50-455  
and STN 50-456, STN 50-457

Mr. Louis O. DelGeorge  
Director of Nuclear Licensing  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. DelGeorge:

DISTRIBUTION

Docket  
LB#1 Rdg  
DEisenhut  
BJYoungblood  
MRushbrook  
RLTedesco  
KKiper  
WKane  
JWermiel  
LRubenstein  
RHVollmer  
TMurley  
RHartfield, MPA  
WJohnston  
OELD

OIE (#)

bcc:  
TERA  
NRC/PDR  
L/PDR  
NSIC  
TIC  
ACRS



We have made an initial review of the auxiliary feedwater system (AFWS) reliability analysis report for Byron which you submitted by letter dated September 18, 1981 and have identified the following area of major concern with the reliability of your AFWS. Your analysis indicates that for a loss of offsite power, AFWS reliability will not be in the high range (10 to 10 per demand) as identified in the criteria of SRP Section 10.4.9 for meeting the requirements of Criterion 44 of the General Design Criteria. We believe this is primarily due to the fact that the system does not have three AFWS pumps capable of functioning in a loss of offsite power condition.

We have recently been informed by members of your staff that although your current reliability analysis uses the methodology of NUREG-0611, it does not use NUREG-0611 failure rate data in all instances as required by the staff. We were further advised that you plan to revise your reliability analysis to correct these shortcomings and that you expect this reanalysis to result in a reliability for your AFWS consistent with the criteria of SRP Section 10.4.9.

We will review your revised analysis when it becomes available. However, we are not encouraged that the reanalysis will show compliance with the above criterion. We therefore encourage you to begin the engineering design effort at this time for implementation of a third AFWS pump capable of providing at least the minimum flow necessary to the steam generators for decay heat removal during a loss of offsite power condition and submit the design details of the AFWS modification as they become available.

Contact W. Kane, who will be the acting Byron Project Manager on (301)492-7050 if you desire to discuss this matter further.

Sincerely,

Original signed by  
Darrell G. Eisenhut

8111170188 811030  
PDR ADDOCK 05000454  
A PDR

Darrell G. Eisenhut, Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

\*SEE PREVIOUS CONCURRENCE FOR INITIALS

OFFICE	DL:LB#1*	DL:LB#1*	ASB*	DSI:C&CS*	DL:LB#1*	DL:AD/L*	DL:DIR
SURNAME	WKane/vt	KKiper	JWermiel	LRubenstein	BJYoungblood	RLTedesco	DEisenhut
DATE	10/ /81	10/ /81	10/ /81	10/ /81	10/ /81	10/ /81	10/ /81

Docket Nos. STN 50-454, STN 50-455  
and STN 50-456, STN 50-457

DISTRIBUTION:

Docket	bcc: TERA
LB#1 Reading	NRC PDR
DEisenhut	L PDR
BHYoungblood	NSIC
MRushbrook	TIC
RLTedesco	ACRS(16)
KKiper	
WKane	
JWermiel	
LRubenstein	
RHVoilmer	
TMurley	
RHartfield,MPA	
WJohnston	
OELD	
OI&E(3)	

Mr. Louis O. DelGeorge  
Director of Nuclear Licensing  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. DelGeorge:

We have made an initial review of the auxiliary feedwater system (AFWS) reliability analysis report for Byron which you submitted by letter dated September 18, 1981, and have identified the following area of major concern with the reliability of your AFWS. Your analysis indicates that for a loss of offsite power, AFWS reliability will not be in the high range ( $10^{-4}$  to  $10^{-5}$  per demand) as identified in the criteria of SRP Section 10.4.9 for meeting the requirements of Criterion 44 of the General Design Criteria. We believe this is primarily due to the fact that the system does not have three AFW pumps capable of functioning in a loss of offsite power condition.

We have recently been informed by members of your staff that although your current reliability analysis uses the methodology of NUREG-0611, it does not use NUREG-0611 failure rate data in all instances as required by the staff. We were further advised that you plan to revise your reliability analysis to correct these shortcomings and that you expect this reanalysis to result in a reliability for your AFWS consistent with the criteria of SRP Section 10.4.9.

We will review your revised analysis when it becomes available. However, we are not encouraged that the reanalysis will show compliance with the above criterion. We therefore encourage you to begin the engineering design effort at this time for implementation of a third AFWS pump capable of providing at least the minimum flow necessary to the steam generators for decay heat removal during a loss of offsite power condition and submit the design details of the AFWS modification as they become available.

Contact W. Kane, Byron Project Manager on (301)492-7050 if you desire to discuss this matter further.

Sincerely,

Darrell G. Eisenhut, Director  
Division of Licensing

cc: See next page

\*SEE PREVIOUS CONCURRENCE FOR INITIALS

retype 10/22	OFFICE	DL:LB#1*	DL:LB#1*	ASB*	DSI:C&CS*	DL:LB#1*	DL:LB#1*	DL:LB#1*
1gb	SURNAME	WKane:yt	KKiper	JWermiel	LRubenstein	BJYoungblood	RLTedesco	DGEisenhut
	DATE	10/21/81	10/20/81	10/21/81	10/21/81	10/21/81	10/22/81	10/21/81

Docket Nos.: STN 50-454, STN 50-455  
and STN 50-456, STN 50-457

Mr. Louis O. DelGeorge  
Director of Nuclear Licensing  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dear Mr. DelGeorge:

We have made an initial review of the auxiliary feedwater system (AFWS) reliability analysis report for Byron which you submitted by letter dated September 18, 1981 and have identified the following area of major concern with the reliability of your AFWS. Your analysis indicates that for a loss of offsite power, AFWS reliability will not be in the high range ( $10^{-4}$  to  $10^{-5}$  per demand) as identified in the criteria of SRP Section 10.4.9 for meeting the requirements of Criterion 44 of the General Design Criteria. We believe this is primarily due to the fact that the system does not have three AFW pumps capable of functioning in a loss of offsite power condition.

We have recently been informed by members of your staff that although your current reliability analysis uses the methodology of NUREG-0611, it does not use NUREG-0611 failure rate data in all instances as required by the staff. We were further advised that you plan to revise your reliability analysis to correct these shortcomings and that you expect this reanalysis to result in a reliability for your AFWS consistent with the criteria of SRP Section 10.4.9.

We will review your revised analysis when it becomes available. However, we are not encouraged that the reanalysis will show compliance with the above criterion. We therefore encourage you to begin the engineering design effort at this time for implementation of a third AFWS pump capable of providing at least the minimum flow necessary to the steam generators for decay heat removal during a loss of offsite power condition and submit the design details of the AFWS modification as they become available.

Contact the Byron Project Manager if you desire to discuss this matter further.

Sincerely,

Darrell G. Eisenhut, Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

\*See previous yellow.

cc: See next page

Dist.  
Docket File  
LB#1 Rdg  
DEisenhut  
BJYoungblood  
MRushbrook  
RLTedesco  
KKiper  
WKane  
JWermiel  
LRubenstein  
RYollmer  
TMurley  
RHartfield, MPA  
WJohnston  
OELD  
OIE (3)

bcc:  
TERA  
NRC/PDR  
L/PDR  
NSIC  
TIC  
ACRS (16)

OFFICE	DL:LB#1	DL:LB#1	ASB <i>Jsw</i>	<i>o d r f n</i>	DL:LB#1	DL:AD/L	DL:DIR
SURNAME	WKane /yt	KKiper*	JWermiel	LRubenstein	BJYoungblood	RLTedesco	DEisenhut
DATE	10/21/81	10/ /81	10/21/81	10/21/81	10/21/81	10/21/81	10/ /81

Docket Nos.: STN 50-454, STN 50-455  
and STN 50-456, STN 50-457

Mr. Louis O. DelGeorge  
Director of Nuclear Licensing  
Commonwealth Edison Company  
Post Office Box 767  
Chicago, Illinois 60690

Dist.  
Docket File OELD  
LB#1 Rdg  
DEisenhut bcc:  
BJYoungblood TERA  
MRushbrook NRC/PDR  
RLTedesco L/PDR  
KKiper NSIC  
WKane TIC  
JWermiel NSIC  
LRubenstein ACRS (16)  
RVollmer  
TMurley  
RHartfield, MPA  
WJohnston  
OELD

Dear Mr. DelGeorge:

We have made an initial review of the auxiliary feedwater system (AFWS) reliability analysis report for Byron which you submitted by letter dated September 18, 1981 and have identified the following area of major concern with the reliability of your AFWS. Your analysis indicates that for a loss of offsite power, AFWS reliability will not be in the high range ( $10^{-4}$  to  $10^{-5}$  per demand) as identified in the criteria of SRP Section 10.4.9 for meeting the requirements of Criterion 44 of the General Design Criteria. We believe this is primarily due to the fact that the system does not have three AFW pumps capable of functioning in a loss of offsite power condition.

We have recently been informed by members of your staff that although your current reliability analysis uses the methodology of NUREG-0611, it does not use NUREG-0611 failure rate data in all instances as required by the staff. We were further advised that you plan to revise your reliability analysis to correct these shortcomings and that you expect this reanalysis to result in a reliability for your AFWS consistent with the criteria of SRP Section 10.4.9. We are not encouraged that the reanalysis will obviate the need for a third pump. We will, of course, review your revised analysis as it becomes available.

Accordingly, we believe you should commit, as soon as possible, to provide a third AFW pump capable of providing at least the minimum flow necessary to the steam generators for decay heat removal during loss of offsite power conditions, and submit the design details of the AFWS modifications as they become available.

Contact the Byron Project Manager if you desire to discuss this matter further.

Sincerely,

Darrell G. Eisenhut, Director  
Division of Licensing  
Office of Nuclear Reactor Regulation

cc: See next page

OFFICE	DL:LB#1	DL:LB#1	ASB		DL:LB#1	AL:AD/L	AL:DIR
SURNAME	KKiper/yt	WKane	JWermiel	LRubenstein	BJYoungblood	RLTedesco	DEisenhut
DATE	10/20/81	10/20/81	10/ /81	10/ /81	10/ /81	10/ /81	10/ /81

Mr. Louis O. Del George  
Director of Nuclear Lic  
Commonwealth Edison Cr  
Post Office Box 767  
Chicago, Illinois 60

ccs:

Mr. William Kortier  
Atomic Power Distribution  
Westinghouse Electric Corporation  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

Paul M. Murphy, Esq.  
Isham, Lincoln & Beale  
One First National Plaza  
42nd Floor  
Chicago, Illinois 60603

Mrs. Phillip B. Johnson  
1907 Stratford Lane  
Rockford, Illinois 61107

Professor Axel Meyer  
Department of Physics  
Northern Illinois University  
DeKalb, Illinois 60115

C. Allen Bock, Esq.  
P. O. Box 342  
Urbanan, Illinois 61801

Thomas J. Gordon, Esq.  
Waalder, Evans & Gordon  
2503 S. Neil  
Champaign, Illinois 61820

Ms. Bridget Little Rorem  
Appleseed Coordinator  
117 North Linden Street  
Essex, Illinois 60935

Dr. Bruce von Zöllin  
Department of Biological Sciences  
Northern Illinois University  
DeKalb, Illinois 61107

Mr. Edward R. Crass  
Nuclear Safeguards and Licensing Division  
Sargent & Lundy Engineers  
55 East Monroe Street  
Chicago, Illinois 60603

Nuclear Regulatory Commission, Region III  
Office of Inspection and Enforcement  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Myron Cherry, Esq.  
Cherry, Flynn and Kanter  
1 IBM Plaza, Suite 4501  
Chicago, Illinois 60611

U. S. Nuclear Regulatory Commission  
Resident Inspectors Office  
4448 German Church Road  
Byron, IL 61010