

NOV 28 1989

Docket Nos. 50-317  
50-318

Baltimore Gas and Electric Company  
ATTN: Mr. George C. Creel  
Vice President  
Nuclear Energy  
Calvert Cliffs Nuclear Power Plant  
MD Rts 2 & 4, P. O. Box 1535  
Lusby, Maryland 20657

Gentlemen:

Subject: Combined Inspection Nos. 50-317/89-29 and 50-318/89-30

This refers to the routine safety inspection conducted by Dr. J. C. Jang of this office on November 13-17, 1989, of activities authorized by NRC License Nos. DPR-53 and DPR-69, and to the discussions of our findings held by Dr. J. Jang with Mr. R. Wenderlich and other members of your staff at the conclusion of the inspection.

Areas examined during this inspection include your gaseous and liquid effluent control programs as described in the NRC Region I Inspection Report which is enclosed with this letter. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

Within the scope of this inspection, no violations were observed. However, one unresolved item was identified regarding retrieval of the calibration results for gaseous and liquid effluent monitors and is discussed in Section 6.0 of the enclosed inspection report. You are requested to review the identified item and respond within 30 days of the date of this letter on actions planned or taken in regard to this item and their results.

The responses requested by this letter are not subject to clearance procedures for the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL-96-511. Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:  
Ronald R. Bellamy

Ronald R. Bellamy, Chief  
Facilities Radiological Safety  
and Safeguards Branch  
Division of Radiation Safety  
and Safeguards

Enclosure:  
NRC Region I Inspection Report Nos. 50-317/89-29 and 50-318/89-30

8912140009 891128  
PDR ADOCK 05000317  
Q PDC

"ORIGINAL RECORD COPY"

IE 06  
11

NOV 28 1989

Baltimore Gas and Electric Company 2

cc w/encl:

W. J. Lippold, General Supervisor, Technical Services Engineering

T. Magette, Administrator, Nuclear Evaluations

J. Lemons, Manager, Nuclear Outage Management

L. Russell, Manager, Calvert Cliffs Nuclear Power Plant

Public Document Room (PDR)

Local Public Document Room (LPDR)

Nuclear Safety Information Center (NSIC)

NRC Resident Inspector

State of Maryland (2)

"OFFICIAL RECORD COPY"

NOV 28 1989

Baltimore Gas and Electric Company 3

bcc w/encl:  
Region I Docket Room (with concurrences)  
Management Assistant, DRMA (w/o encl)  
J. Wiggins, DRP  
L. Tripp, DRP  
D. Limroth, DRP  
S. McNeil, NRR  
K. Lathrop, DRP

*[Signature]*  
RI:DRSS  
Lang  
11/21/89

*[Signature]*  
RI:DRSS  
Bores  
11/27/89

*[Signature]*  
RI:DRSS  
Bellamy  
11/28/89  
OFFICIAL RECORD COPY

OFFICIAL RECORD COPY