GE Supply

October 17, 1988

Via Certified Mail

Duke Power Company Oconee Nuclear Station Highway 130 Seneca, SC 29679

Onchet No 99901113

Attn: Quality Assurance

Re: NRC Information Notice #88-46

In response to the NRC Information Notice #88-46, dated July 8, 1988, regarding refurbished circuit breakers which may have been supplied to nuclear power plants, GE Supply undertook a review of its purchases, from January 1, 1986 to date, from the five identified suppliers and other non-manufacturer suppliers of circuit breakers.

That review indicates that GE Supply purchased from one of these suppliers circuit breakers or other products which in turn were sold to you either directly by GE Supply or by one of your suppliers who purchased them from GE Supply. Details of such transaction(s) have been provided to the Nuclear Regulatory Commission, and are summarized in the enclosed Attachment(s). GE Supply no longer purchases products from any of these suppliers.

We have no information indicating that these products are in any way defective, and it appears that they were sold for commercial application. However, we suggest that you evaluate your receipt and use of these products in order to determine whether they may constitute a substantial safety hazard and reportable condition under 10 C.F.R. Part 21.

If you have any questions regarding the enclosed information or require further information, please feel free to contact me at (203) 382-2778.

Very truly yours,

Tillo

Martha Castillo Counsel

MC/hvd

cc: W. McNulty, NRC K.R. Naidu, NRC

9001030026 881017 PDR GA999 EMVGEN 99901113 PM

5361a/6

Page _1 of _2_

ATTACHMENT 1

GE Supply Branch: GE Supply Customer: Customer P.O. Number:	Charlotte, NC Duke Power Company MR 04824		
		Ship To Address:	Oconee Nuclear Station Highway 130 Seneca, SC 29679

Date of Shipment: 7/8/87 Description of Item(s) Sold: 2 GE TE 122070

5303a

* *

6.1

498 2

ATTACHMENT _2_

GE Supply Branch:

Charlotte, NC

GE Supply Customer:

Duke Power Company

Customer P.O. Number:

WN 16386 - 70

Ship To Address:

Duke Power Company Oconee Nuclear Station Highway 130 Seneca, SC 29679

Date of Shipment: 3/20/87 Description of Item(s) Sold: 1 Gould ITE - E43B015

5303a