



October 17, 1988

Via Certified Mail

Florida Power & Light
St. Lucie Stores
6501 S. A1A
Jensen Beach, FL 34957

*Jacket No
99901113*

Attn: Quality Assurance

Re: NRC Information Notice #88-46

In response to the NRC Information Notice #88-46, dated July 8, 1988, regarding refurbished circuit breakers which may have been supplied to nuclear power plants, GE Supply undertook a review of its purchases, from January 1, 1986 to date, from the five identified suppliers and other non-manufacturer suppliers of circuit breakers.

That review indicates that GE Supply purchased from one of these suppliers circuit breakers or other products which in turn were sold to you either directly by GE Supply or by one of your suppliers who purchased them from GE Supply. Details of such transaction(s) have been provided to the Nuclear Regulatory Commission, and are summarized in the enclosed Attachment(s). GE Supply no longer purchases products from any of these suppliers.

We have no information indicating that these products are in any way defective, and it appears that they were sold for commercial application. However, we suggest that you evaluate your receipt and use of these products in order to determine whether they may constitute a substantial safety hazard and reportable condition under 10 C.F.R. Part 21.

If you have any questions regarding the enclosed information or require further information, please feel free to contact me at (203) 382-2778.

Very truly yours,

Martha Castillo
Counsel

MC/hvd

cc: W. McNulty, NRC
K.R. Naidu, NRC

5361a/7

*DFB
11*

ATTACHMENT 1

GE Supply Branch: Ft. Lauderdale, FL

GE Supply Customer: Florida Power & Light Company

Customer P.O. Number: C 88932 - 90252

Ship To Address: St. Lucie Stores - PSL-972
6501 S. A1A
Jensen Beach FL 34957
c/o PSL - 972

Date of Shipment: 5/3/88

Description of Item(s) Sold: 2 - Westinghouse Contact Kits - Size 3
2 - Westinghouse Contact Kits - Size 4

ATTACHMENT 2

GE Supply Branch: Ft. Lauderdale, FL

GE Supply Customer: Florida Power & Light Company

Customer P.O. Number: C 88932 - 90799

Ship To Address: St. Lucie Stores - PSL-972
6501 S. A1A
Jensen Beach FL 34957
c/o PSL - 972

Date of Shipment: 6/22/88

Description of Item(s) Sold: 1 - Square D 8536-SBO-2 Contactor, Open 3 - pole,
Size 0, 120V Control, 480 VAC -
3 Phase Line, 3.2 FL, Class 8536