

Duquesne Light Company

Beaver Valley Power Station
PO. Box 4
Shippingport, PA 15077-0004

JOHN D. SIEBER
Vice President - Nuclear Group

December 21, 1989

(412) 643-5255

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
NRC Bulletin 88-11

Gentlemen:


In accordance with Item 1.a of Bulletin 88-11, "Pressurizer Surge Line Thermal Stratification", we performed a visual inspection (ASME, Section XI, VT-3) of the Beaver Valley Unit 1 (BV-1) pressurizer surge line during the seventh refueling outage. No discernible distress or damage was identified for the pressurizer surge line piping, supports, pipe whip restraints, and anchor bolts.

However, during the inspection of this line, the rupture restraint gaps were found to be open greater than the original design analysis and the rupture restraints baseplate to embedments were welded together and the shear bars/lugs were not installed. These deficiencies were reported in Licensee Event Report (LER) 89-011-00. Both of the deficiencies were corrected during the seventh refueling outage.

We are continuing our efforts to complete the BV-1 plant specific analyses for Item 1.d of the Bulletin by January, 1991.

If you have any questions concerning this response, please contact my office.

Very truly yours,


J. D. Sieber
Vice President
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. W. T. Russell, NRC Region I Administrator
Mr. P. Tam, Sr. Project Manager
Mr. R. Saunders (VEPCO)

9001040020 891221
PDR ADOCK 05000334
Q PDC

TE30
110

COMMONWEALTH OF PENNSYLVANIA))
) SS:
COUNTY OF BEAVER))

On this 21st day of December, 1989,
before me, Tracey A. Baczek, a Notary Public in and for said
Commonwealth and County, personally appeared J. D. Sieber, who being
duly sworn, deposed, and said that (1) he is Vice President of
Duquesne Light, (2) he is duly authorized to execute and file the
foregoing Submittal on behalf of said Company, and (3) the statements
set forth in the Submittal are true and correct to the best of his
knowledge, information and belief.

Tracey A. Baczek

Notarial Seal
Tracey A. Baczek, Notary Public
Shippingport Boro, Beaver County
My Commission Expires Aug. 16, 1993

Member, Pennsylvania Association of Notaries