



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555  
December 21, 1989

Docket No. 50-155

Mr. Kenneth W. Berry  
Director, Nuclear Licensing  
Consumers Power Company  
1945 West Parnall Road  
Jackson, Michigan 49201

Dear Mr. Berry:

SUBJECT: RESPONSE TO GENERIC LETTER 89-04 - INSERVICE TESTING PROGRAMS  
(TAC NO. 74759)

By letter dated September 29, 1989, Consumers Power Company responded to Generic Letter 89-04 for Big Rock Point. Your response said that Big Rock Point Plant's Inservice Testing Program was reviewed to ensure compliance with NRC Generic Letter 89-04. Some changes in your program were addressed in accordance with the positions stated in GL 89-04 and revised relief requests were included with your response. You also stated that these changes bring Big Rock Point Plant's ISI Program into compliance with the requirements of GL 89-04.

Two of these proposed changes, Items 3 and 6, reflect procedure development and revision yet it does not indicate when this work would be completed. The intent of the Generic Letter was to have procedures written and implemented by the end of six months from the date of receipt of GL 89-04. See question 56 from the "Minutes of the Public Meetings on Generic Letter 89-04," dated October 25, 1989.

A subsequent call to Mr. Dan Eddy after receipt of your response on October 16, 1989, confirmed that both of these items will be completed by March 1, 1990. The completion of this effort by March 1, is acceptable, however, please confirm this in writing.


It was also noted, that Item 1 referred to installation of flow meters during the 1990 refueling outage. This should include the implementation of all applicable procedures for these flow meters.

9001040126 891221  
PDR ADDCK 05000155  
P PDC

*DFD*  
*110*

A detailed technical review of the response has not been performed; however, the area is subject to review or inspection at a later date. If a subsequent review or inspection identifies deficiencies in the response; this issue would be reopened. We consider this action complete upon receipt of the confirmation requested above.

Sincerely,



Robert M. Pulsifer, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III,  
IV, V & Special Projects  
Office of Nuclear Reactor Regulation

cc: See next page

Mr. Kenneth W. Berry  
Consumers Power Company

Big Rock Point Plant

cc:

Mr. Thomas A. McNish, Secretary  
Consumers Power Company  
212 West Michigan Avenue  
Jackson, Michigan 49201

Judd L. Bacon, Esquire  
Consumers Power Company  
212 West Michigan Avenue  
Jackson, Michigan 49201

Mr. Thomas W. Elward  
Plant Manager  
Big Rock Point Plant  
10269 U.S. 31 North  
Charlevoix, Michigan 49720

Jane E. Brannon, County Clerk  
County Building  
Charlevoix, Michigan 49720

Office of the Governor  
Room 1 - Capitol Building  
Lansing, Michigan 48913

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Nuclear Facilities and Environmental  
Monitoring Section Office  
Division of Radiological Health  
P. O. Box 30035  
Lansing, Michigan 48909

U.S. Nuclear Regulatory Commission  
Resident Inspector Office  
Big Rock Point Plant  
10253 U.S. 31 North  
Charlevoix, Michigan 49720



A detailed technical review of the response has not been performed; however, the area is subject to review or inspection at a later date. If a subsequent review or inspection identifies deficiencies in the response; this issue would be reopened. We consider this action complete upon receipt of the confirmation requested above.

Sincerely,

*Robert M. Pulsifer*  
Robert M. Pulsifer, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III,  
IV, V & Special Projects  
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

DOCKET FILE

PD31 GRAY FILE  
PSHUTTLEWORTH  
OGC  
ACRS(10)

NRC & LOCAL PDRs  
JZWOLINSKI  
RPULSIFER  
EJORDAN

LA/PD31:DRSP *MLL*  
PSHUTTLEWORTH  
12/19/89

PM/PD31:DRSP  
RPULSIFER *RP*  
12/19/89

~~(A)~~ PD31:DRSP  
JHOMA  
12/20/89