

REFUELING OPERATIONSCONTAINMENT VENTILATION ISOLATION SYSTEMLIMITING CONDITION FOR OPERATION

3.9.9 The Containment Ventilation Isolation System shall be OPERABLE.

APPLICABILITY: MODE 6

ACTION:

With the Containment Ventilation Isolation System inoperable, close each of the penetrations providing direct access from the Containment atmosphere to the outside atmosphere. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.9 The Containment Ventilation Isolation System shall be demonstrated OPERABLE within 100 hours prior to the start of and at least once per 7 days during CORE ALTERATIONS by verifying that Containment Ventilation isolation occurs on manual initiation and on a high radiation signal from each of the applicable Containment process radiation monitoring instrumentation channels specified in Table 3.3-13.

111

TROJAN-UNIT 1

3/4 9-9

Amendment No. 111
March 4, 1986

REFUELING OPERATIONSCONTAINMENT VENTILATION ISOLATION SYSTEMLIMITING CONDITION FOR OPERATION

3.9.9 The Containment Ventilation isolation system shall be OPERABLE.

APPLICABILITY: MODE 6

ACTION:

With the Containment Ventilation isolation system inoperable, close each of the penetrations providing direct access from the containment atmosphere to the outside atmosphere. The provisions of Specification 3.0.3 and 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.9 The Containment Ventilation isolation system shall be demonstrated OPERABLE within 100 hours prior to the start of and at least once per 7 days during CORE ALTERATIONS by verifying that Containment Ventilation isolation occurs on manual initiation and on a high radiation signal from each of the containment process radiation monitoring instrumentation channels.