

Telemecanique, Incorporated  
Westminster, Maryland 21157

Docket No. 99901011/88-01

NOTICE OF NONCONFORMANCE

Based upon the results of an NRC inspection conducted December 14-15, 1988, it appears that certain of your activities were not conducted in accordance with NRC requirements.

Criterion V of Appendix B to 10 CFR 50 states:

"Activities affecting quality shall be prescribed by documented instructions, procedures, or drawings, of a type appropriate to the circumstances and shall be accomplished in accordance with these instructions, procedures, or drawings. Instructions, procedures, or drawings shall include appropriate quantitative or qualitative acceptance criteria for determining that important activities have been satisfactorily accomplished."

Contrary to the above, Telemecanique has not implemented procedures as necessary to ensure that Certificates of Conformance are received from subvendors before material is dedicated and released by Telemecanique.

Additionally, the Originator of the Certificates of Conformance has not been audited by Telemecanique as necessary to verify the validity of the Certificates of Conformance. (88-01-01)

9001120124 900105  
PDR QA999 EMVTEMEC  
99901011 FDC